

PERFORMANCE DATA

LGB - Typical Selection Guide



Unit Size	Airflow	Minimum ΔPs				Discharge	Radiated
		Discharge – Basic in.w.g.	Discharge – 1 Row in.w.g.	Discharge – 2 Row in.w.g.	Bypass in.w.g.		
6	100	0.01	0.01	0.02	0.01	--	--
	200	0.01	0.02	0.05	0.01	--	--
	300	0.01	0.05	0.10	0.01	--	30
	400	0.01	0.07	0.16	0.01	--	37
8	400	0.01	0.07	0.16	0.09	--	22
	500	0.01	0.11	0.23	0.14	--	28
	600	0.01	0.15	0.32	0.19	--	32
	700	0.01	0.19	0.41	0.26	--	36
10	500	0.01	0.06	0.12	0.01	--	--
	700	0.01	0.10	0.22	0.01	--	22
	900	0.01	0.15	0.33	0.01	--	28
	1100	0.01	0.22	0.46	0.01	--	33
12	800	0.01	0.13	0.27	0.05	--	--
	1000	0.01	0.19	0.40	0.08	--	21
	1300	0.01	0.29	0.61	0.13	--	29
	1600	0.01	0.42	0.87	0.19	--	35
14	1100	0.01	0.13	0.27	0.06	--	--
	1400	0.01	0.19	0.41	0.09	--	23
	1700	0.01	0.27	0.57	0.14	--	29
	2100	0.01	0.39	0.81	0.20	--	35
16	1600	0.01	0.13	0.27	0.08	--	--
	2000	0.01	0.19	0.40	0.12	--	26
	2400	0.01	0.25	0.54	0.17	--	32
	2800	0.01	0.33	0.69	0.22	--	37

Performance Notes:

1. NCs are derived from sound power levels, which are obtained in accordance with AHRI Standard 880-2017 and ASHRAE Standard 130-2016.
2. NCs are derived from sound power levels which include duct end corrections per AHRI Standard 880 -2017.
3. Blank spaces (--) indicate NCs less than 20.
4. ΔPs is the difference in static pressure from inlet to discharge of the unit.
5. Listed minimum static pressure discharge is the static pressure loss through the unit with 100% airflow through the discharge outlet.
6. Listed minimum static pressure bypass is the static pressure loss through the unit with 100% airflow through the bypass outlet.
7. NC values are calculated based on procedures outlined in AHRI Standard 885-2008, "A Procedure for Estimating Occupied Space Sound Levels in the Application of Air Terminals and Air Outlets."

Radiated NC is based on a 5/8 in. mineral fiber tile ceiling per AHRI 885-2008, Appendix E typical attenuation values.

Radiated Attenuation	Octave Band					
	2	3	4	5	6	7
Total Deductions	18	19	20	26	31	36

(2) Discharge NC is based on environmental effect and space effect with no attenuation for downstream ductwork. Space effect is based on a room with a volume of 5000 ft³ and the sound source is 5 ft away from the occupant. These calculations are not covered by AHRI 885-2008 Appendix E.

Discharge Attenuation (NC2)	Octave Band Mid Frequency, Hz					
	2	3	4	5	6	7
Total Deductions	9	9	9	9	10	11

(1) Discharge NC is based on environmental effect, duct lining effect, end reflection, flex duct effect and sound power division per AHRI 885-2008 Appendix E typical attenuation factors.

Discharge Attenuation	Octave Band					
	2	3	4	5	6	7
< 300 cfm	24	28	39	53	59	40
300-700 cfm	27	29	40	51	53	39
> 700 cfm	29	30	41	51	52	39

LGB - AHRI Certification Rating Points

Unit Size	Rated Airflow	Minimum Operating Pressure Required	Radiated Sound Power Level, dB at 1.5 in. w.g. Octave Band						Discharge Sound Power Level, dB at 1.5 in. w.g. Octave Band					
			2	3	4	5	6	7	2	3	4	5	6	7
6	400	0.01	50	48	41	39	33	26	57	56	48	44	41	31
8	700	0.01	50	45	41	38	32	26	59	55	50	45	42	34
10	1100	0.01	49	43	40	36	32	26	58	53	46	44	40	29
12	1600	0.01	50	43	41	36	31	26	58	53	48	45	41	32
14	2100	0.01	50	44	43	37	32	27	59	52	46	45	40	30
16	2800	0.01	53	44	47	38	35	30	63	53	48	45	41	32

Performance Notes:

1. cfm, cubic feet per minute.
2. in. w.g., inches of water gauge.
3. Sound power levels expressed in decibels, (dB) re 10⁻¹² watts.

PERFORMANCE DATA

LGB - Radiated and Discharge Sound

Unit Size	Rated Airflow cfm	Sound Power Levels Lw, dB, RE 10^-12 Watts									
		Radiated Sound Octave Band			Discharge Sound Octave Band						
2	3	4	5	6	7	2	3	4	5	6	7
6	100	--	--	--	--	--	--	--	--	--	--
	200	38	35	26	23	--	43	41	31	25	--
	300	45	42	35	33	25	52	50	41	36	32
	400	50	48	41	39	33	57	56	48	44	41
8	400	38	34	29	24	--	48	44	36	29	24
	500	43	39	34	30	23	--	52	48	41	35
	600	47	42	38	34	28	--	56	52	46	41
	700	50	45	41	38	32	26	59	55	50	45
10	500	--	--	--	--	--	46	36	26	--	--
	700	40	34	30	25	21	--	51	43	35	31
	900	45	39	36	31	27	21	55	48	41	38
	1100	49	43	40	36	32	26	58	53	46	44
12	800	36	--	--	--	--	42	37	30	26	--
	1000	41	33	30	24	--	--	47	42	36	32
	1300	46	39	36	31	25	20	53	48	43	40
	1600	50	43	41	36	31	26	58	53	48	45
14	1100	38	30	27	--	--	--	44	37	30	27
	1400	42	35	33	27	20	--	50	43	36	34
	1700	46	39	38	32	26	21	54	47	41	39
	2100	50	44	43	37	32	27	59	52	46	45
16	1600	40	32	34	26	21	--	48	39	34	29
	2000	45	37	39	31	27	22	54	45	40	36
	2400	49	41	44	35	31	27	59	49	44	41
	2800	53	44	47	38	35	30	63	53	48	45

Performance Notes:

1. Test data obtained in accordance with AHRI Standard 880-2017 and ASHRAE Standard 130-2016.
2. AHRI certified data is highlighted in blue. All other data are application ratings.
3. Application ratings are outside the scope of the AHRI 880 Certification Program.
4. Dashes (--) indicate sound power levels below 36-29-26-22-19-17 for each octave band; values below these sound power levels are considered below significance per AHRI 880

PERFORMANCE DATA



LGB - 1 and 2 Row Hot Water Coil Data – IP Units

Model Size 6 and 8

Rows	Coil gpm	HD Loss	Airflow Rate (cfm)					
			100	200	300	400	500	600
1 Row	0.5	0.2	5.2	7.4	8.7	9.6	10.3	10.9
	1	0.59	5.8	8.6	10.4	11.8	12.9	13.8
	2	1.77	6.1	9.3	11.6	13.4	14.8	16
	3	3.37	6.2	9.6	12.1	14	15.6	16.9
	Through the Coil, ΔPs		0.01	0.02	0.05	0.09	0.13	0.18
2 Row	1	0.25	9.2	14	17.2	19.4	21.2	22.6
	2	0.79	9.8	15.8	20	23.3	25.9	28
	4	2.56	10.2	16.9	21.9	25.8	29.1	32
	6	5.16	10.4	17.3	22.6	26.9	30.5	33.6
	Through the Coil, ΔPs		0.01	0.05	0.11	0.18	0.27	0.38

Size 6

Model Size 10 and 12

Rows	Coil gpm	HD Loss	Airflow Rate (cfm)					
			400	600	800	1000	1200	1400
1 Row	1	0.19	12.9	15	16.5	17.6	18.5	19.2
	2	0.61	15	18	20.2	22	23.4	24.6
	4	2.02	16.4	20.1	22.9	25.2	27.1	28.7
	6	4.15	17	21	24.1	26.6	28.7	30.5
	Through the Coil, ΔPs		0.04	0.09	0.15	0.23	0.32	0.42
2 Row	1	0.33	22.4	26.3	29	30.9	32.4	33.6
	2	1	26.7	32.7	37.1	40.5	43.3	45.5
	4	3.16	29.6	37.3	43.2	48	51.9	55.3
	6	6.27	30.7	39.1	45.7	51.2	55.7	59.6
	Through the Coil, ΔPs		0.09	0.19	0.32	0.48	0.66	0.88

Size 10

Model Size 14

Rows	Coil gpm	HD Loss	Airflow Rate (cfm)					
			1100	1300	1500	1700	1900	2100
1 Row	1	0.23	21.2	22.2	23	23.7	24.3	24.8
	2	0.72	26.7	28.4	29.8	31	32	33
	4	2.36	30.8	33.1	35	36.7	38.2	39.6
	6	4.77	32.6	35.1	37.3	39.2	40.9	42.5
	Through the Coil, ΔPs		0.15	0.21	0.27	0.33	0.41	0.49
2 Row	1	0.41	35.7	37.3	38.5	39.5	40.4	41.2
	2	1.24	47.8	50.8	53.3	55.5	57.4	59
	4	3.84	57.3	61.8	65.7	69.1	72.1	74.8
	6	7.52	61.3	66.5	71.1	75.2	78.8	82.1
	Through the Coil, ΔPs		0.32	0.43	0.56	0.7	0.86	1.03

Model Size 16

Rows	Coil gpm	HD Loss	Airflow Rate (cfm)					
			1700	1900	2100	2300	2500	2700
1 Row	1	0.29	28.2	29	29.6	30.2	30.7	31.1
	2	0.9	37.3	38.7	39.9	41	42	42.9
	4	2.85	44.5	46.5	48.3	49.9	51.5	52.8
	6	5.69	47.6	49.9	52	53.9	55.7	57.3
	Through the Coil, ΔPs		0.17	0.21	0.25	0.29	0.34	0.39
2 Row	1.5	0.43	53.5	55	56.3	57.5	58.5	59.4
	3	1.36	71.7	74.7	77.3	79.7	81.8	83.7
	6	4.45	86.1	90.5	94.5	98.2	101.5	104.6
	9	9.01	92.2	97.4	102.1	106.4	110.4	114.1
	Through the Coil, ΔPs		0.36	0.44	0.52	0.62	0.72	0.82

Performance Notes:

1. Tabulated values are in MBH (thousands of Btu per hour).
2. Tables are based on a temperature difference of 125°F (180 °F entering water temperature and 55 °F entering air temperature). For other temperature differences, multiply MBH values by factors listed below.
3. Minimum air and water values are based on ASHRAE recommendations for coil selection. For selections outside these tabulated air or water flow values, please consult your local Price representative.
4. HD (head) loss is in ft of water.
5. ΔPs, is the pressure drop in in. of water across the coil.
6. Air temperature rise = ATR
ATR (°F) = 927 x MBH/cfm
7. Water temperature rise = WTR
WTR (°F) = 2.04 x MBH/gpm
8. Values in tables are listed for 0 ft of altitude and no glycol in the system.
9. Reheat coils used in this unit have performance rated and certified in accordance with the current edition of AHRI Standard 410.