


PFC - PRICE FAN COLUMN



NOTE:

- UNIT TOLERANCE TO +/- 1/32
- UNIT SHALL BE BUILT WITH SOLID GALVANIZED SHEETMETAL ON THE EXTERIOR. INTERIOR WILL CONTAIN 23% PERFORATED SHEETMETAL.

EXTERIOR CABINET MATERIAL:

- 18G GALV NO PAINT
- 18G GALV W/ PAINT
- 16G GALV NO PAINT
- 16G GALV W/ PAINT

CABINET INSULATION:

- 2" (51) AFB AT 3 LBS
- 2" (51) AFB AT 1.5 LBS W/LINER

ACCESS DOOR HANDLE:

- STANDARD WITH CAMLOCKS
- LATCHING WITH COMPOSITE HANDLES
- VENTLOCK DOOR LATCH

WINDOW:

- NONE
- FAN DOOR WINDOW

FILTER GAUGE:

- NONE
- MINIHELIC

FILTER:

- 2" MERV8
- 2" MERV13
- 4" MERV8 SPECIAL
- 4" MERV13 SPECIAL

FACTORY MTN ACTUATOR

- NONE
- 24 VOLT
- 120 VOLT

FAN PIEZOMETER RING:

- NONE
- PIEZOMETER RING ONLY
- PIEZOMETER RING W/4-20mA

FAN SHAFT GRND KIT:

- NONE
- SHAFT GROUNDING KIT

FAN NON-FUSED DISC:

- NONE
- NONE FUSED DISCONNECT

LIGHT PACKAGE:

- NONE
- LIGHT PACKAGE

DUCT MOUNTED TEMP. SENSOR:

- DISCHARGE AIR TEMP. SENSOR

CONNECTION SIDE:

- LEFT HAND COIL CONNECTION
- RIGHT HAND COIL CONNECTION

UNIT DISCHARGE:

- 4 WAY
- 3 WAY (CONFIGURABLE)
- 2 WAY (CONFIGURABLE)

UNDERFLOOR HEIGHT (UH)

- 8" (203)
- 9" (229)
- 10" (254)
- 11" (279)
- 12" (305)
- 13" (330)
- 14" (356)

		AIRFLOW	WIDTH	HEIGHT	# OF SHIP
<input type="checkbox"/>	(SIZE)**	(CFM)	(A)*	(B)	SECTION
<input type="checkbox"/>	PFC-25	2500	30 (762)	78.5 (1994)	1
<input type="checkbox"/>	PFC-50	5000	40 (1016)	101 (2565)	2
<input type="checkbox"/>	PFC-75	7500	49 (1245)	121 (3073)	2
<input type="checkbox"/>	PFC-100	10000	52 (1321)	129 (3277)	2
<input type="checkbox"/>	PFC-125	12500	58 (1473)	139 (3531)	2
<input type="checkbox"/>	PFC-150	15000	64 (1626)	158 (4013)	2
<input type="checkbox"/>	PFC-175	17500	72 (1829)	168 (4267)	3

* ALL UNITS HAVE A SQUARE CROSS-SECTION

** VOLTAGE OPTIONS: 208/3/60, 230/3/60, 460/3/60 & 575/3/60

ALL METRIC DIMENSIONS [] ARE SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO METRIC AND ROUNDED TO THE NEAREST MILLIMETER.

PROJECT:		price	
ENGINEER:			
CUSTOMER:		PFC PRICE FAN COLUMN	
SUBMITTAL DATE:			
SPEC. SYMBOL:		DATE DRAWN: 4/3/2024	