



NOTE
CONTROLLER MUST BE MOUNTED IN AN UPRIGHT POSITION AS SHOWN. IF ACTUATOR MUST BE MOUNTED IN OTHER THAN UPRIGHT POSITION LEAVE A LOOP IN THE FLOW SENSOR TUBING SO THAT CONDENSATION WILL NOT RUN INTO THE CONTROLLER.

NOTE
* INDICATES SUPPLIED BY CONTROL CONTRACTOR

LEGEND
----- FIELD INSTALLED WIRING

PROJECT:		PRICE [®]
ENGINEER:		
CUSTOMER:		12330
SUBMITTAL DATE:	SPEC. SYMBOL:	1/29/2010

**SINGLE DUCT
TELETROL iVAV TSC**
Clg., HW REHEAT
Variable or Constant Volume