



NOTE
CONTROLLER MUST BE MOUNTED IN AN UPRIGHT POSITION AS SHOWN. IF ACTUATOR MUST BE MOUNTED IN OTHER THAN UPRIGHT POSITION LEAVE A LOOP IN THE FLOW SENSOR TUBING SO THAT CONDENSATION WILL NOT RUN INTO THE CONTROLLER.

NOTE
* INDICATES SUPPLIED BY CONTROL CONTRACTOR
** WIRE STAGES OF HEAT AS REQUIRED BY ORDER

PROJECT:		PRICE [®]
ENGINEER:		
CUSTOMER:		12331
SUBMITTAL DATE:	SPEC. SYMBOL:	1/29/2010
<p>SINGLE DUCT NOVAR VAV4040 Clg., UP TO 2 STG ELEC REHEAT Variable or Constant Volume</p>		