



NOTE: CONTROLLER OUTPUTS MUST BE CAPABLE OF HANDLING PRICE CONTACTOR INRUSH CURRENT UP TO 1.7 AMP AND HOLDING CURRENT UP TO 0.5 AMP.

IF CONTROLLER OUTPUTS CANNOT HANDLE THE INRUSH AND HOLDING CURRENTS, INTERPOSING RELAYS ARE REQUIRED TO ENERGIZE CONTACTOR COILS AND WILL BE SUPPLIED BY CUSTOMER.

NOTE :
SOME CONTROLS HAVE PREWIRED-JUMPER. INSTALL JUMPER IF PREWIRED-JUMPER IS NOT PRESENT.

NOTE :

* INDICATES COMPONENTS SUPPLIED BY CONTROL CONTRACTOR.

** WIRE STAGES OF HEAT AS REQUIRED BY ORDER

LEGEND

— FACTORY FLOW SENSOR TUBING

— FACTORY ELECTRICAL WIRING

PROJECT:

ENGINEER:

CUSTOMER:

SUBMITTAL DATE:

SPEC. SYMBOL:



**FAN POWERED
HONEYWELL PVB/L 6436AS**
COOLING,
OPT. HW REHEAT or
UP TO 3-STG ELEC REHEAT
VARIABLE/CONSTANT VOLUME

W16255

2018/05/09