

PERFORMANCE DATA

Unit Size L. x W (mm) [Face Area (m ²)]	Face Velocity (m/s)	Air Flow (L/s)	Total Pressure (Pa)	Static Pressure (Pa)	Noise Criteria (NC)	Proximity to Outlet (m)			
						$\Delta T = 2.8\text{ }^{\circ}\text{C}$		$\Delta T = 5.6\text{ }^{\circ}\text{C}$	
						DR		DR	
						15%	20%	15%	20%
600 x 300 [0.19]	0.10	19	-	-	-	-	-	-	-
	0.15	28	-	-	-	-	-	-	-
	0.20	38	2	2	-	-	-	-	-
	0.25	47	5	5	-	-	0.3	-	-
1200 x 300 [0.37]	0.10	38	-	-	-	-	-	-	-
	0.15	57	-	-	-	-	-	0.3	-
	0.20	76	2	2	-	-	0.9	-	-
	0.25	94	5	5	-	-	1.2	0.3	-
1825 x 300 [0.56]	0.10	57	-	-	-	-	-	0.3	-
	0.15	85	-	-	-	-	-	1.2	0.3
	0.20	113	-	-	-	0.6	-	1.5	0.6
	0.25	142	2	2	-	0.9	-	2.4	1.2

Performance Notes:

1. Sound and pressure drop tested in accordance with ASHRAE Standard 70-2006 (RA 2011) "Method of Testing for Rating the Performance of Air Outlets and Inlets."
2. Air flow is in Litres per second, L/s.
3. The NC values, sound pressure level, are based on a room absorption of 10 dB, re 10-12 watts and one diffuser
4. ΔT is the difference between the room air temperature 1 m above the floor and the temperature of the supply air.
5. Proximity to outlet is the minimum distance from an outlet to the occupant in order to achieve the listed DR value.
6. Distances closer to the diffuser have a higher DR than the cataloged value.
7. DR is the predicted percentage of people dissatisfied (PPD) due to draft. A value of less than 20 meets the requirements of ASHRAE Standard 55-2013, Thermal Environmental Conditions for Human Occupancy.
8. Blanks (-) indicate that the DR is below the specified value at all distances from the diffuser face.
9. DR catalog data is presented for an occupant density of 25 people/100 m², which is the default occupancy density for classrooms (ages 5-8) given by ASHRAE 62.1-2013. For other occupant densities, please refer to the DV Room Designer Software.
10. Performance data for standard diffusers not listed in the catalog is available in Price AIO Software.