

PERFORMANCE DATA

DR180 Wall or Pillar Unit

Unit Size W x H [in]	Inlet Size [in]	Face Velocity [fpm]	Air Flow [cfm]	Total Pressure [in. w.g.]	Static Pressure [in. w.g.]	Noise Criteria [NC]	Proximity to Outlet [ft]			
							DR 20%		Adjacent Zone	
							ΔT = 5 °F	ΔT = 10 °F	ΔT = 5°F	ΔT = 10°F
18 x 24	6	20	85	0.02	-	-	-	1	-	-
		30	128	0.05	0.02	-	1	2	1	1
		40	171	0.09	0.04	21	1	3	2	3
		50	213	0.13	0.06	28	2	5	3	4
24 x 24	8	20	115	0.01	-	-	-	1	-	-
		30	173	0.03	0.02	-	1	2	1	2
		40	230	0.05	0.03	-	1	3	2	3
		50	288	0.08	0.04	19	2	5	3	4
30 x 24	8	20	145	0.02	-	-	-	1	-	-
		30	217	0.04	0.02	-	1	2	1	2
		40	290	0.07	0.03	-	1	3	2	3
		50	362	0.12	0.05	18	2	5	3	4
18 x 36	6	20	130	0.04	0.01	-	1	2	1	1
		30	196	0.09	0.02	22	2	4	2	3
	10 x 4	40	261	0.09	0.04	26	3	6	3	5
		50	326	0.14	0.06	34	4	8	5	8
24 x 36	8	20	176	0.02	-	-	1	2	1	1
		30	264	0.05	0.02	-	2	4	2	3
		40	352	0.10	0.03	20	3	6	3	6
		50	440	0.15	0.05	27	4	8	5	9
30 x 36	8	20	221	0.03	-	-	1	2	1	1
		30	332	0.04	0.01	-	2	4	2	3
	10	40	443	0.07	0.03	-	3	6	3	6
		50	554	0.11	0.04	19	4	8	5	9
18 x 48	6	20	175	0.06	-	20	1	3	1	2
		30	263	0.13	0.02	33	2	6	3	5
	10 x 4	40	351	0.14	0.04	36	4	9	5	9
		50	439	0.21	0.06	44	6	12	9	14
24 x 48	8	20	237	0.04	-	-	1	3	1	2
		30	355	0.08	0.02	19	2	6	3	5
	9	40	473	0.10	0.03	25	4	9	5	9
		50	592	0.16	0.05	32	6	12	8	14
30 x 48	10	20	298	0.03	-	-	1	3	1	3
		30	447	0.06	0.02	-	2	6	3	5
	12	40	596	0.10	0.03	19	4	9	5	9
		50	745	0.09	0.04	21	6	12	8	15
24 x 60	9	20	297	0.03	-	-	2	4	2	4
		30	446	0.08	0.01	23	4	8	5	8
	16 x 5	40	595	0.10	0.03	28	6	12	8	14
		50	744	0.15	0.04	36	8	16	12	22
30 x 60	12	20	374	0.02	-	-	2	4	1	4
		30	561	0.04	0.01	-	4	8	5	8
	40	40	749	0.08	0.02	19	6	12	8	14
		50	936	0.12	0.04	27	8	16	12	22
	20 x 6	40	749	0.07	0.02	18	6	12	8	14
	50	936	0.11	0.04	26	8	16	12	22	

Performance Notes:

- Sound and pressure drop tested in accordance with ASHRAE Standard 70-2006 "Method of Testing for Rating the Performance of Air Outlets and Inlets."
- Air flow is in cubic feet per minute, cfm.
- Pressure is in inches of water, in. w.g.
- The NC values, sound pressure level, are based on a room absorption of 10 dB, re 10^{-12} watts and one diffuser.
- ΔT is the difference between the room air temperature 3 ½ ft above the floor and the temperature of the supply air.
- Proximity to outlet is the minimum distance from an outlet to the occupant in order to achieve the listed DR value.
- Distances closer to the diffuser have a higher DR than the catalogued value.
- DR is the predicted percentage of people dissatisfied (PPD) due to draft. A value of less than 20 meets the requirements of ASHRAE Standard 55-2004, Thermal Environmental Conditions for Human Occupancy.
- Blanks “-” indicate that the DR is below the specified value at all distances from the diffuser face.
- DR catalog data is presented for an occupant density of 25 people/1000ft², which is the default occupancy density for classrooms (ages 5-8) given by ASHRAE 62.1-2004. For other occupant densities, please refer to the DV Room Designer Software.
- The Adjacent zone describes the distance from the face of the diffuser and measured 1 in. from the floor, at which the supply air velocity is 50 fpm.

PERFORMANCE DATA

DR180 U-shaped Wall or Pillar Unit

Unit Size W x H [in]	Inlet Size [in]	Face Velocity [fpm]	Air Flow [cfm]	Total Pressure [in. w.g.]	Static Pressure [in. w.g.]	Noise Criteria [NC]	Proximity to Outlet [ft]			
							DR 20%		Adjacent Zone	
							ΔT = 5 °F	ΔT = 10 °F	ΔT = 5 °F	ΔT = 10 °F
18 x 36	12	20	217	0.01	-	-	1	2	1	2
		30	326	0.02	0.01	-	2	2	2	3
		40	434	0.04	0.03	-	2	3	3	4
		50	543	0.07	0.04	21	2	4	4	5
24 x 36	16	20	292	0.01	-	-	1	2	1	2
		30	437	0.02	0.01	-	2	2	2	3
		40	583	0.03	0.02	-	2	3	3	3
		50	729	0.05	0.03	17	2	4	4	4
30 x 36	20	20	366	0.01	-	-	1	2	1	2
		30	549	0.01	-	-	2	2	2	2
		40	732	0.02	0.01	-	2	3	3	3
		50	915	0.03	0.02	-	2	4	3	4
36 x 36	24	20	441	0.00	-	-	1	2	1	2
		30	661	0.01	-	-	2	2	2	2
		40	881	0.02	0.01	-	2	3	3	3
		50	1101	0.03	0.02	-	2	4	3	4
18 x 48	12	20	292	0.01	-	-	2	2	2	2
		30	438	0.03	0.01	-	2	3	3	4
		40	585	0.06	0.02	18	3	4	4	5
		50	731	0.09	0.03	25	4	5	5	7
24 x 48	16	20	392	0.01	-	-	2	2	2	2
		30	589	0.02	0.01	-	2	3	3	4
		40	785	0.04	0.02	-	3	4	4	5
		50	981	0.06	0.03	20	4	5	5	6
30 x 48	20	20	492	0.01	-	-	2	2	2	2
		30	739	0.02	0.01	-	2	3	3	4
		40	985	0.03	0.02	-	3	4	4	5
		50	1231	0.05	0.03	-	4	5	5	6
18 x 60	12	20	367	0.01	-	-	2	3	3	3
		30	551	0.03	-	-	3	4	4	5
		40	735	0.06	-	20	4	5	6	7
		50	918	0.09	-	27	5	7	8	9
24 x 60	16	20	493	0.01	-	-	2	3	3	3
		30	740	0.03	-	-	3	4	4	5
		40	986	0.05	0.02	-	4	5	6	7
		50	1233	0.08	0.03	20	5	7	7	8

Performance Notes:

- Sound and pressure drop tested in accordance with ASHRAE Standard 70-2006 "Method of Testing for Rating the Performance of Air Outlets and Inlets."
- Air flow is in cubic feet per minute, cfm.
- Pressure is in inches of water, in. w.g.
- The NC values, sound pressure level, are based on a room absorption of 10 dB, re 10⁻¹² watts and one diffuser.
- ΔT is the difference between the room air temperature 3 ½ ft above the floor and the temperature of the supply air.
- Proximity to outlet is the minimum distance from an outlet to the occupant in order to achieve the listed DR value.
- Distances closer to the diffuser have a higher DR than the catalogued value.
- DR is the predicted percentage of people dissatisfied (PPD) due to draft. A value of less than 20 meets the requirements of ASHRAE Standard 55-2004, Thermal Environmental Conditions for Human Occupancy.
- Blanks “-” indicate that the DR is below the specified value at all distances from the diffuser face.
- DR catalog data is presented for an occupant density of 25 people/1000ft², which is the default occupancy density for classrooms (ages 5-8) given by ASHRAE 62.1-2004. For other occupant densities, please refer to the DV Room Designer Software.
- The Adjacent zone describes the distance from the face of the diffuser and measured 1 in. from the floor, at which the supply air velocity is 50 fpm.