### **PURAFLO®** Cleanroom Technologies for Commercial Applications

# PERFORMANCE DATA - METRIC

### Supply

Unit Size (mm)	Filter	Motor - Fan	Active Filter Area (m²)	Max L/s	Watts at Max L/s	L/s at 0.46 m/s	Watts at 0.46 m/s	Sound (dBA) at 0.46 m/s	Weight (kg)
600 x 1200	RSR	ECM - BC	0.49	354	140	227	60	53	34
		ECM - FC	0.49	354	210	227	80	52	34
		PSC - BC	0.49	354	215	227	160	54	34
		PSC - FC	0.49	354	395	227	295	52	34
600 x 900	RSR	ECM - BC	0.35	255	110	163	50	53	29
		ECM - FC	0.35	255	150	163	65	50	28
		PSC - BC	0.35	255	175	163	150	51	29
		PSC - FC	0.35	255	320	163	230	49	28
600 x 600	RSR	ECM - FC	0.21	142	125	99	65	48	24
		PSC - FC	0.21	142	180	99	125	52	24

#### **Performance Notes:**

1. Units are tested in accordance with IEST RP-CC002.2, Recommended Practice for Unidirectional Flow Clean-Air Devices.

2. Sound levels were measured with unit installed in a T-Bar ceiling, with gasket, in a standard room. Sound levels in dBA were measured at a distance of 760 mm from the filter face, with the unit set to produce 0.46 m/s average face velocity. (Note that data is for a clean filter only. If fan speed is increased to compensate for filter loading the noise level will increase.)

3. For electrical circuit sizing, consult the "max amps" shown on the submittal for each product configuration and voltage.

4. All data is based on a unit with a clean filter.

5. 0.46 m/s values are based on active filter area.

6. Heat Gain: BTUh = Watts x 3.413

### **Reverse Flow**

Unit Size (mm)	Filter	Motor - Fan	Active Filter Area (m²)	Max L/s	Watts at Max L/s	L/s at 0.46 m/s	Watts at 0.46 m/s	Sound (dBA) at 0.46 m/s	Weight (kg)
600 X 1200	RSR	ECM - BC	0.5	354	185	227	75	54	26
		ECM - FC	0.5	354	430	227	315	58	26
600 X 600		PSC - BC	0.2	142	120	99	65	50	34
		PSC - FC	0.2	142	185	99	130	52	34

#### Performance Notes:

7. Units are tested in accordance with IEST RP-CC002.2, Recommended Practice for Unidirectional Flow Clean-Air Devices.

8. Sound levels were measured with unit installed in a T-Bar ceiling, with gasket, in a standard room. Sound levels in dBA were measured at a distance of 760 mm from the filter face, with the unit set to produce 0.46 m/s average face velocity. (Note that data is for a clean filter only. If fan speed is increased to compensate for filter loading the noise level will increase.)

9. For electrical circuit sizing, consult the "max amps" shown on the submittal for each product configuration and voltage.

10. All data is based on a unit with a clean filter.

11. 0.46 m/s values are based on active filter area.

12. Heat Gain: BTUh = Watts x 3.413

## Reverse Flow - UVC Option

Unit Size (mm)	Filter	Motor - Fan	Active Filter Area (m²)	Max L/s	Watts at Max L/s	L/s at 0.30 m/s	Watts at 0.30 m/s	Sound (dBA) at 0.30 m/s	Weight (kg)
600 x 1200 (w/ UVC)	RSR	ECM - FC	0.5	274	350	151	95	55	36
		PSC - FC	0.5	274	430	151	160	57	36

#### Performance Notes:

1. Units are tested in accordance with IEST RP-CC002.2, Recommended Practice for Unidirectional Flow Clean-Air Devices.

2. Sound levels were measured with unit installed in a T-Bar ceiling, with gasket, in a standard room. Sound levels in dBA were measured at a distance of 760 mm from the filter face, with the unit set to produce 0.30 m/s average face velocity. (Note that data is for a clean filter only. If fan speed is increased to compensate for filter loading the noise level will increase.)

3. For electrical circuit sizing, consult the "max amps" shown on the submittal for each product configuration and voltage.

4. All data is based on a unit with a clean filter.

5. 0.30 m/s values are based on active filter area.

6. Heat gain: BTUh = Watts x 3.413