

PERFORMANCE DATA

Linear Bar Grille (LBP/LBPH) – Core 15A

Size	Static Pressure (in. w.g.)		0.011	0.024	0.044	0.069	0.098	0.133	0.175	0.222
1½ in.	Flow Rate (cfm/ft)		12	19	25	31	37	43	50	56
	Sound (NC)		-	-	-	19	24	28	32	35
	Throw (ft)	Sill or Floor Sidewall	1-1-1 2-4-6	2-2-2 4-7-10	4-4-4 6-9-13	6-6-6 7-11-16	8-8-9 8-13-19	9-10-11 9-15-21	10-11-13 10-16-23	12-13-15 12-18-25
2 in.	Flow Rate (cfm/ft)		19	28	37	47	56	66	75	84
	Sound (NC)		-	-	-	18	23	28	31	35
	Throw (ft)	Sill or Floor Sidewall	1-1-1 3-5-7	4-4-4 5-8-11	6-6-6 7-11-15	9-9-9 9-14-19	11-11-12 11-16-22	12-13-15 12-18-25	14-15-17 14-20-27	15-17-19 15-22-29
2½ in.	Flow Rate (cfm/ft)		26	39	52	65	78	91	104	117
	Sound (NC)		-	-	-	19	24	29	33	36
	Throw (ft)	Sill or Floor Sidewall	1-1-1 4-6-8	5-5-5 6-9-12	8-8-8 8-12-16	10-10-11 10-15-20	13-14-15 13-18-24	15-16-17 15-21-27	16-18-20 16-22-30	20-20-21 20-27-34
3 in.	Flow Rate (cfm/ft)		33	50	66	83	100	116	133	149
	Sound (NC)		-	-	-	20	25	30	34	37
	Throw (ft)	Sill or Floor Sidewall	2-2-2 4-6-9	6-6-6 7-10-14	9-9-10 9-13-18	12-12-13 12-17-22	15-16-17 15-20-25	18-19-20 18-23-29	20-21-22 20-26-33	23-23-23 23-30-37
3½ in.	Flow Rate (cfm/ft)		41	61	82	102	122	143	163	184
	Sound (NC)		-	-	-	21	26	31	35	38
	Throw (ft)	Sill or Floor Sidewall	2-2-2 5-7-10	7-7-7 8-11-15	10-10-11 10-15-20	15-15-15 15-19-24	17-18-19 17-22-27	20-21-22 20-25-31	22-23-24 22-28-35	25-25-26 25-32-39
4 in.	Flow Rate (cfm/ft)		49	73	98	122	146	171	195	220
	Sound (NC)		-	-	-	16	22	28	32	36
	Throw (ft)	Sill or Floor Sidewall	3-3-3 6-8-11	8-8-8 9-12-16	12-12-13 12-16-20	15-15-16 15-20-25	19-19-20 19-24-29	21-22-23 21-26-32	24-24-25 24-30-36	26-26-27 26-33-40
5 in.	Flow Rate (cfm/ft)		63	94	125	157	188	220	251	282
	Sound (NC)		-	-	-	16	22	27	32	36
	Throw (ft)	Sill or Floor Sidewall	4-4-4 7-9-12	9-9-9 11-14-18	14-14-14 14-18-22	17-17-17 17-21-26	21-21-22 21-26-31	24-24-24 24-29-35	27-27-27 27-33-39	29-29-29 30-36-43
6 in.	Flow Rate (cfm/ft)		78	116	155	194	233	272	310	349
	Sound (NC)		-	-	-	18	24	29	34	37
	Throw (ft)	Sill or Floor Sidewall	5-5-5 8-10-13	10-10-10 12-15-19	15-15-15 15-19-23	18-18-18 20-24-28	23-23-23 23-27-32	25-25-25 26-31-37	28-28-29 29-34-40	31-31-31 33-39-45

For Performance Notes and Correction Factors, see end of section.

Linear Bar Grille (LBP/LBPH) – Core 16A

Size	Static Pressure (in. w.g.)		0.013	0.027	0.05	0.079	0.111	0.151	0.199	0.252
1½ in.	Flow Rate (cfm/ft)		14	20	27	34	41	48	54	61
	Sound (NC)		-	-	-	22	29	34	38	42
	Throw (ft)	Sill or Floor Sidewall	1-1-1 2-4-6	3-3-3 4-7-10	4-4-4 6-10-14	7-7-7 7-12-17	9-9-10 9-14-20	10-11-12 10-16-22	12-13-15 12-18-25	13-14-16 13-20-27
2 in.	Flow Rate (cfm/ft)		20	29	39	49	59	69	78	88
	Sound (NC)		-	-	-	20	26	31	36	40
	Throw (ft)	Sill or Floor Sidewall	1-1-1 3-5-7	4-4-4 5-8-11	6-6-6 7-11-15	9-9-9 9-14-19	11-11-12 11-16-22	12-13-15 12-18-25	14-16-18 14-20-27	15-17-19 15-22-30
2½ in.	Flow Rate (cfm/ft)		26	39	52	65	78	91	104	117
	Sound (NC)		-	-	-	20	26	31	36	40
	Throw (ft)	Sill or Floor Sidewall	1-1-1 4-6-8	5-5-5 6-9-12	8-8-8 8-12-16	10-10-11 10-15-20	13-14-15 13-19-24	14-15-17 14-20-26	17-18-20 17-23-30	19-20-21 19-26-33
3 in.	Flow Rate (cfm/ft)		33	49	66	82	98	115	131	148
	Sound (NC)		-	-	-	20	26	31	36	40
	Throw (ft)	Sill or Floor Sidewall	2-2-2 4-6-9	6-6-6 7-10-13	9-9-9 9-13-17	12-12-13 12-16-21	15-15-16 15-20-25	17-18-19 17-22-28	20-21-22 20-26-32	21-22-23 21-28-35
3½ in.	Flow Rate (cfm/ft)		40	59	79	99	119	138	158	178
	Sound (NC)		-	-	-	20	27	32	36	40
	Throw (ft)	Sill or Floor Sidewall	2-2-2 5-7-9	8-8-8 8-11-14	11-11-11 11-15-19	13-13-14 13-17-22	16-17-18 16-21-26	19-20-21 19-24-30	22-22-23 22-28-34	23-24-25 23-30-37
4 in.	Flow Rate (cfm/ft)		47	70	94	117	140	164	187	220
	Sound (NC)		-	-	-	21	27	33	37	41
	Throw (ft)	Sill or Floor Sidewall	3-3-3 5-7-10	9-9-9 9-12-15	12-12-12 12-16-20	15-15-15 15-19-24	18-19-20 19-23-28	21-21-22 21-26-32	23-24-25 23-29-35	25-25-26 25-32-39
5 in.	Flow Rate (cfm/ft)		61	91	121	152	182	212	243	274
	Sound (NC)		-	-	-	22	28	33	38	42
	Throw (ft)	Sill or Floor Sidewall	3-3-3 7-9-12	9-9-9 10-13-17	13-13-13 14-18-22	16-16-17 16-21-26	20-20-21 20-25-30	23-23-24 23-28-34	25-25-26 25-31-37	28-28-28 28-34-41
6 in.	Flow Rate (cfm/ft)		74	111	149	186	223	260	298	335
	Sound (NC)		-	-	-	22	29	34	39	42
	Throw (ft)	Sill or Floor Sidewall	4-4-4 8-10-13	10-10-10 11-14-18	14-14-14 15-19-23	18-18-18 19-23-27	22-22-22 23-27-31	25-25-25 25-30-35	28-28-28 28-33-39	30-30-30 31-37-43

For Performance Notes and Correction Factors, see end of section.

LBP/LBPH/LBM/LBMH

Linear Bar Grille

PERFORMANCE DATA

Linear Bar Grille (LBP/LBPH) – Core 15B

Size	Static Pressure (in. w.g.)		0.009	0.020	0.036	0.057	0.080	0.109	0.143	0.182
1½ in.	Flow Rate (cfm/ft)		14	21	28	35	42	49	56	63
	Sound (NC)		-	-	16	22	27	31	35	38
	Throw (ft)	Sill or Floor Sidewall	1-1-1 2-4-6	2-2-2 4-7-10	4-4-4 6-7-13	7-7-7 7-12-17	8-9-10 8-13-19	10-11-12 10-16-22	11-12-14 11-17-24	12-14-17 12-19-26
2 in.	Flow Rate (cfm/ft)		22	33	44	55	66	77	88	99
	Sound (NC)		-	-	-	18	23	27	31	34
	Throw (ft)	Sill or Floor Sidewall	1-1-1 3-5-7	4-4-4 5-8-12	7-7-7 7-11-16	9-9-10 9-14-20	11-11-12 11-17-23	13-14-16 13-19-26	14-16-18 14-21-28	15-17-20 15-22-30
2½ in.	Flow Rate (cfm/ft)		30	44	59	74	89	104	118	133
	Sound (NC)		-	-	-	17	22	26	30	33
	Throw (ft)	Sill or Floor Sidewall	1-1-1 4-6-8	5-5-5 6-9-13	9-9-9 9-13-17	11-11-12 11-16-21	13-14-15 13-18-24	15-16-17 15-21-28	18-19-20 17-24-31	20-21-23 20-27-35
3 in.	Flow Rate (cfm/ft)		38	58	77	96	115	134	154	173
	Sound (NC)		-	-	-	17	22	26	30	33
	Throw (ft)	Sill or Floor Sidewall	2-2-2 5-7-10	7-7-7 7-10-14	10-10-11 10-14-19	12-13-14 12-17-23	15-16-17 15-20-26	18-19-20 18-24-30	20-21-23 20-27-34	23-24-25 23-30-38
3½ in.	Flow Rate (cfm/ft)		46	69	93	116	139	162	186	209
	Sound (NC)		-	-	-	17	22	26	30	33
	Throw (ft)	Sill or Floor Sidewall	3-3-3 5-7-10	8-8-8 9-12-16	12-12-12 12-16-20	15-15-16 15-20-25	18-19-20 18-23-28	20-21-23 20-26-32	23-24-25 23-29-36	25-26-27 25-32-40
4 in.	Flow Rate (cfm/ft)		56	83	111	139	167	195	222	250
	Sound (NC)		-	-	-	18	23	27	31	34
	Throw (ft)	Sill or Floor Sidewall	3-3-3 6-8-11	9-9-9 10-13-17	13-13-13 13-17-21	16-16-17 16-20-25	20-20-21 20-25-30	22-23-24 22-28-34	24-25-26 24-30-37	27-27-27 28-35-42
5 in.	Flow Rate (cfm/ft)		72	107	143	179	215	250	286	322
	Sound (NC)		-	-	-	18	23	27	31	34
	Throw (ft)	Sill or Floor Sidewall	4-4-4 8-10-13	10-10-10 11-14-18	14-14-14 15-19-23	18-18-18 18-22-27	22-22-23 22-27-32	24-24-24 24-30-36	27-27-28 27-33-40	30-30-31 30-37-44
6 in.	Flow Rate (cfm/ft)		88	133	177	221	265	310	354	398
	Sound (NC)		-	-	-	19	24	28	32	35
	Throw (ft)	Sill or Floor Sidewall	5-5-5 9-12-15	10-10-10 13-16-20	15-15-15 16-20-24	18-18-18 20-24-29	23-23-23 24-29-34	25-25-25 28-33-39	28-28-28 30-35-41	31-31-31 34-40-46

For Performance Notes and Correction Factors, see end of section.

Linear Bar Grille (LBP/LBPH) – Core 16B

Size	Static Pressure (in. w.g.)		0.009	0.02	0.036	0.057	0.08	0.109	0.143	0.182
1½ in.	Flow Rate (cfm/ft)		16	23	31	39	47	55	62	70
	Sound (NC)		-	17	26	32	37	42	46	49
	Throw (ft)	Sill or Floor Sidewall	1-1-1 2-4-6	3-3-3 4-7-10	5-5-5 6-10-14	8-8-8 8-13-18	9-9-10 9-14-20	10-11-13 10-16-23	12-13-15 12-18-25	13-15-17 13-20-27
2 in.	Flow Rate (cfm/ft)		22	34	45	56	67	78	90	101
	Sound (NC)		-	-	19	25	30	35	39	43
	Throw (ft)	Sill or Floor Sidewall	1-1-1 3-5-7	4-4-4 5-8-12	7-7-7 7-11-16	9-9-10 9-14-20	11-12-13 11-17-23	12-14-16 12-18-25	14-16-18 14-20-27	15-17-20 15-22-30
2½ in.	Flow Rate (cfm/ft)		30	45	60	75	90	105	120	135
	Sound (NC)		-	-	18	24	29	34	38	42
	Throw (ft)	Sill or Floor Sidewall	1-1-1 4-6-8	5-5-5 6-9-13	8-8-9 8-12-17	11-11-12 11-16-21	13-14-15 13-19-25	15-16-18 15-21-27	17-19-21 17-24-31	20-21-22 20-27-35
3 in.	Flow Rate (cfm/ft)		37	56	74	93	112	130	149	167
	Sound (NC)		-	-	17	23	28	33	37	41
	Throw (ft)	Sill or Floor Sidewall	2-2-2 4-6-9	6-6-6 7-10-14	10-10-10 10-13-18	12-12-13 12-17-22	15-16-17 15-20-26	18-19-20 18-24-30	20-21-23 20-26-33	23-23-24 23-30-37
3½ in.	Flow Rate (cfm/ft)		45	68	90	113	136	158	181	203
	Sound (NC)		-	-	17	23	28	33	37	41
	Throw (ft)	Sill or Floor Sidewall	2-2-2 5-7-10	7-7-7 8-11-15	12-12-12 12-16-20	14-14-15 14-18-23	17-18-19 17-22-27	20-21-22 20-25-31	22-23-24 22-28-35	25-25-26 25-32-39
4 in.	Flow Rate (cfm/ft)		53	80	106	133	160	186	212	239
	Sound (NC)		-	-	18	24	29	34	38	42
	Throw (ft)	Sill or Floor Sidewall	3-3-3 6-8-11	8-8-9 9-12-16	13-13-13 13-17-21	15-15-16 15-19-24	19-19-20 19-24-29	22-22-23 22-27-33	24-24-25 24-30-36	26-26-27 25-33-40
5 in.	Flow Rate (cfm/ft)		69	104	138	173	208	242	277	312
	Sound (NC)		-	-	18	24	29	34	38	42
	Throw (ft)	Sill or Floor Sidewall	4-4-4 8-10-13	9-9-9 11-14-18	14-14-14 15-19-23	17-17-17 17-21-26	20-21-22 20-25-31	24-24-24 24-29-35	26-26-27 26-33-38	29-29-29 29-35-42
6 in.	Flow Rate (cfm/ft)		85	127	170	212	254	296	339	382
	Sound (NC)		-	-	18	24	29	34	38	42
	Throw (ft)	Sill or Floor Sidewall	5-5-5 9-11-14	10-10-10 13-16-20	15-15-15 16-20-24	18-18-18 20-24-28	23-23-23 23-27-32	25-25-25 25-30-36	28-28-28 28-33-39	30-30-30 31-37-43

For Performance Notes and Correction Factors, see end of section.

PERFORMANCE DATA

Linear Bar Grille (LBP/LBPH) – Core 25B/25C

Size	Static Pressure (in. w.g.)		0.01	0.022	0.04	0.063	0.089	0.121	0.159	0.202
1½ in.	Flow Rate (cfm/ft)		10	16	21	26	31	36	42	47
	Sound (NC)		-	-	-	19	24	29	33	36
	Throw (ft)	Sill or Floor* Sidewall	1-1-1 2-4-6	2-2-2 4-7-10	4-4-4 5-9-13	7-7-7 7-12-17	8-9-10 8-13-19	10-11-12 10-16-22	11-12-14 11-17-24	12-14-16 12-19-26
2 in.	Flow Rate (cfm/ft)		18	27	36	45	54	63	72	81
	Sound (NC)		-	-	-	18	23	28	32	35
	Throw (ft)	Sill or Floor* Sidewall	1-1-1 3-5-7	4-4-4 5-9-12	7-7-7 7-11-16	9-9-10 9-14-20	10-11-13 10-16-23	13-14-16 13-19-26	14-16-18 14-21-28	15-17-20 15-22-30
2½ in.	Flow Rate (cfm/ft)		26	40	53	66	79	92	106	119
	Sound (NC)		-	-	-	20	25	30	34	37
	Throw (ft)	Sill or Floor* Sidewall	2-2-2 4-6-9	6-6-6 6-9-12	8-8-9 8-12-17	11-12-13 11-16-22	13-14-16 13-19-25	15-17-19 15-21-28	18-20-22 18-25-32	21-22-23 21-28-36
3 in.	Flow Rate (cfm/ft)		35	53	70	88	106	123	141	158
	Sound (NC)		-	-	-	21	26	31	35	38
	Throw (ft)	Sill or Floor* Sidewall	2-2-2 5-7-10	7-7-7 7-11-15	10-10-11 10-14-19	12-13-15 12-17-23	15-16-18 15-21-27	18-19-21 18-24-31	20-22-24 20-27-34	24-24-25 24-31-39
3½ in.	Flow Rate (cfm/ft)		44	66	88	110	132	154	176	198
	Sound (NC)		-	-	-	16	22	27	32	39
	Throw (ft)	Sill or Floor* Sidewall	3-3-3 5-7-10	8-8-8 9-12-16	12-12-12 12-16-20	15-15-16 15-20-25	18-19-20 18-23-28	20-21-22 20-26-32	23-24-25 23-29-36	25-26-27 25-32-40
4 in.	Flow Rate (cfm/ft)		53	80	106	133	160	186	213	239
	Sound (NC)		-	-	-	17	23	28	33	40
	Throw (ft)	Sill or Floor* Sidewall	3-3-3 6-8-11	9-9-9 10-13-17	13-13-13 13-17-21	16-16-17 16-21-26	20-20-21 20-25-30	22-23-24 22-28-34	24-25-26 24-30-37	28-28-28 28-35-42
5 in.	Flow Rate (cfm/ft)		71	106	142	177	212	248	283	318
	Sound (NC)		-	-	-	18	24	29	34	41
	Throw (ft)	Sill or Floor* Sidewall	4-4-4 8-10-13	10-10-10 11-14-18	15-15-15 15-19-23	18-18-18 18-22-27	22-22-23 22-27-32	25-25-25 25-31-37	27-27-28 27-33-40	30-30-30 30-37-44
6 in.	Flow Rate (cfm/ft)		89	133	178	222	266	310	355	400
	Sound (NC)		-	-	-	19	25	30	35	42
	Throw (ft)	Sill or Floor* Sidewall	5-5-5 9-11-14	10-10-10 13-16-20	15-15-15 16-20-24	19-19-19 20-24-29	23-23-23 24-29-34	25-25-25 28-33-39	29-29-29 30-35-41	31-31-31 34-40-46

For Performance Notes and Correction Factors, see end of section.

* 1/2" core spacing (26B) not for use in floor applications.

Linear Bar Grille (LBP/LBPH) – Core 26B/26C

Size	Static Pressure (in. w.g.)		0.012	0.026	0.048	0.076	0.107	0.145	0.191	0.242
1½ in.	Flow Rate (cfm/ft)		12	19	25	31	37	43	50	56
	Sound (NC)		-	16	24	31	36	41	45	48
	Throw (ft)	Sill or Floor* Sidewall	1-1-1 2-4-6	3-3-3 4-7-10	5-5-5 6-10-14	7-7-7 7-12-17	9-9-10 9-14-20	10-11-12 10-16-23	12-13-15 12-18-25	13-15-17 13-20-27
2 in.	Flow Rate (cfm/ft)		19	29	38	48	58	67	77	86
	Sound (NC)		-	-	19	26	31	36	40	43
	Throw (ft)	Sill or Floor* Sidewall	1-1-1 3-5-7	4-4-4 5-8-12	7-7-7 7-11-16	9-9-10 9-14-20	11-12-13 11-17-24	14-14-15 13-19-26	15-16-18 15-22-29	16-18-20 16-23-31
2½ in.	Flow Rate (cfm/ft)		27	40	54	67	80	94	107	120
	Sound (NC)		-	-	19	26	31	36	40	43
	Throw (ft)	Sill or Floor* Sidewall	1-1-1 4-6-8	5-5-5 6-9-13	9-9-9 9-13-17	11-11-12 11-16-21	13-14-15 14-19-25	15-16-18 15-21-27	17-19-21 17-24-31	20-21-22 20-27-35
3 in.	Flow Rate (cfm/ft)		34	52	69	86	103	120	138	155
	Sound (NC)		-	-	19	26	31	36	40	43
	Throw (ft)	Sill or Floor* Sidewall	2-2-2 4-6-9	6-6-6 8-11-15	10-10-11 10-14-19	12-13-14 13-18-23	15-16-18 16-21-27	18-19-20 18-24-31	20-21-23 21-28-35	23-24-25 23-30-38
3½ in.	Flow Rate (cfm/ft)		42	63	84	105	126	147	168	189
	Sound (NC)		-	-	20	27	32	37	41	44
	Throw (ft)	Sill or Floor* Sidewall	2-2-2 6-8-11	8-8-8 9-12-16	11-11-12 12-16-21	15-15-15 14-19-24	17-18-19 18-23-29	21-21-22 21-27-33	22-23-25 23-29-36	25-25-26 25-32-40
4 in.	Flow Rate (cfm/ft)		51	76	102	127	152	178	203	228
	Sound (NC)		-	-	21	28	33	38	42	45
	Throw (ft)	Sill or Floor* Sidewall	3-3-3 6-9-12	9-9-9 10-13-17	13-13-13 13-17-22	16-16-17 15-20-25	19-20-21 19-24-30	22-22-23 22-28-34	24-25-26 25-31-38	27-27-27 28-36-42
5 in.	Flow Rate (cfm/ft)		67	100	134	167	200	234	267	301
	Sound (NC)		-	-	21	28	33	38	42	45
	Throw (ft)	Sill or Floor* Sidewall	4-4-4 8-11-14	10-10-10 11-15-19	14-14-14 15-19-24	18-18-18 19-23-28	21-21-22 21-26-32	24-24-25 24-30-36	26-27-28 26-32-39	30-30-30 29-36-43
6 in.	Flow Rate (cfm/ft)		84	126	168	210	252	294	336	378
	Sound (NC)		-	-	23	30	35	40	44	47
	Throw (ft)	Sill or Floor* Sidewall	5-5-5 9-12-15	10-10-10 14-17-21	15-15-15 17-21-25	19-19-19 20-24-29	23-23-23 24-29-34	25-25-25 27-32-38	28-28-29 29-35-41	31-31-31 32-38-44

For Performance Notes and Correction Factors, see end of section.

* 1/2" core spacing (26B) not for use in floor applications.

PERFORMANCE DATA

Linear Bar Grille (LBP/LBPH) – Core 27B/27C

Size	Static Pressure (in. w.g.)	0.012	0.026	0.048	0.076	0.107	0.145	0.191	0.242
1½ in.	Flow Rate (cfm/ft)	13	19	26	32	38	45	51	58
	Sound (NC)	-	16	24	31	36	41	45	48
	Throw (ft)	Sill or Floor* Sidewall	1-1-1 2-4-6	2-2-2 4-7-10	4-4-4 6-9-13	6-6-6 7-11-16	8-8-9 8-13-19	9-10-11 9-15-21	10-11-13 10-16-23
2 in.	Flow Rate (cfm/ft)	19	29	38	48	58	67	77	86
	Sound (NC)	-	-	20	26	31	36	40	43
	Throw (ft)	Sill or Floor* Sidewall	1-1-1 3-5-7	4-4-4 5-8-11	6-6-6 7-11-15	9-9-9 9-14-19	11-11-12 11-16-22	12-13-15 12-18-25	14-15-17 14-20-27
2½ in.	Flow Rate (cfm/ft)	26	39	52	65	77	91	104	117
	Sound (NC)	-	-	20	26	31	36	40	43
	Throw (ft)	Sill or Floor* Sidewall	1-1-1 4-6-8	5-5-5 6-9-12	8-8-8 8-12-16	10-10-11 10-15-20	13-14-15 13-19-24	15-16-17 14-20-26	16-18-20 17-23-30
3 in.	Flow Rate (cfm/ft)	33	50	66	83	100	116	133	149
	Sound (NC)	-	-	20	26	31	36	40	43
	Throw (ft)	Sill or Floor* Sidewall	2-2-2 4-6-9	6-6-6 7-10-13	9-9-10 9-13-17	12-12-13 12-16-21	15-16-17 15-20-25	18-19-20 17-22-28	20-21-22 20-26-32
3½ in.	Flow Rate (cfm/ft)	40	60	80	100	120	140	160	180
	Sound (NC)	-	-	20	27	32	36	40	43
	Throw (ft)	Sill or Floor* Sidewall	2-2-2 5-7-9	7-7-7 8-11-14	10-10-11 11-15-19	15-15-15 13-17-22	17-18-19 16-21-26	20-21-22 19-24-30	22-23-24 22-28-34
4 in.	Flow Rate (cfm/ft)	49	73	97	122	146	171	195	219
	Sound (NC)	-	-	21	27	33	37	41	44
	Throw (ft)	Sill or Floor* Sidewall	3-3-3 6-8-11	8-8-8 9-12-16	12-12-13 12-16-20	15-15-16 15-20-25	19-19-20 19-24-29	21-22-23 21-26-32	24-24-25 24-30-36
5 in.	Flow Rate (cfm/ft)	63	95	126	158	190	221	253	284
	Sound (NC)	-	-	22	28	33	38	42	45
	Throw (ft)	Sill or Floor* Sidewall	4-4-4 7-9-12	9-9-9 11-14-19	14-14-14 14-18-22	17-17-17 17-21-26	21-21-22 21-26-31	24-24-24 24-29-35	27-27-27 27-33-39
6 in.	Flow Rate (cfm/ft)	76	114	152	190	228	266	304	342
	Sound (NC)	-	-	22	29	34	39	42	46
	Throw (ft)	Sill or Floor* Sidewall	5-5-5 8-10-13	10-10-10 12-15-18	15-15-15 15-19-23	18-18-18 20-24-28	23-23-23 23-27-32	25-25-25 26-31-37	28-28-28 29-34-40

* 1/2" core spacing (26B) not for use in floor applications.

Performance Notes:

1. Tested in accordance with ASHRAE Standard 70 – 2006 "Method of Testing for Rating the Performance of Air Outlets and Inlets."
2. Airflow is in cubic feet per minute [cfm].
3. NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a 10 ft. active section. The NC correction values for other lengths are listed in the table below
4. When used as a return air intake, the NC value given in the performance table will be increased by 4. For return air application, the negative static pressure will be 0.8 times the static pressure value as shown in the performance table.
5. Blanks "-" indicate an NC level below 15.
6. All pressures are in inches of water column [in. w.g.].
7. Pressures not listed can be calculated using the following formula:
P_{total} = P_{static} + P_{velocity}
8. Throw values are measured in feet for terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)

9. These throw values are based on a 4 ft. active section of grille with a cooling temperature differential of 20°F. The multiplier factors listed in the table below are applicable for other lengths.

Throw Correction for Length (Multiply)

Active Length	Terminal Velocity		
	150 fpm	100 fpm	50 fpm
1 ft.	0.5	0.6	0.7
10 ft. or Continuous	1.6	1.4	1.2

10. 1/2" core spacing (15B, 16B, 25B, 26B, 27B) not for use in floor applications.

Active Length, ft	1	2	4	6	8	10	15	20	25	30
NC Correction	-10	-7	-4	-2	-1	0	+2	+3	+4	+5