

PERFORMANCE DATA

Cooling: Electric Heat Option

Unit Size L x H [in]	Face Velocity [fpm]	Air Flow [cfm]	Total Pressure [in. w.g.]	Static Pressure [in. w.g.]	Noise Criteria [NC]	Proximity to Outlet [ft]			
						DR 20%		Adjacent Zone	
						$\Delta T = 5\text{ }^\circ\text{F}$	$\Delta T = 10\text{ }^\circ\text{F}$	$\Delta T = 5\text{ }^\circ\text{F}$	$\Delta T = 10\text{ }^\circ\text{F}$
30 x 20	20	25	-	-	-	-	1	--	1
	30	38	-	-	-	-	3	--	2
	40	50	-	-	-	1	4	1	4
	50	63	0.01	0.01	-	2	5	2	5
30 x 24	20	42	-	-	-	-	4	1	3
	30	63	-	-	-	2	5	2	5
	40	83	-	-	-	3	7	3	7
	50	104	0.01	0.01	-	4	8	5	8
30 x 28	20	58	-	-	-	2	5	1	5
	30	88	-	-	-	3	7	4	7
	40	117	-	-	-	5	9	5	9
	50	146	0.01	0.01	-	6	10	7	10
36 x 20	20	30	-	-	-	-	1	--	1
	30	45	-	-	-	-	3	--	2
	40	60	-	-	-	1	4	1	4
	50	75	0.01	0.01	-	2	5	2	5
36 x 24	20	50	-	-	-	-	4	--	3
	30	75	-	-	-	2	5	2	5
	40	100	-	-	-	3	7	3	7
	50	125	0.01	0.01	-	4	8	5	8
36 x 28	20	70	-	-	-	2	5	1	5
	30	105	-	-	-	3	7	4	7
	40	140	0.01	0.01	-	5	9	5	9
	50	175	0.02	0.02	-	6	10	7	10
48 x 20	20	40	-	-	-	-	1	--	1
	30	60	-	-	-	-	3	--	2
	40	80	-	-	-	1	4	1	4
	50	100	0.01	0.01	-	2	5	2	5
48 x 24	20	67	-	-	-	-	3	--	3
	30	100	-	-	-	2	5	2	5
	40	133	-	-	-	3	7	3	7
	50	167	0.02	0.02	-	4	8	5	8
48 x 28	20	93	-	-	-	1	5	1	5
	30	140	-	-	-	3	7	4	7
	40	187	0.01	0.01	-	4	8	5	9
	50	233	0.02	0.02	-	6	10	7	10
60 x 20	20	50	-	-	-	-	1	--	--
	30	75	-	-	-	-	3	--	2
	40	100	-	-	-	1	4	1	4
	50	125	0.01	0.01	-	2	5	2	5
60 x 24	20	83	-	-	-	-	3	--	3
	30	125	-	-	-	2	5	2	5
	40	167	0.01	0.01	-	3	7	3	7
	50	208	0.02	0.02	-	4	8	5	8
60 x 28	20	117	-	-	-	1	5	1	5
	30	175	-	-	-	3	7	4	7
	40	233	0.01	0.01	-	4	8	5	9
	50	292	0.02	0.02	-	6	10	7	10

Performance Notes:

- Sound and pressure drop tested in accordance with ASHRAE Standard 70-2006 "Method of Testing for Rating the Performance of Air Outlets and Inlets."
- Air flow is in cubic feet per minute, cfm.
- Pressure is in inches of water, in. w.g.
- The NC values, sound pressure level, are based on a room absorption of 10 dB, re 10⁻¹² watts and one diffuser.
- ΔT is the difference between the room air temperature 3½ ft above the floor and the temperature of the supply air.
- Proximity to outlet is the minimum distance from an outlet to the occupant in order to achieve the listed DR value.
- Distances closer to the diffuser have a higher DR than the cataloged value.
- DR is the predicted percentage of people dissatisfied (PPD) due to draft. A value of less than 20 meets the requirements of ASHRAE Standard 55-2004, Thermal Environmental Conditions for Human Occupancy.
- Blanks "-" indicate that the DR is below the specified value at all distances from the diffuser face.
- DR catalog data is presented for an occupant density of 25 people/1000ft², which is the default occupancy density for classrooms (ages 5-8) given by ASHRAE 62.1-2004. For other occupant densities, please refer to the DV Room Designer Software.
- The Adjacent zone describes the distance from the face of the diffuser and measured 1 in. from the floor, at which the supply air velocity is 50 fpm.

Electric Heating Performance

Nom. Length (in.)	Heater Output		
	120V	208V	240V
30	500W	375W	500W
36	500W	375W	500W
48	1000W	750W	1000W
60	1000W	750W	1000W

Note: The cooling performance for the hydronic and electric units will be different due to a difference in the heights of the heating sections.

PERFORMANCE DATA

Cooling: Hydronic Heating Option

Unit Size L x H [in]	Face Velocity [fpm]	Air Flow [cfm]	Total Pressure [in. w.g.]	Static Pressure [in. w.g.]	Noise Criteria [NC]	Proximity to Outlet [ft]			
						DR 20%		Adjacent Zone	
						$\Delta T = 5\text{ }^\circ\text{F}$	$\Delta T = 10\text{ }^\circ\text{F}$	$\Delta T = 5\text{ }^\circ\text{F}$	$\Delta T = 10\text{ }^\circ\text{F}$
24 x 16	20	20	-	-	-	-	1	--	1
	30	30	-	-	-	-	3	--	2
	40	40	-	-	-	1	4	1	4
	50	50	0.01	0.01	-	2	5	2	5
24 x 20	20	33	-	-	-	-	4	--	3
	30	50	-	-	-	2	5	2	5
	40	67	-	-	-	3	7	3	7
	50	83	0.01	0.01	-	4	8	5	8
24 x 24	20	47	-	-	-	2	5	1	5
	30	70	-	-	-	3	7	4	7
	40	93	-	-	-	5	9	5	9
	50	117	0.01	0.01	-	6	10	7	10
36 x 16	20	30	-	-	-	-	1	--	1
	30	45	-	-	-	-	3	--	2
	40	60	-	-	-	1	4	1	4
	50	75	0.01	0.01	-	2	5	2	5
36 x 20	20	50	-	-	-	-	3	--	3
	30	75	-	-	-	2	5	2	5
	40	100	-	-	-	3	7	3	7
	50	125	0.01	0.01	-	4	8	5	8
36 x 24	20	70	-	-	-	1	5	1	5
	30	105	-	-	-	3	7	4	7
	40	140	0.01	0.01	-	4	8	5	9
	50	175	0.02	0.02	-	6	10	7	10
48 x 16	20	40	-	-	-	-	1	--	--
	30	60	-	-	-	-	3	--	2
	40	80	-	-	-	1	4	1	4
	50	100	0.01	0.01	-	2	5	2	5
48 x 20	20	67	-	-	-	-	3	--	3
	30	100	-	-	-	2	5	2	5
	40	133	-	-	-	3	7	3	7
	50	167	0.02	0.02	-	4	8	5	8
48 x 24	20	93	-	-	-	1	5	1	5
	30	140	-	-	-	3	7	4	7
	40	187	0.01	0.01	-	4	8	5	9
	50	233	0.02	0.02	-	6	10	7	10
60 x 16	20	50	-	-	-	-	1	--	--
	30	75	-	-	-	-	3	--	2
	40	100	-	-	-	1	4	1	4
	50	125	0.01	0.01	-	1	5	2	5
60 x 20	20	83	-	-	-	-	3	--	3
	30	125	-	-	-	2	5	2	5
	40	167	0.01	0.01	-	3	7	3	7
	50	208	0.02	0.02	-	4	8	5	8
60 x 24	20	117	-	-	-	1	5	1	5
	30	175	-	-	-	3	7	4	7
	40	233	0.01	0.01	-	4	8	5	9
	50	292	0.02	0.02	-	6	10	7	10

Performance Notes:

- Sound and pressure drop tested in accordance with ASHRAE Standard 70-2006 "Method of Testing for Rating the Performance of Air Outlets and Inlets."
- Air flow is in cubic feet per minute, cfm.
- Pressure is in inches of water, in. w.g.
- The NC values, sound pressure level, are based on a room absorption of 10 dB, re 10⁻¹² watts and one diffuser.
- ΔT is the difference between the room air temperature 3 ½ ft above the floor and the temperature of the supply air.
- Proximity to outlet is the minimum distance from an outlet to the occupant in order to achieve the listed DR value.
- Distances closer to the diffuser have a higher DR than the cataloged value.
- DR is the predicted percentage of people dissatisfied (PPD) due to draft. A value of less than 20 meets the requirements of ASHRAE Standard 55-2004, Thermal Environmental Conditions for Human Occupancy.
- Blanks "-" indicate that the DR is below the specified value at all distances from the diffuser face.
- DR catalog data is presented for an occupant density of 25 people/1000ft², which is the default occupancy density for classrooms (ages 5-8) given by ASHRAE 62.1-2004. For other occupant densities, please refer to the DV Room Designer Software.
- The Adjacent zone describes the distance from the face of the diffuser and measured 1 in. from the floor, at which the supply air velocity is 50 fpm.