


		IMPERIAL UNITS (inches)										
UNIT		STAN	DARD COIL	S		HIGH CA	APACITY CO	DILS				
SIZE	SIZE	С	CONNECT	ION SIZES	В	С	CONNECT	ION SIZES				
	ь		1 ROW	2 ROW	В		1 ROW	2 ROW				
10	12	10	1/2	7/8	14	12 1/2	1/2	7/8				
20	16	15	7/8	7/8	20	17 1/2	1/2	7/8				
30	16	15	7/8	7/8	20	17 1/2	1/2	7/8				
40	16	15	7/8	7/8	20	17 1/2	1/2	7/8				
50	20	17 1/2	7/8	7/8	28	17 1/2	7/8	7/8				

	SI UNITS (mm)									
UNIT		STAN	DARD COIL	S		HIGH CA	APACITY CO	DILS		
SIZE	SIZE	С	CONNECT	ION SIZES	ВС	•	CONNECT	ION SIZES		
	В	ر	1 ROW	2 ROW		١	1 ROW	2 ROW		
10	305	254	13	22	356	318	13	22		
20	406	381	22	22	508	445	13	22		
30	406	381	22	22	508	445	13	22		
40	406	381	22	22	508	445	13	22		
50	508	445	22	22	711	445	22	22		




## NOTES:

- 1. FABRICATED FROM 22 GA. GALVANIZED STEEL. MECHANICALLY SEALED, LEAK RESISTANT CONSTRUCTION.
- 2. HOT WATER COILS HAVE COPPER TUBES AND ALUMINUM FINS WITH O.D. SWEAT CONNECTIONS.
- BY INSTALLING CONTRACTOR.
- 4. HANDING OF HOT WATER COILS CAN BE ON THE SAME SIDE AS THE CONTROLS, OR OPPOSITE SIDE. LEFT HAND UNIT WITH SAME SIDE CONNECTION IS ILLUSTRATED ABOVE.
- 5. ALLOW  $1\frac{1}{2}$ " (38) MINIMUM CLEARANCE FOR INSTALLATION AT THIS END.
- 3. METHOD OF VENTING HOT WATER COIL IS TO BE PROVIDED 6. PERFORMANCE RATED AND CERTIFIED IN ACCORDANCE WITH THE CURRENT EDITION OF AHRI STANDARD 410.
  - 7. STANDARD COILS SUPPLIED WITH 10 FINS PER INCH.

☐ HC - HIGH CAPACITY COILS SUPPLIED WITH 12 FINS PER INCH.


ALL METRIC DIMENSIONS ( ) ARE	SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO	METRIC AND ROUNDED TO THE	IE NEAREST MILLIMETER.	
PROJECT:				
ENGINEER:		<u> </u>	HOT WATER C	
CUSTOMER:		2679	7930 FDC & FDC DO/ SIZES 10-50	
SUBMITTAL DATE:	SPEC. SYMBOL:	09/26/	5/2019	





		IMPERIAL UNITS (inches)									
UNIT		STAND	ARD COIL	S	HIGH CAPACITY COILS						
SIZE	В		CONNECTION SIZES		В		CONNECTION SIZES				
	ь	·	1 ROW	2 ROW	В	·	1 ROW	2 ROW			
60	38	18	7/8	7/8	38	18	7/8	7/8			

		SI UNITS (mm)									
UNIT		STANE	ANDARD COILS HIGH CAP				PACITY COILS				
SIZE	В	_	C CONNECTION SIZES B C		_	CONNECTION SIZE					
	ь	·	1 ROW	2 ROW	В	·	1 ROW	2 ROW			
60	965	457	22	22	965	457	22	22			



### NOTES:


- 1. FABRICATED FROM 22 GA. GALVANIZED STEEL. MECHANICALLY SEALED, LEAK RESISTANT CONSTRUCTION.
- 2. HOT WATER COILS HAVE COPPER TUBES AND ALUMINUM FINS WITH O.D. SWEAT CONNECTIONS.
- 3. METHOD OF VENTING HOT WATER COIL IS TO BE PROVIDED BY INSTALLING CONTRACTOR.
- 4. FLANGED ADAPTOR REQUIRED TO ATTACH HOT WATER COILS TO FANS.
- 5. HANDING OF HOT WATER COILS CAN BE ON THE SAME SIDE AS THE CONTROLS, OR OPPOSITE SIDELEFT HAND UNIT WITH SAME SIDE CONNECTION IS ILLUSTRATED ABOVE.
- 6. ALLOW 1  $\frac{1}{2}$ " (38) MINIMUM CLEARANCE FOR INSTALLATION AT THIS END.
- 7. PERFORMANCE RATED AND CERTIFIED IN ACCORDANCE WITH THE CURRENT EDITION OF AHRI STANDARD 410.
- 8. STANDARD COILS SUPPLIED WITH 10 FINS PER INCH.

### **OPTIONS:**

☐ HC - HIGH CAPACITY COILS SUPPLIED WITH 12 FINS PER INCH.


ALL METRIC DIMENSIONS ( ) ARE SOFT CO	NVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO MI	TRIC AND ROUNDED	TO THE NEAREST	MILLIMETER.
PROJECT:				JLICE,
ENGINEER:			F	HOT WATER COILS FAN POWERED TERMINALS
CUSTOMER:			267930	FDC SIZE 60
SUBMITTAL DATE:	SPEC. SYMBOL:	0	9/26/2019	





		IMPERIAL UNITS (inches)										
UNIT		STAN	DARD COIL	S		HIGH CA	APACITY CO	DILS				
SIZE	В	CONNECTION SIZES B		CONNECT	ION SIZES							
	D	С	1 ROW	2 ROW	В	С	1 ROW	2 ROW				
10	12	10	1/2	7/8	14	12 1/2	1/2	7/8				
20	16	15	7/8	7/8	20	17 1/2	1/2	7/8				
30	16	15	7/8	7/8	20	17 1/2	1/2	7/8				
40	16	15	7/8	7/8	20	17 1/2	1/2	7/8				
50	20	17 1/2	7/8	7/8	28	17 1/2	7/8	7/8				

	SI UNITS (mm)											
UNIT		STAN	DARD COIL	S		HIGH CA	APACITY CO	DILS				
SIZE	CONNECTION SIZES		В	•	CONNECT	ION SIZES						
	В	С	1 ROW	2 ROW	В	С	1 ROW	2 ROW				
10	305	254	13	22	356	318	13	22				
20	406	381	22	22	508	445	13	22				
30	406	381	22	22	508	445	13	22				
40	406	381	22	22	508	445	13	22				
50	508	445	22	22	711	445	22	22				



### NOTES:

- 1. FABRICATED FROM 22 GA. GALVANIZED STEEL.
  MECHANICALLY SEALED, LEAK RESISTANT CONSTRUCTION.
- 2. HOT WATER COILS HAVE COPPER TUBES AND ALUMINUM FINS WITH O.D. SWEAT CONNECTIONS.
- 3. METHOD OF VENTING HOT WATER COIL IS TO BE PROVIDED BY INSTALLING CONTRACTOR.
- 4. HANDING OF HOT WATER COILS CAN BE ON THE SAME SIDE AS THE CONTROLS, OR OPPOSITE SIDE. LEFT HAND UNIT WITH SAME SIDE CONNECTION IS ILLUSTRATED ABOVE.
- 5. ALLOW 1 12" (38) MINIMUM CLEARANCE FOR INSTALLATION AT THIS END.

- 6. PERFORMANCE RATED AND CERTIFIED IN ACCORDANCE WITH THE CURRENT EDITION OF AHRI STANDARD 410.
- 7. STANDARD COILS SUPPLIED WITH 10 FINS PER INCH.

#### **OPTIONS:**

- $\hfill \square$  HC HIGH CAPACITY COILS SUPPLIED WITH 12 FINS PER INCH
- ☐ CAD ACCESS DOOR W/SCREWS
- ☐ CADL ACCESS DOOR W/SNAP LATCHES
- ☐ CADQ COIL ACCESS DOOR W/QUARTER TURN SASH LATCHES

PROJECT:

ENGINEER:


CUSTOMER:

SPEC. SYMBOL:

ALL METRIC DIMENSIONS () ARE SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO METRIC AND ROUNDED TO THE NEAREST MILLIMETER.


HOT WATER COILS
FAN POWERED TERMINALS
FDC & FDC DOAS
W/ ACCESS DOOR
SIZES 10-50





		IMPERIAL UNITS (inches)											
UNIT		STAN	DARD COILS	ARD COILS HIGH CAPACITY COILS									
SIZE	В	_	CONNECTION SIZES		В	•	CONNECTION SIZES						
	В	C	1 ROW	2 ROW	ВС		1 ROW	2 ROW					
60	38	18	7/8	7/8	38	18	7/8	7/8					

		SI UNITS (mm)										
UNIT		STAN	DARD COILS		HIGH CAPACITY COILS							
SIZE	В	,	CONNECTION SIZES		В	,	CONNECTION SIZES					
	ь	C	1 ROW	2 ROW	ь	C	1 ROW	2 ROW				
60	965	457	22	22	965	457	22	22				



- 1. FABRICATED FROM 22 GA. GALVANIZED STEEL. MECHANICALLY SEALED, LEAK RESISTANT CONSTRUCTION.
- 2. HOT WATER COILS HAVE COPPER TUBES AND ALUMINUM FINS WITH O.D. SWEAT CONNECTIONS.
- 3. METHOD OF VENTING HOT WATER COIL IS TO BE PROVIDED BY INSTALLING CONTRACTOR.
- 4. FLANGED ADAPTOR REQUIRED TO ATTACH HOT WATER COILS TO FANS.
- 5. HANDING OF HOT WATER COILS CAN BE ON THE SAME SIDE AS THE CONTROLS, OR OPPOSITE SIDE. LEFT HAND UNIT WITH SAME SIDE CONNECTION IS ILLUSTRATED ABOVE.
- 6. ALLOW 1 12" (38) MINIMUM CLEARANCE FOR INSTALLATION AT THIS END.


- 7. PERFORMANCE RATED AND CERTIFIED IN ACCORDANCE WITH THE CURRENT EDITION OF AHRI STANDARD 410.
- 8. STANDARD COILS SUPPLIED WITH 10 FINS PER INCH.


#### **OPTIONS:**

- $\hfill \square$  HC HIGH CAPACITY COILS SUPPLIED WITH 12 FINS PER INCH
- ☐ CAD ACCESS DOOR W/SCREWS
- $\ \square$  CADL ACCESS DOOR W/SNAP LATCHES
- $\square$  CADQ COIL ACCESS DOOR W/QUARTER TURN SASH LATCHES

ALL METRIC DIMENSIONS () ARE SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO METRIC AND ROUNDED TO THE NEAREST MILLIMETER.

PROJECT:		Price.	
ENGINEER:		4	HOT WATER COILS FAN POWERED TERMINALS
CUSTOMER:		26793	W/ ACCESS DOCIT
SUBMITTAL DATE:	SPEC. SYMBOL:	09/26/2	019 SIZE 60





UNIT SIZES	OUTLET DUCT SIZE B X C		D	F	К
10	12x10	(305x254)	14 5/8 (371)	4 (102)	18 3/8 (467)
20	16x15	(406x381)	18 (457)	5 (127)	16 1/4 (413)
30	16x15	(406x381)	18 (457)	5 (127)	16 1/4 (413)
40	16x15	(406x381)	18 (457)	5 (127)	16 1/4 (413)
50	20x17 1/2	(508x445)	18 (457)	3 (76)	16 1/4 (413)

### STANDARD FEATURES

- INTEGRATED RIVET HINGED ACCESS DOOR
- AUTOMATIC RESET THERMAL CUTOUT
- MANUAL RESET THERMAL CUTOUT
- FAN INTERLOCKED WITH HEATING ELEMENTS
- MAGNETIC CONTACTORS
- 20 GA. GALVANIZED STEEL CONSTRUCTION
- HIGH GRADE NICKEL CHROME HEATING ELEMENTS
- SINGLE POINT ELECTRICAL CONNECTION, EXCEPT SEPARATE POWER SUPPY FOR  $600/3 \, \phi/3 \, \text{WIRE}$ SUPPLY VOLTAGE:

# □ 115/1Ø

- $\square$  208/1 $\phi$  (3 WIRE)
- $\square$  240/1 $\phi$
- $\square$  277/1 $\phi$
- $\Box$  480/1 $\phi$  (3 WIRE)
- $\square$  208/3 $\phi$  (4 WIRE)
- $\Box$  480/3 $\phi$  (4 WIRE)
- $\Box$  600/3 $\phi$  (3 OR 4 WIRE)


### **OPTIONAL FEATURES**


- ☐ AIR FLOW SWITCH
- ☐ CONTROL CIRCUIT FUSE
- ☐ DOOR INTERLOCK DISCONNECT SWITCH
- ☐ MAIN SUPPLY FUSE
- ☐ MOTOR FUSE
- ☐ SCR CONTROLS
- ☐ SCR-DAT CONTROLS
  - □ 0 to 10 Vdc CONTROL SIGNAL
  - ☐ 4 to 20 mA CONTROL SIGNAL
  - ☐ 24 VAC PULSE CONTROL
- ☐ DP DUAL POINT POWER CONNECTION
- ☐ INSULATED EC SECTION

#### **NOTES**

- 70 CFM PER KW MINIMUM AIR FLOW ACROSS HEATER COILS.
- MINIMUM 0.2" w.g.(50 Pa) EXTERNAL STATIC PRESSURE TO OPERATE.
- ASSEMBLY ETL CERTIFIED TO UL1995 & CSA236.

ALL METRIC DIMENSIONS () ARE PROJECT:	SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO	METRIC AND ROUNDED TO THE NEARES	T MILLIMETER.
ENGINEER:		4	ELECTRIC COILS CONSTANT VOLUME
CUSTOMER:		267932	FDC & FDC DOAS SIZES 10-50
SUBMITTAL DATE:	SPEC. SYMBOL:	09/26/2019	





UNIT SIZES	OUTLET DUCT SIZE B X C		D	F
60	38x18	(965x457)	18 (457)	7 (178)

### STANDARD FEATURES

- INTEGRATED RIVET HINGED ACCESS DOOR
- AUTOMATIC RESET THERMAL CUTOUT
- MANUAL RESET THERMAL CUTOUT
- FAN INTERLOCKED WITH HEATING ELEMENTS
- MAGNETIC CONTACTORS
- 20 GA. GALVANIZED STEEL CONSTRUCTION
- HIGH GRADE NICKEL CHROME HEATING ELEMENTS
- SINGLE POINT ELECTRICAL CONNECTION, EXCEPT SEPARATE POWER SUPPY FOR  $600/3\,\phi/3$  WIRE

# SUPPLY VOLTAGE: $\Box$ 115/1 $\phi$

- $\square$  208/1 $\phi$  (3 WIRE)
- $\square$  240/1 $\phi$
- $\Box 277/10$
- $\Box$  480/1 $\phi$  (3 WIRE)
- $\square$  208/3 $\phi$  (4 WIRE)
- $\Box$  480/3 $\phi$  (4 WIRE)
- $\Box$  600/3 $\phi$  (3 OR 4 WIRE)

### **OPTIONAL FEATURES**

- ☐ AIR FLOW SWITCH
- ☐ CONTROL CIRCUIT FUSE
- ☐ DOOR INTERLOCK DISCONNECT SWITCH
- ☐ MAIN SUPPLY FUSE
- ☐ MOTOR FUSE
- ☐ SCR CONTROLS
- $\square$  SCR-DAT CONTROLS
- □ 0 to 10 Vdc CONTROL SIGNAL
- ☐ 4 to 20 mA CONTROL SIGNAL
- ☐ 24 VAC PULSE CONTROL
- ☐ DP DUAL POINT POWER CONNECTION
- ☐ INSULATED EC SECTION

#### **NOTES**

- 70 CFM PER KW MINIMUM AIR FLOW ACROSS HEATER COILS.
- MINIMUM 0.2" w.g.(50 Pa) EXTERNAL STATIC PRESSURE TO OPERATE.
- ASSEMBLY ETL CERTIFIED TO UL1995 & CSA236.

ALL METRIC DIMENSIONS () ARE SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO METRIC AND ROUNDED TO THE NEAREST MILLIMETER.

PROJECT:

ENGINEER:

CUSTOMER:


CUSTOMER:

SPEC. SYMBOL:

O9/26/2019


ELECTRIC COILS
CONSTANT VOLUME
FDC
SIZE 60





IMPERIAL UNITS (inches)			
	В	С	
28	9	15 1/4	
38	15	18 1/2	
38	15	18 1/2	
38	17	18 1/2	
41	17	20 1/8	
	L 28 38 38 38	L B 28 9 38 15 38 15 38 17	


UNIT SIZE	S	I UNITS (mm	1)
UNIT SIZE	L	В	С
10	711	229	387
20	965	381	470
30	965	381	470
40	965	432	470
50	1041	432	511




- 22 GA. GALVANIZED STEEL HOUSING, MECHANICALLY SEALED LEAK RESISTANT CONSTRUCTION.
- INTERNAL INSULATION 1" (25mm) THICK, MIN. 1.5 LB/CU.FT DENSITY WHICH MEETS REQUIREMENTS OF NFPA90A AND UL181.
   ATTENUATOR LINER MATCHES THE UNIT LINER (EXCEPT FOR SM1 UNIT LINER COMES WITH PM1 ATTENUATOR LINER).

ALL METRIC DIMENSIONS () ARE SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO METRIC AND ROUNDED TO THE NEAREST MILLIMETER **PROJECT: ATTENUATOR ENGINEER: FAN POWERED TERMINALS INLET FDC CUSTOMER:** 267933 **SIZES 10-50 SPEC. SYMBOL: SUBMITTAL DATE:** 09/26/2019








- 22 GA. GALVANIZED STEEL HOUSING, MECHANICALLY SEALED LEAK RESISTANT CONSTRUCTION.
- INTERNAL INSULATION 1" (25mm) THICK, MIN. 1.5 LB/CU.FT DENSITY WHICH MEETS REQUIREMENTS OF NFPA90A AND UL181.
   ATTENUATOR LINER MATCHES THE UNIT LINER (EXCEPT FOR SM1 UNIT LINER COMES WITH PM1 ATTENUATOR LINER).

ALL METRIC DIMENSIONS () ARE SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO METRIC AND ROUNDED TO THE NEAREST MILLIMETEF **PROJECT: ATTENUATOR ENGINEER: FAN POWERED TERMINALS INLET FDC CUSTOMER:** 267933 SIZE 60 **SUBMITTAL DATE: SPEC. SYMBOL:** 09/26/2019



	IMPERIA	AL UNITS	S.I. U	INITS
UNIT SIZE	w	Н	w	Н
10	10	15 1/4	254	387
20	15 7/8	17 7/8	403	454
30	15 7/8	17 7/8	403	454
40	15 7/8	17 7/8	403	454
50	17 7/8	19 7/8	454	505
60*	15 3/4	19 7/8	400	505

# \*SIZE 60 REQUIRES 2 FILTERS


## NOTES:


- 1"(25) NOMINAL FILTER MEDIA.

- CARDBOARD FRAME.

  MERV 3 RATING (THROWAWAY).


  FILTERS ARE CLIPPED TO TERMINAL CASING.






ALL METRIC DIMENSIONS ( ) ARE S	SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO M	ETRIC AND ROUNDED TO 1	THE NEAREST	MILLIMETER.
PROJECT:				
ENGINEER:			£	FILTERS FAN POWERED TERMINAL
CUSTOMER:		26	67934	FDC SIZES 10-60
SUBMITTAL DATE:	SPEC. SYMBOL:	09/2	26/2019	MERV3








	IMPERIAL UNITS				:	S.I. UNIT	S			
UNIT	FIL	TER	ı	BOOT SIZ	E	FIL	TER	ı	BOOT SIZ	E
SIZE	W	Н	Α	В	L	W	Н	Α	В	L
10	10 1/4	18	10 3/4	15 1/4	13	260	457	273	387	330
20	15	20 3/4	15 1/2	18 1/2	13	381	527	394	470	330
30	15	20 3/4	15 1/2	18 1/2	13	381	527	394	470	330
40	17 1/2	23 1/2	18	18 1/2	17 1/2	445	597	457	470	445
50	21 3/8	23 7/8	21 7/8	20 1/8	16 1/4	543	606	556	511	413
60*	16 1/4	25 1/4	16 3/4	20 1/8	18 1/2	413	641	425	511	470


\*SIZE 60 REQUIRES 2 FILTERS

# NOTES:


- 2" (51) NOMINALFILTER MEDIA.
- CARDBOARD FRAME.
- MERV 8 RATING.
- FILTER MOUNTED AS STANDARD ON RH CONFIGURATION AS SHOWN BELOW. UNITS WITH LH CONFIGURATION ARE FLIPPED, CAUSING THE FILTER BOOT TO FACE DOWN.



PROJECT:			JLICG.
ENGINEER:		4	FILTERS FAN POWERED TERMINAL
CUSTOMER:		267934	FDC SIZES 10-60
SUBMITTAL DATE:	SPEC. SYMBOL:	09/26/2019	MERV8




	IMPERIA	AL UNITS	S.I. U	INITS
UNIT SIZE	w	H	W	H
10	16 1/2	12 1/2	419	318
20	19	15	483	381
30	19	15	483	381
40	19	15	483	381
50	20 1/2	17 1/2	521	445




- 1" (51) NOMINAL FILTER MEDIA, FOR MERV 3 RATING (THROWAWAY).
  2" (51) NOMINAL FILTER MEDIA, FOR MERV 8 OR 13 RATING.
- CARDBOARD FRAME.
- 2 FILTERS PER UNIT REQUIRED.

ALL METRIC DIMENSIONS ( ) ARE	SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO	METRIC AND ROUNDED TO THE NEARE	ST MILLIMETER.
PROJECT:			buce,
ENGINEER:		4	FILTERS FAN POWERED TERMINAL
CUSTOMER:		267934	FDC DOAS SIZES 10-50
SUBMITTAL DATE:	SPEC. SYMBOL:	09/26/2019	MERV 3, 8, OR 13




	IMPERIA	AL UNITS	S.I. U	INITS
UNIT SIZE	w	н	w	н
10	9	15 1/4	229	387
20	15	18 1/2	381	470
30	15	18 1/2	381	470
40	17	18 1/2	432	470
50	17	20 1/8	432	511
60*	15 1/2	17 1/2	394	445

\*SIZE 60 REQUIRES 2 FILTERS



# NOTES:

- 1"(25) NOMINAL FILTER MEDIA.
  CARDBOARD FRAME.
- MERV 3 RATING (THROWAWAY).




ALL METRIC DIMENSIONS () ARE SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO METRIC AND ROUNDED TO THE NEAREST MILLIMETER.

PROJECT:			buce,
ENGINEER:		4	FILTERS FAN POWERED TERMINAL
CUSTOMER:		2682	312L3 10-00
SUBMITTAL DATE:	SPEC. SYMBOL:	09/26/2	2019 MERV3 W/ IAS

DLIC6,

**Submittal Sheet** 



**SPEC. SYMBOL:** 

© Copyright PRICE INDUSTRIES 2018

**SUBMITTAL DATE:** 

**CUSTOMER:** 


268268

09/26/2019

FDC

SIZES 10-60 MERV8 W/ IAS


FDC-1-3



### NOTES:


- HANGER BRACKETS ARE 12 GAUGE ZINC COATED STEEL.
- 4 PER UNIT (6 FOR SIZE 60 W/IAS).
- 2 PER DISCHARGE ATTENUATOR OR SILENCER.
- 2 PER ELECTRIC AND WATER COIL FOR SIZE 60 ONLY.
- BRACKETS ARE SHIPPED LOOSE FOR FIELD INSTALLATION FOR USE WITH THREADED HANGER RODS (BY OTHERS).
- LAYOUT INDICATES SUGGESTED HANGER BRACKET LOCATIONS.

ALL METRIC DIMENSIONS () ARE SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO METRIC AND ROUNDED TO THE NEAREST MILLIMETER **PROJECT: ACCESSORIES ENGINEER:** HANGER BRACKETS [HB] **LOCATIONS CUSTOMER:** 267935 FOR FDC **SUBMITTAL DATE: SPEC. SYMBOL:** 01/12/2021




- 2 PER ELECTRIC AND WATER COIL FOR SIZE 60 ONLY.
- 2 ADDITIONAL HANGER BRACKETS WHEN ELECTRIC COIL & SM/PM LINER IS SELECTED FOR SIZE 10 & 50 ONLY.
- BRACKETS ARE SHIPPED LOOSE FOR FIELD INSTALLATION FOR USE WITH THREADED HANGER RODS (BY OTHERS).
- LAYOUT INDICATES SUGGESTED HANGER BRACKET LOCATIONS.

ALL METRIC DIMENSIONS () ARE SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO METRIC AND ROUNDED TO THE NEAREST MILLIMETER **PROJECT: ACCESSORIES ENGINEER:** HANGER BRACKETS [HB] **LOCATIONS CUSTOMER:** 267935 **FOR FDC SPEC. SYMBOL: SUBMITTAL DATE:** 01/12/2021




• LAYOUT INDICATES SUGGESTED HANGER BRACKET LOCATIONS.

	CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO	METRIC AND ROUNI			
PROJECT:					
			C.	ACCES	SORIES
ENGINEER:			4	HANGER BR	ACKETS [HB]
CUSTOMER:			267935		ATIONS TO T
SUBMITTAL DATE:	SPEC. SYMBOL:		01/12/2021		
© Copyright PRICE INDUSTRIES 2021	•		SHEET 3 OF 6	REV I	FDC-1-3




Solid Edg



- 2 PER RETURN SILENCER.
- 2 PER SENSIBLE COOLING COIL.
- BRACKETS ARE SHIPPED LOOSE FOR FIELD INSTALLATION FOR USE WITH THREADED HANGER RODS (BY OTHERS).
- LAYOUT INDICATES SUGGESTED HANGER BRACKET LOCATIONS.

ALL METRIC DIMENSIONS () ARE SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO METRIC AND ROUNDED TO THE NEAREST MILLIMETER **PROJECT: ACCESSORIES ENGINEER:** HANGER BRACKETS [HB] **LOCATIONS CUSTOMER:** 267935 FOR FDC DOAS **SPEC. SYMBOL: SUBMITTAL DATE:** 01/12/2021





		HBS QTY REQUIRED							
PRODUCT	BASE UNIT	DAS/SLR	IAS	EC/WC	EC+SM/PM LINER	SM/PM LINER	RSLR1	RSLR3	DOAS SENSIBLE COOLING COIL
FDC 10	RED (X4)	RED (X2)	-	-	RED (X2)	-	-	-	-
FDC 20-40	YELLOW (X4)	RED (X2)	-	-	-	-	-	i	-
FDC 50	YELLOW (X4)	RED (X2)	-	-	YELLOW (X2)	ı	-	ı	-
FDC 60	YELLOW (X4)	RED (X2)	RED (X2)	YELLOW (X2)	-	YELLOW (X2)	-	-	-
FDC DOAS 10	RED (X4)	RED (X2)	-	-	RED (X1)	-	RED (X2)	YELLOW (X2)	RED (X2)
FDC DOAS 20-40	YELLOW (X4)	RED (X2)	-	-	-	-	RED (X2)	YELLOW (X2)	RED (X2)
FDC DOAS 50	YELLOW (X4)	RED (X2)	-	-	YELLOW (X1)	-	RED (X2)	YELLOW (X2)	RED (X2) SEE NOTE 1

# NOTES:

- HBS ARE SHIPPED LOOSE FOR FIELD INSTALLATION BY OTHERS, UNLESS OTHERWISE NOTED ON ORDER
- NUMBER OF HBS SHIPPED PER UNIT ACCORDING TO THE REFERENCE CHARTS ABOVE
- RED SPRING LOAD RANGE: 16 LBS 35 LBS
- YELLOW SPRING LOAD RANGE: 36 LBS 65 LBS
- NOTE 1: FOR 6 & 8 ROW SENSIBLE COOLING COIL ON SIZE 50, USE YELLOW (X2)

PROJECT:

ENGINEER:


CUSTOMER:

SPEC. SYMBOL:

ALL METRIC DIMENSIONS () ARE SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO METRIC AND ROUNDED TO THE NEAREST MILLIMETER.

ACCESSORIES
HANGER BRACKETS [HB]
LOCATIONS
FOR FDC & FDC DOAS
HBS






IMPERIAL UNITS (INCHES)				
Unit Size	w	н	Α	
10	12	10	4	
20	16	15	5	
30	16	15	5	
40	16	15	5	
50	20	17 1/2	5	

SI UNITS (mm)				
Unit Size	w	н	Α	
10	305	254	102	
20	406	381	127	
30	406	381	127	
40	406	381	127	
50	508	445	127	

## NOTES:


- MADE FROM 22 GA GALVANIZED STEEL CONSTRUCTION
- SLIP AND DRIVE CONNECTION




PROJECT:			buce.
ENGINEER:		4	DISCHARGE COLLAR FAN POWERED TERMINALS
CUSTOMER:		268618	CONSTANT VOLUME FDC-1-X & FDC DOAS
SUBMITTAL DATE:	SPEC. SYMBOL:	09/26/20	9 SIZES 10 TO 50

	IMPERIAL UNITS (inches)				
UNIT	WITHOUT CO	OIL OR WITH	WITH HIGH	I CAPACITY	
SIZE	STANDARD COIL		STANDARD COIL COIL		OIL
	В	С	В	С	
10	12	10	14	12 1/2	
20	16	15	20	17 1/2	
30	16	15	20	17 1/2	
40	16	15	20	17 1/2	
50	20	17 1/2	28	17 1/2	


	SI UNITS (mm)			
UNIT		WITHOUT COIL OR WITH WITH HIG		CAPACITY
SIZE	STANDA	RD COIL	CC	OIL
	В	С	В	С
10	305	254	356	318
20	406	381	508	445
30	406	381	508	445
40	406	381	508	445
50	508	445	711	445






- 22 GA. GALVANIZED STEEL HOUSING, MECHANICALLY SEALED LEAK RESISTANT CONSTRUCTION.
   INSULATION TYPE WILL MATCH THE UNIT INSULATION TYPE.
- DISCHARGE ATTENUATORS SHIPPED LOOSE WITH SLIP AND DRIVE CLEATS WHERE REQUIRED.
   SLIP AND DRIVE CONNECTION (DISCHARGE COLLAR IS PROVIDED).

ALL METRIC DIMENSIONS ( ) ARE	SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO	METRIC AND ROUNDED TO THE NEARES	T MILLIMETER.	ı
PROJECT:			DLICE,	
ENGINEER:		4	ATTENUATOR FAN POWERED TERMINALS	
CUSTOMER:		268659	DISCHARGE FDC & FDC DOAS SIZES 10-50	В
SUBMITTAL DATE:	SPEC. SYMBOL:	12/05/2022	]	Solid






- 22 GA. GALVANIZED STEEL HOUSING, MECHANICALLY SEALED LEAK RESISTANT CONSTRUCTION.
   INSULATION TYPE WILL MATCH THE UNIT INSULATION TYPE.
- DISCHARGE ATTENUATORS SHIPPED LOOSE WITH SLIP AND DRIVE CLEATS WHERE REQUIRED.
   SLIP AND DRIVE CONNECTION (DISCHARGE COLLAR IS PROVIDED).

ALL METRIC DIMENSIONS ( ) ARE S	OFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO	METRIC AND ROUNDED TO THE NEARE	ST MILLIMETER.	l
PROJECT:			PLICE,	
ENGINEER:		4	ATTENUATOR FAN POWERED TERMINALS	
CUSTOMER:		268659	DISCHARGE FDC SIZE 60	Solid Edge
SUBMITTAL DATE:	SPEC. SYMBOL:	12/05/2022	:]	Solic




UNIT	IMPERIAL UNITS (inches)				
SIZE	ВС				
20	16	15			
30	16	15			
40	16	15			
50	20 17 1/2				

UNIT	SI UNITS (mm)			
SIZE	ВС			
20	406	381		
30	406	381		
40	406	381		
50	508	445		







### NOTES:

- 22 GA. GALVANIZED STEEL HOUSING, MECHANICALLY SEALED LEAK RESISTANT CONSTRUCTION.
- SILENCER WITH PERFORATED LINER OVER ACOUSTIC FIBERGLASS MEDIA.
- DISCHARGE SILENCERS SHIPPED LOOSE WITH SLIP AND DRIVE CLEATS WHERE REQUIRED.
- SLIP AND DRIVE CONNECTION (DISCHARGE COLLAR IS PROVIDED).

# **OPTIONAL LINERS:**


- ☐ FC FIBERGLASS CLOTH
- ☐ PL POLYMER LINER


ALL METRIC DIMENSIONS () ARE SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO METRIC AND ROUNDED TO THE NEAREST MILLIMETER **PROJECT: ATTENUATOR ENGINEER: FAN POWERED TERMINALS DISCHARGE SILENCER CUSTOMER:** 268660 **FDC & FDC DOAS SIZES 20-50 SPEC. SYMBOL:** 

**SUBMITTAL DATE:** 

09/26/2019







# NOTES:


- 22 GA. GALVANIZED STEEL HOUSING, MECHANICALLY SEALED LEAK RESISTANT CONSTRUCTION.
- SILENCER WITH PERFORATED LINER OVER ACOUSTIC FIBERGLASS MEDIA.
- $\bullet$  DISCHARGE SILENCERS SHIPPED LOOSE WITH SLIP AND DRIVE CLEATS WHERE REQUIRED.
- SLIP AND DRIVE CONNECTION (DISCHARGE COLLAR IS PROVIDED).

# **OPTIONAL LINERS:**

- ☐ FC FIBERGLASS CLOTH
- ☐ PL POLYMER LINER

ALL METRIC DIMENSIONS ( ) ARE	SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO	METRIC AND ROUNDED TO THE NEARES	T MILLIMETER.
PROJECT:			buce,
ENCINEED.		G	ATTENUATOR
ENGINEER:		H	FAN POWERED TERMINALS
CUSTOMER:		268660	DISCHARGE SILENCER FDC
SUBMITTAL DATE:	SPEC. SYMBOL:	09/26/2019	SIZE 60






IMPERIAL UNITS (INCHES)			
Unit Size	Inlet Sizes A	FAI Sizes K	
10	6, 8	4, 5, 6	
20	6, 8, 10	4, 5, 6	
30	8, 10, 12	6, 8	
40	10, 12, 14 6, 8		
50	12, 14	6, 8	


SI UNITS (mm)				
Unit Size	Inlet Sizes A	FAI Sizes K		
10	152, 203	102,127,152		
20	152, 203, 254	102,127,152		
30	203, 254, 305	152, 203		
40	254, 305, 356	152, 203		
50	305, 356 152, 203			


# NOTES:


- FRESH AIR INLET LINER MATCHES THE UNIT LINER
   OVERALL LENGTH OF UNIT IS INCREASED BY 11.000" (279) WITH THE FRESH AIR INLET OPTION

PROJECT:			Price:	
ENGINEER:			4	FDC FAN POWERED TERMINALS
CUSTOMER:			269644	CONSTANT VOLUME FRESH AIR INLET
SUBMITTAL DATE:	SPEC. SYMBOL:	0	9/26/2019	SIZES 10-50









#### NOTES:


- PLASTIC INJECTION MOLDED BUTTON, WITH GALVANIZED STEEL TABS.
- 6 LATCHES PER ACCESS PANEL.
- SLOT INCLUDED IN CAM LATCH FOR EASY ACCESSIBILITY WITH A SCREWDRIVER.


ALL METRIC DIMENSIONS () ARE SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO METRIC AND ROUNDED TO THE NEAREST MILLIMETER.  PROJECT:			
ENGINEER:		4	CAM LATCHES FAN POWERED TERMINAL
CUSTOMER:		269078	FDC / FDC-DOAS SIZES 10-60
SUBMITTAL DATE:	SPEC. SYMBOL:	09/26/2019	



UNIT SIZE	IMPERIAL UNITS (inches)		
UNIT SIZE	В	C	
10	31 5/8	12 1/2	
20	36 5/8	15	
30	36 5/8	15	
40	36 5/8	15	
50	39 5/8	17 1/2	

UNIT SIZE	SI UNITS (mm)		
	В	С	
10	803	318	
20	930	381	
30	930	381	
40	930	381	
50	1006	445	





# NOTES:

- 22 GA. GALVANIZED STEEL HOUSING, MECHANICALLY SEALED LEAK RESISTANT CONSTRUCTION.
   SILENCER WITH PERFORATED LINER OVER ACOUSTIC FIBERGLASS MEDIA.

### **OPTIONAL LINERS:**

☐ PL - POLYMER LINER

ALL METRIC DIMENSIONS () ARE SOFT CONVERTED. IMPERIAL DIMENSIONS ARE CONVERTED TO METRIC AND ROUNI PROJECT:			DED TO THE NEAREST MILLIMETER.	
ENGINEER:			ATTENUATOR FAN POWERED TERMINALS	
CUSTOMER:		271535	RETURN SILENCER FDC DOAS	
SUBMITTAL DATE:	SPEC. SYMBOL:	01/12/2021	SIZES 10-50	