

PERFORMANCE DATA

TBD2 – Curved Pattern Controller, 1 Slot

Model TBD2100 1 in. Slot Width

	Flow Rate (cfm)	50	75	100	125	150	175	200
Model = 24 in. 6 in. Diameter Inlet	Total Pressure (in. w.g.)	0.031	0.070	0.124	0.194	0.279	0.380	0.496
	Static Pressure (in. w.g.)	0.027	0.061	0.108	0.169	0.243	0.330	0.432
	Sound (NC)	-	18	27	34	39	43	47
	Throw (ft.)	3-6-11	6-8-17	7-11-20	9-14-23	11-17-25	13-19-27	15-20-29
	Flow Rate (cfm)	50	80	110	140	170	200	230
Model = 24 in. 8 in. Diameter Inlet	Total Pressure (in. w.g.)	0.023	0.060	0.113	0.182	0.269	0.372	0.492
	Static Pressure (in. w.g.)	0.022	0.056	0.106	0.172	0.254	0.352	0.465
	Sound (NC)	-	17	26	33	39	44	48
	Throw (ft.)	4-7-13	7-11-21	10-15-25	13-19-28	15-22-31	18-23-33	21-25-36
	Flow Rate (cfm)	75	105	135	165	195	225	255
Model = 24 in. 10 in. Diameter Inlet	Total Pressure (in. w.g.)	0.042	0.082	0.136	0.203	0.283	0.377	0.484
	Static Pressure (in. w.g.)	0.041	0.080	0.132	0.197	0.275	0.366	0.470
	Sound (NC)	-	22	30	36	40	45	48
	Throw (ft.)	8-12-23	11-16-27	14-21-31	17-24-34	20-26-37	23-28-39	24-30-42
	Flow Rate (cfm)	80	120	160	200	240	280	320
Model = 48 in. 6 in. Diameter Inlet	Total Pressure (in. w.g.)	0.027	0.061	0.109	0.171	0.246	0.334	0.437
	Static Pressure (in. w.g.)	0.017	0.038	0.068	0.106	0.152	0.207	0.271
	Sound (NC)	-	16	24	31	36	41	45
	Throw (ft.)	1-3-8	3-6-12	5-8-14	7-10-16	8-12-18	9-13-19	11-14-20
	Flow Rate (cfm)	100	150	200	250	300	350	400
Model = 48 in. 8 in. Diameter Inlet	Total Pressure (in. w.g.)	0.032	0.072	0.128	0.200	0.288	0.392	0.512
	Static Pressure (in. w.g.)	0.027	0.060	0.107	0.168	0.242	0.329	0.430
	Sound (NC)	-	19	27	34	39	44	48
	Throw (ft.)	3-6-12	6-9-16	8-12-19	10-15-21	12-16-23	14-17-25	15-19-26
	Flow Rate (cfm)	100	160	220	280	340	400	460
Model = 48 in. 10 in. Diameter Inlet	Total Pressure (in. w.g.)	0.026	0.065	0.124	0.201	0.296	0.409	0.541
	Static Pressure (in. w.g.)	0.023	0.060	0.114	0.184	0.271	0.376	0.497
	Sound (NC)	-	18	27	34	40	45	49
	Throw (ft.)	4-7-14	8-11-19	10-15-22	13-17-25	16-19-27	17-21-29	18-22-31
	Flow Rate (cfm)	150	200	250	300	350	400	450
Model = 48 in. 12 in. Diameter Inlet	Total Pressure (in. w.g.)	0.048	0.085	0.133	0.192	0.261	0.341	0.432
	Static Pressure (in. w.g.)	0.046	0.081	0.127	0.183	0.249	0.325	0.411
	Sound (NC)	-	22	29	34	39	43	46
	Throw (ft.)	8-12-20	11-16-23	13-18-25	16-20-28	17-21-30	19-23-32	20-24-34

Model TBD2150 1-1/2 in. Slot Width

	Flow Rate (cfm)	50	75	100	125	150	175	200
Model = 24 in. 6 in. Diameter Inlet	Total Pressure (in. w.g.)	0.028	0.063	0.113	0.176	0.253	0.345	0.450
	Static Pressure (in. w.g.)	0.024	0.054	0.096	0.151	0.217	0.295	0.386
	Sound (NC)	-	17	25	32	37	42	46
	Throw (ft.)	3-5-11	5-8-16	7-11-20	9-14-22	11-16-25	13-19-26	14-20-28
	Flow Rate (cfm)	50	80	110	140	170	200	230
Model = 24 in. 8 in. Diameter Inlet	Total Pressure (in. w.g.)	0.021	0.054	0.102	0.166	0.244	0.338	0.447
	Static Pressure (in. w.g.)	0.020	0.051	0.096	0.156	0.229	0.317	0.420
	Sound (NC)	-	15	25	32	38	42	47
	Throw (ft.)	4-7-13	7-11-21	10-15-24	12-18-27	15-21-30	18-23-33	20-25-35
	Flow Rate (cfm)	75	105	135	165	195	225	255
Model = 24 in. 10 in. Diameter Inlet	Total Pressure (in. w.g.)	0.038	0.074	0.123	0.184	0.257	0.342	0.439
	Static Pressure (in. w.g.)	0.037	0.072	0.119	0.178	0.249	0.331	0.426
	Sound (NC)	-	21	28	34	39	43	47
	Throw (ft.)	8-12-22	11-16-26	14-21-30	17-23-33	20-26-36	22-27-39	24-29-41

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks “-” indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
Ptotal = Pstatic + Pvelocity
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)

PERFORMANCE DATA

TBD2 – Curved Pattern Controller, 1 Slot (continued)

Model = 48 in. 6 in. Diameter Inlet	Flow Rate (cfm)	80	125	170	215	260	305	350
	Total Pressure (in. w.g.)	0.025	0.061	0.112	0.179	0.262	0.361	0.475
	Static Pressure (in. w.g.)	0.014	0.035	0.065	0.104	0.153	0.210	0.277
	Sound (NC)	-	15	24	31	37	42	46
	Throw (ft.)	1-3-8	3-6-12	6-8-15	7-11-16	9-13-18	10-14-20	11-15-21
Model = 48 in. 8 in. Diameter Inlet	Flow Rate (cfm)	90	145	200	255	310	365	420
	Total Pressure (in. w.g.)	0.024	0.061	0.116	0.189	0.279	0.387	0.513
	Static Pressure (in. w.g.)	0.019	0.050	0.096	0.156	0.230	0.319	0.423
	Sound (NC)	-	16	26	33	39	43	48
	Throw (ft.)	2-5-11	6-9-16	8-12-16	10-15-21	12-16-23	14-17-25	15-19-26
Model = 48 in. 10 in. Diameter Inlet	Flow Rate (cfm)	110	175	240	305	370	435	500
	Total Pressure (in. w.g.)	0.028	0.071	0.134	0.216	0.318	0.440	0.582
	Static Pressure (in. w.g.)	0.026	0.065	0.122	0.197	0.290	0.401	0.529
	Sound (NC)	-	19	28	35	41	46	50
	Throw (ft.)	5-8-15	8-12-19	11-16-22	14-18-25	16-20-28	17-21-30	19-23-32
Model = 48 in. 12 in. Diameter Inlet	Flow Rate (cfm)	150	200	250	300	350	400	450
	Total Pressure (in. w.g.)	0.044	0.078	0.121	0.174	0.237	0.310	0.393
	Static Pressure (in. w.g.)	0.041	0.073	0.115	0.165	0.225	0.294	0.372
	Sound (NC)	-	21	27	33	37	41	45
	Throw (ft.)	8-12-19	10-16-22	13-18-25	16-19-27	17-21-30	18-22-32	19-24-34

For Performance Notes, see previous page.

TBD2 – Curved Pattern Controller, 2 Slot, 1-Way Discharge

Model TBD2100 1 in. Slot Width

Model = 24 in. 6 in. Diameter Inlet	Flow Rate (cfm)	90	125	160	195	230	265	300
	Total Pressure (in. w.g.)	0.058	0.112	0.184	0.273	0.379	0.503	0.645
	Static Pressure (in. w.g.)	0.045	0.087	0.142	0.211	0.294	0.390	0.500
	Sound (NC)	16	25	33	38	43	47	51
	Throw (ft.)	5-8-16	8-11-20	10-15-22	12-17-25	14-19-27	16-20-29	18-22-31
Model = 24 in. 8 in. Diameter Inlet	Flow Rate (cfm)	90	135	180	225	270	315	360
	Total Pressure (in. w.g.)	0.033	0.074	0.131	0.204	0.294	0.400	0.523
	Static Pressure (in. w.g.)	0.029	0.064	0.114	0.178	0.257	0.349	0.456
	Sound (NC)	-	20	29	35	40	45	49
	Throw (ft.)	7-10-19	10-15-24	13-19-27	17-22-31	19-24-33	21-26-36	22-27-39
Model = 24 in. 10 in. Diameter Inlet	Flow Rate (cfm)	100	155	210	265	320	375	430
	Total Pressure (in. w.g.)	0.026	0.062	0.114	0.181	0.264	0.363	0.477
	Static Pressure (in. w.g.)	0.024	0.057	0.105	0.167	0.243	0.333	0.438
	Sound (NC)	-	18	27	34	40	44	48
	Throw (ft.)	9-13-23	13-20-28	18-23-33	21-26-37	24-29-41	25-31-44	27-33-47
Model = 48 in. 6 in. Diameter Inlet	Flow Rate (cfm)	150	195	240	285	330	375	420
	Total Pressure (in. w.g.)	0.078	0.132	0.200	0.281	0.377	0.487	0.611
	Static Pressure (in. w.g.)	0.042	0.070	0.106	0.150	0.201	0.260	0.326
	Sound (NC)	19	26	32	38	42	46	49
	Throw (ft.)	3-6-12	5-8-14	7-10-15	8-12-17	9-13-18	10-13-19	11-14-20
Model = 48 in. 8 in. Diameter Inlet	Flow Rate (cfm)	170	225	280	335	390	445	500
	Total Pressure (in. w.g.)	0.056	0.099	0.153	0.219	0.296	0.386	0.487
	Static Pressure (in. w.g.)	0.042	0.073	0.113	0.161	0.219	0.285	0.359
	Sound (NC)	15	23	30	35	39	43	47
	Throw (ft.)	6-8-15	7-11-17	9-13-19	11-15-21	13-16-22	14-17-24	15-18-25
Model = 48 in. 10 in. Diameter Inlet	Flow Rate (cfm)	175	240	305	370	435	500	565
	Total Pressure (in. w.g.)	0.038	0.072	0.116	0.171	0.236	0.312	0.398
	Static Pressure (in. w.g.)	0.032	0.060	0.097	0.142	0.196	0.259	0.331
	Sound (NC)	-	19	26	32	37	41	44
	Throw (ft.)	7-10-17	9-14-20	12-16-22	14-17-24	15-19-26	16-20-28	17-21-30
Model = 48 in. 12 in. Diameter Inlet	Flow Rate (cfm)	200	275	350	425	500	575	650
	Total Pressure (in. w.g.)	0.035	0.065	0.106	0.156	0.216	0.286	0.366
	Static Pressure (in. w.g.)	0.031	0.058	0.094	0.138	0.191	0.253	0.323
	Sound (NC)	-	18	26	31	36	40	44
	Throw (ft.)	9-13-20	12-16-23	15-18-26	16-20-29	18-22-31	19-23-33	20-25-35

For Performance Notes, see end of section.

PERFORMANCE DATA

TBD2 – Curved Pattern Controller, 2 Slot, 1-Way Discharge (continued)

Model TBD2150 1-1/2 in. Slot Width

Model = 24 in. 6 in. Diameter Inlet	Flow Rate (cfm)	90	125	160	195	230	265	300
	Total Pressure (in. w.g.)	0.047	0.090	0.148	0.220	0.305	0.405	0.52
	Static Pressure (in. w.g.)	0.034	0.065	0.106	0.158	0.220	0.292	0.374
	Sound (NC)	-	22	29	35	40	44	48
	Throw (ft.)	5-8-15	7-11-19	9-14-21	11-16-23	13-18-25	15-19-27	17-20-29
Model = 24 in. 8 in. Diameter Inlet	Flow Rate (cfm)	90	135	180	225	270	315	360
	Total Pressure (in. w.g.)	0.026	0.059	0.105	0.164	0.237	0.322	0.421
	Static Pressure (in. w.g.)	0.022	0.050	0.089	0.138	0.199	0.271	0.355
	Sound (NC)	-	16	25	32	37	41	45
	Throw (ft.)	6-9-18	9-14-22	12-18-26	15-20-29	18-22-32	20-24-34	21-26-37
Model = 24 in. 10 in. Diameter Inlet	Flow Rate (cfm)	100	155	210	265	320	375	430
	Total Pressure (in. w.g.)	0.021	0.050	0.092	0.146	0.213	0.292	0.384
	Static Pressure (in. w.g.)	0.019	0.045	0.082	0.131	0.191	0.263	0.346
	Sound (NC)	-	15	24	31	36	41	45
	Throw (ft.)	8-12-22	12-19-27	17-22-31	20-25-35	22-27-39	24-30-42	26-32-45
Model = 48 in. 6 in. Diameter Inlet	Flow Rate (cfm)	150	200	250	300	350	400	450
	Total Pressure (in. w.g.)	0.064	0.113	0.177	0.254	0.346	0.452	0.572
	Static Pressure (in. w.g.)	0.027	0.048	0.076	0.109	0.148	0.193	0.245
	Sound (NC)	15	24	30	36	40	44	48
	Throw (ft.)	3-6-11	5-8-13	6-10-15	8-11-16	9-12-17	10-13-19	11-14-20
Model = 48 in. 8 in. Diameter Inlet	Flow Rate (cfm)	180	240	300	360	420	480	540
	Total Pressure (in. w.g.)	0.051	0.092	0.143	0.206	0.280	0.366	0.463
	Static Pressure (in. w.g.)	0.035	0.062	0.097	0.140	0.190	0.248	0.314
	Sound (NC)	-	22	28	34	38	42	46
	Throw (ft.)	6-8-14	7-11-17	9-13-19	11-14-20	13-16-22	14-17-24	14-18-25
Model = 48 in. 10 in. Diameter Inlet	Flow Rate (cfm)	220	290	360	430	500	570	640
	Total Pressure (in. w.g.)	0.049	0.086	0.132	0.188	0.254	0.330	0.417
	Static Pressure (in. w.g.)	0.039	0.068	0.105	0.149	0.202	0.262	0.331
	Sound (NC)	-	21	28	33	38	41	45
	Throw (ft.)	8-12-18	10-14-20	13-16-23	14-18-25	16-19-27	17-20-29	18-22-30
Model = 48 in. 12 in. Diameter Inlet	Flow Rate (cfm)	275	355	435	515	595	675	755
	Total Pressure (in. w.g.)	0.053	0.089	0.134	0.187	0.250	0.322	0.403
	Static Pressure (in. w.g.)	0.046	0.076	0.115	0.161	0.214	0.276	0.345
	Sound (NC)	15	23	29	34	38	42	45
	Throw (ft.)	11-15-22	14-18-25	16-19-27	17-21-30	19-23-32	20-24-34	21-26-36

Performance Notes:

1. Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
2. Airflow is in cubic feet per minute [cfm].
3. NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
4. Blanks “-” indicate an NC level below 15.
5. All pressures are in inches of water column [in. w.g.].
6. Pressures not listed can be calculated using the following formula:
P_{total} = P_{static} + P_{velocity}
7. Throw data is based on supply air and room air being at isothermal conditions.
8. Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)

PERFORMANCE DATA

TBD3 – Ice-Tong Pattern Controller, 1 Slot

Model TBD350 1/2 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.053	0.120	0.214	0.334	0.481	0.654				
	Static Pressure (in. w.g.)	0.051	0.115	0.204	0.318	0.458	0.624				
	Flow Rate (cfm)	39	59	78	98	118	137				
	Sound (NC)	-	25	35	42	48	53				
	Throw (ft.)	4-7-14	7-11-19	10-14-22	12-18-25	14-19-27	17-21-30				
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.141	0.317	0.564							
	Static Pressure (in. w.g.)	0.139	0.312	0.554							
	Flow Rate (cfm)	70	105	140							
	Sound (NC)	26	40	49							
	Throw (ft.)	8-13-21	13-18-26	17-21-30							
Length = 48 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.020	0.045	0.080	0.124	0.179	0.244	0.319	0.403	0.498	
	Static Pressure (in. w.g.)	0.017	0.039	0.070	0.109	0.157	0.213	0.279	0.353	0.436	
	Flow Rate (cfm)	39	59	78	98	118	137	157	176	196	
	Sound (NC)	-	-	20	28	34	39	43	47	50	
	Throw (ft.)	1-3-7	3-5-10	4-7-13	6-8-16	7-10-17	8-12-19	9-13-20	10-15-21	11-16-22	
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.045	0.100	0.178	0.278	0.401	0.546				
	Static Pressure (in. w.g.)	0.042	0.095	0.168	0.263	0.378	0.515				
	Flow Rate (cfm)	70	105	140	175	209	244				
	Sound (NC)	-	23	32	39	45	51				
	Throw (ft.)	4-6-12	6-9-16	8-12-19	10-15-21	12-16-23	14-17-25				
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.092	0.207	0.367	0.574						
	Static Pressure (in. w.g.)	0.089	0.201	0.357	0.558						
	Flow Rate (cfm)	109	164	218	273						
	Sound (NC)	20	33	43	50						
	Throw (ft.)	6-9-17	9-14-20	12-17-23	15-18-26						
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.174	0.391	0.695							
	Static Pressure (in. w.g.)	0.171	0.385	0.685							
	Flow Rate (cfm)	157	236	314							
	Sound (NC)	29	43	52							
	Throw (ft.)	9-13-20	13-17-24	16-20-28							
Length = 60 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.015	0.035	0.061	0.096	0.138	0.188	0.245	0.311	0.384	0.552
	Static Pressure (in. w.g.)	0.013	0.029	0.051	0.080	0.116	0.157	0.206	0.260	0.321	0.463
	Flow Rate (cfm)	39	59	78	98	118	137	157	176	196	235
	Sound (NC)	-	-	16	24	30	35	39	43	47	53
	Throw (ft.)	1-1-4	1-3-6	2-4-8	3-5-10	4-6-11	4-7-13	5-8-14	6-9-15	6-10-16	8-11-17
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.032	0.072	0.128	0.200	0.288	0.392	0.512			
	Static Pressure (in. w.g.)	0.029	0.066	0.118	0.184	0.265	0.361	0.472			
	Flow Rate (cfm)	70	105	140	175	209	244	279			
	Sound (NC)	-	18	27	35	41	46	50			
	Throw (ft.)	2-3-7	3-5-10	5-7-13	6-9-15	7-10-16	8-12-17	9-13-19			
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.063	0.143	0.253	0.396	0.570					
	Static Pressure (in. w.g.)	0.061	0.137	0.243	0.380	0.548					
	Flow Rate (cfm)	109	164	218	273	327					
	Sound (NC)	-	28	37	45	51					
	Throw (ft.)	4-5-11	5-8-14	7-11-16	9-13-18	11-14-20					
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.117	0.264	0.469							
	Static Pressure (in. w.g.)	0.115	0.258	0.459							
	Flow Rate (cfm)	157	236	314							
	Sound (NC)	24	37	46							
	Throw (ft.)	5-8-14	8-11-17	10-14-20							

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks "-" indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
Ptotal = Pstatic + Pvelocity
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
- Blank area outside recommended operating range.
- Does not include effects of ceiling radiation damper (TBD3-FR).

PERFORMANCE DATA

TBD3 – Ice-Tong Pattern Controller, 1 Slot (continued)

Model TBD375 3/4 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.040	0.090	0.159	0.249	0.358	0.488	0.637			
	Static Pressure (in. w.g.)	0.037	0.084	0.149	0.233	0.336	0.457	0.597			
	Flow Rate (cfm)	39	59	78	98	118	137	157			
	Sound (NC)	-	22	33	41	48	54	58			
	Throw (ft.)	3-6-13	6-10-19	9-13-22	11-16-25	13-19-27	15-21-30	17-22-32			
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.102	0.229	0.406	0.635						
	Static Pressure (in. w.g.)	0.099	0.223	0.396	0.619						
	Flow Rate (cfm)	70	105	140	175						
	Sound (NC)	26	41	52	60						
	Throw (ft.)	8-11-21	11-17-26	15-21-30	19-24-33						
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.220	0.495	0.880							
	Static Pressure (in. w.g.)	0.217	0.489	0.870							
	Flow Rate (cfm)	109	164	218							
	NC	42	57	68							
	Throw (ft.)	12-18-26	18-23-32	22-26-37							
Length = 48 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.014	0.032	0.057	0.090	0.129	0.176	0.229	0.290	0.358	0.516
	Static Pressure (in. w.g.)	0.012	0.027	0.047	0.074	0.107	0.145	0.189	0.240	0.296	0.426
	Flow Rate (cfm)	39	59	78	98	118	137	157	176	196	235
	Sound (NC)	-	-	-	20	27	33	38	42	46	53
	Throw (ft.)	1-2-6	2-4-9	3-6-12	5-7-14	6-9-17	7-10-19	8-12-20	9-13-21	10-14-22	12-17-24
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.033	0.075	0.133	0.208	0.299	0.408	0.532			
	Static Pressure (in. w.g.)	0.031	0.069	0.123	0.192	0.277	0.377	0.492			
	Flow Rate (cfm)	70	105	140	175	209	244	279			
	Sound (NC)	-	19	29	37	44	50	55			
	Throw (ft.)	2-5-10	5-8-15	7-10-19	9-13-21	10-15-23	12-17-25	14-19-26			
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.067	0.151	0.269	0.421	0.606					
	Static Pressure (in. w.g.)	0.065	0.146	0.259	0.405	0.584					
	Flow Rate (cfm)	109	164	218	273	327					
	Sound (NC)	18	33	44	52	59					
	Throw (ft.)	5-8-16	8-12-20	11-16-23	13-18-26	16-20-29					
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.124	0.279	0.496							
	Static Pressure (in. w.g.)	0.122	0.273	0.486							
	Flow Rate (cfm)	157	236	314							
	Sound (NC)	30	45	56							
	Throw (ft.)	8-12-20	12-17-24	15-20-28							
Length = 60 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.011	0.024	0.042	0.066	0.095	0.129	0.169	0.214	0.264	0.380
	Static Pressure (in. w.g.)	0.008	0.018	0.032	0.050	0.073	0.099	0.129	0.163	0.202	0.290
	Flow Rate (cfm)	39	59	78	98	118	137	157	176	196	235
	Sound (NC)	-	-	-	-	21	26	31	36	40	46
	Throw (ft.)	0-1-3	1-2-5	1-3-7	2-4-8	3-5-10	4-6-12	4-7-13	5-7-15	5-8-16	7-10-17
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.024	0.054	0.095	0.149	0.214	0.292	0.381	0.482	0.595	
	Static Pressure (in. w.g.)	0.021	0.048	0.085	0.133	0.192	0.261	0.341	0.431	0.533	
	Flow Rate (cfm)	70	105	140	175	209	244	279	314	349	
	Sound (NC)	-	-	22	31	37	43	48	52	56	
	Throw (ft.)	1-3-6	3-4-9	4-6-12	5-7-15	6-9-16	7-10-17	8-12-19	9-13-20	10-15-21	
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.047	0.106	0.188	0.294	0.423	0.576				
	Static Pressure (in. w.g.)	0.045	0.100	0.178	0.278	0.401	0.546				
	Flow Rate (cfm)	109	164	218	273	327	382				
	Sound (NC)	-	26	36	45	51	57				
	Throw (ft.)	3-5-9	5-7-14	6-9-16	8-11-18	9-14-20	11-15-22				
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.085	0.191	0.340	0.532						
	Static Pressure (in. w.g.)	0.083	0.186	0.330	0.516						
	Flow Rate (cfm)	157	236	314	393						
	Sound (NC)	23	38	48	57						
	Throw (ft.)	4-7-13	7-10-17	9-13-20	11-16-22						

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks "-" indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
 $P_{total} = P_{static} + P_{velocity}$
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
- Blank area outside recommended operating range.
- Does not include effects of ceiling radiation damper (TBD3-FR).

PERFORMANCE DATA

TBD3 – Ice-Tong Pattern Controller, 1 Slot (continued)

Model TBD3100 1 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.026	0.057	0.102	0.159	0.230	0.313	0.408	0.517	0.638	
	Static Pressure (in. w.g.)	0.023	0.052	0.092	0.144	0.207	0.282	0.368	0.466	0.575	
	Flow Rate (cfm)	39	59	78	98	118	137	157	176	196	
	Sound (NC)	-	-	16	25	31	37	42	46	50	
	Throw (ft.)	2-5-12	5-9-18	8-12-22	10-15-25	12-18-27	14-20-30	16-22-32	18-24-34	19-25-35	
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.055	0.124	0.221	0.345	0.496	0.676				
	Static Pressure (in. w.g.)	0.053	0.119	0.211	0.329	0.474	0.645				
	Flow Rate (cfm)	70	105	140	175	209	244				
	Sound (NC)	-	20	30	39	45	51				
	Throw (ft.)	7-10-21	10-16-26	14-21-30	17-24-33	21-26-37	23-28-39				
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.107	0.240	0.427							
	Static Pressure (in. w.g.)	0.104	0.234	0.417							
	Flow Rate (cfm)	109	164	218							
	Sound (NC)	17	32	42							
	Throw (ft.)	11-16-26	16-23-32	22-26-37							
Length = 48 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.011	0.026	0.046	0.071	0.102	0.139	0.182	0.231	0.285	0.410
	Static Pressure (in. w.g.)	0.009	0.020	0.036	0.056	0.080	0.109	0.142	0.180	0.222	0.320
	Flow Rate (cfm)	39	59	78	98	118	137	157	176	196	235
	Sound (NC)	-	-	-	-	17	23	28	32	36	43
	Throw (ft.)	1-1-5	1-3-8	2-5-10	4-6-13	5-8-15	6-9-18	7-10-20	8-12-21	9-13-22	10-15-24
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.022	0.050	0.088	0.138	0.199	0.271	0.353	0.447	0.552	
	Static Pressure (in. w.g.)	0.020	0.044	0.078	0.122	0.176	0.240	0.313	0.397	0.490	
	Flow Rate (cfm)	70	105	140	175	209	244	279	314	349	
	Sound (NC)	-	-	-	22	29	35	39	44	48	
	Throw (ft.)	2-4-9	4-7-14	6-9-18	8-11-21	9-14-23	11-16-25	12-18-26	14-20-28	15-21-30	
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.039	0.088	0.157	0.245	0.353	0.480	0.627			
	Static Pressure (in. w.g.)	0.037	0.083	0.147	0.229	0.330	0.449	0.587			
	Flow Rate (cfm)	109	164	218	273	327	382	436			
	Sound (NC)	-	-	24	32	39	45	50			
	Throw (ft.)	4-7-14	7-11-20	10-14-23	12-18-26	14-20-29	17-22-31	19-23-33			
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.065	0.147	0.261	0.408	0.588					
	Static Pressure (in. w.g.)	0.063	0.141	0.251	0.392	0.565					
	Flow Rate (cfm)	157	236	314	393	471					
	Sound (NC)	-	23	33	42	48					
	Throw (ft.)	7-10-20	10-15-24	14-20-28	17-22-31	20-24-34					
Length = 60 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.009	0.020	0.036	0.056	0.081	0.110	0.144	0.183	0.225	0.325
	Static Pressure (in. w.g.)	0.007	0.015	0.026	0.041	0.059	0.080	0.104	0.132	0.163	0.235
	Flow Rate (cfm)	39	59	78	98	118	137	157	176	196	235
	Sound (NC)	-	-	-	-	-	18	23	28	32	38
	Throw (ft.)	0-1-2	1-1-4	1-2-6	2-4-7	2-4-9	3-5-10	4-6-12	4-7-13	5-7-15	6-9-17
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.017	0.038	0.068	0.106	0.152	0.207	0.271	0.343	0.423	0.609
	Static Pressure (in. w.g.)	0.014	0.032	0.058	0.090	0.130	0.177	0.231	0.292	0.361	0.519
	Flow Rate (cfm)	70	105	140	175	209	244	279	314	349	419
	Sound (NC)	-	-	-	17	24	30	35	39	43	50
	Throw (ft.)	1-2-5	2-4-8	3-5-10	4-7-13	5-8-16	6-9-17	7-10-19	8-12-20	9-13-21	10-16-23
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.029	0.066	0.117	0.183	0.263	0.358	0.467	0.591		
	Static Pressure (in. w.g.)	0.027	0.060	0.107	0.167	0.240	0.327	0.427	0.541		
	Flow Rate (cfm)	109	164	218	273	327	382	436	491		
	Sound (NC)	-	-	19	27	34	40	44	49		
	Throw (ft.)	2-4-8	4-6-12	5-8-16	7-10-18	8-12-20	9-14-22	11-16-23	12-17-25		
Length = 60 in. Inlet = 12 in.	Total Pressure	0.048	0.107	0.190	0.297	0.428	0.583				
	Static Pressure	0.045	0.101	0.180	0.282	0.406	0.552				
	Flow Rate	157	236	314	393	471	550				
	Sound (NC)	-	17	28	36	43	48				
	Throw 150,100,50	4-6-12	6-9-17	8-12-20	10-15-22	12-17-24	14-18-26				

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks “-” indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
 $P_{total} = P_{static} + P_{velocity}$
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
- Blank area outside recommended operating range.
- Does not include effects of ceiling radiation damper (TBD3-FR).

PERFORMANCE DATA

TBD3 – Ice-Tong Pattern Controller, 2 Slot

Model TBD350 1/2 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.045	0.080	0.124	0.179	0.244	0.319	0.403	0.498		
	Static Pressure (in. w.g.)	0.039	0.070	0.109	0.157	0.213	0.279	0.353	0.436		
	Flow Rate (cfm)	59	78	98	118	137	157	176	196		
	Sound (NC)	-	20	28	34	39	43	47	50		
	Throw (ft.)	7-11-19	10-14-22	12-18-25	14-19-27	17-21-30	18-22-32	19-24-34	20-25-35		
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.100	0.178	0.278	0.401						
	Static Pressure (in. w.g.)	0.095	0.168	0.263	0.378						
	Flow Rate (cfm)	105	140	175	209						
	Sound (NC)	23	32	39	45						
	Throw (ft.)	10-16-26	14-21-30	17-24-33	21-26-37						
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.207	0.367	0.574							
	Static Pressure (in. w.g.)	0.201	0.357	0.558							
	Flow Rate (cfm)	164	218	273							
	NC	33	43	50							
	Throw (ft.)	16-23-32	22-26-37	24-29-42							
Length = 48 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.039	0.061	0.088	0.120	0.157	0.199	0.245	0.353	0.480
	Static Pressure (in. w.g.)		0.029	0.046	0.066	0.090	0.117	0.148	0.183	0.263	0.358
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	17	23	28	32	36	40	46	51
	Throw (ft.)		2-5-10	4-6-13	5-8-15	6-9-18	7-10-20	8-12-21	9-13-22	10-15-24	12-18-26
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.039	0.069	0.108	0.156	0.212	0.277	0.351	0.433	0.624	
	Static Pressure (in. w.g.)	0.033	0.059	0.093	0.133	0.182	0.237	0.300	0.371	0.534	
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	
	Sound (NC)	-	18	25	31	37	41	45	48	54	
	Throw (ft.)	4-7-14	6-9-18	8-11-21	9-14-23	11-16-25	12-18-26	14-20-28	15-21-30	18-23-32	
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.069	0.124	0.193	0.278	0.378	0.494	0.625			
	Static Pressure (in. w.g.)	0.064	0.114	0.177	0.256	0.348	0.454	0.575			
	Flow Rate (cfm)	164	218	273	327	382	436	491			
	Sound (NC)	17	27	34	40	45	50	53			
	Throw (ft.)	7-11-20	10-14-23	12-18-26	14-20-29	17-22-31	19-23-33	20-25-35			
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.120	0.214	0.334	0.482	0.655					
	Static Pressure (in. w.g.)	0.115	0.204	0.319	0.459	0.625					
	Flow Rate (cfm)	236	314	393	471	550					
	Sound (NC)	25	35	42	48	53					
	Throw (ft.)	10-15-24	14-20-28	17-22-31	20-24-34	21-26-37					
Length = 60 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.033	0.052	0.075	0.102	0.133	0.168	0.208	0.299	0.407
	Static Pressure (in. w.g.)		0.023	0.036	0.052	0.071	0.093	0.118	0.145	0.209	0.285
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	21	26	30	34	37	43	48
	Throw (ft.)		1-2-6	2-4-7	2-4-9	3-5-10	4-6-12	4-7-13	5-7-15	6-9-17	7-10-18
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.031	0.054	0.085	0.122	0.166	0.217	0.275	0.339	0.488	0.664
	Static Pressure (in. w.g.)	0.025	0.044	0.069	0.100	0.136	0.177	0.224	0.277	0.398	0.542
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	22	28	33	37	41	45	51	56
	Throw (ft.)	2-4-8	3-5-10	4-7-13	5-8-16	6-9-17	7-10-19	8-12-20	9-13-21	10-16-23	12-17-25
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.051	0.091	0.142	0.205	0.279	0.365	0.462	0.570		
	Static Pressure (in. w.g.)	0.046	0.081	0.127	0.183	0.249	0.325	0.411	0.508		
	Flow Rate (cfm)	164	218	273	327	382	436	491	545		
	Sound (NC)	-	22	30	36	41	45	49	52		
	Throw (ft.)	4-6-12	5-8-16	7-10-18	8-12-20	9-14-22	11-16-23	12-17-25	14-18-26		
Length = 60 in. Inlet = 12 in.	Total Pressure	0.085	0.152	0.237	0.342	0.465	0.607				
	Static Pressure	0.080	0.142	0.222	0.319	0.434	0.567				
	Flow Rate	236	314	393	471	550	628				
	NC	20	30	37	43	48	53				
	Throw 150,100,50	6-9-17	8-12-20	10-15-22	12-17-24	14-18-26	16-20-28				

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks "-" indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
 $P_{total} = P_{static} + P_{velocity}$
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
- Blank area outside recommended operating range.
- Does not include effects of ceiling radiation damper (TBD3-FR).

PERFORMANCE DATA

TBD3 – Ice-Tong Pattern Controller, 2 Slot (continued)

Model TBD375 3/4 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.032	0.057	0.090	0.129	0.176	0.229	0.290	0.358	0.516	
	Static Pressure (in. w.g.)	0.027	0.047	0.074	0.107	0.145	0.189	0.240	0.296	0.426	
	Flow Rate (cfm)	59	78	98	118	137	157	176	196	235	
	Sound (NC)	-	-	20	27	33	38	42	46	53	
	Throw (ft.)	3-7-15	6-10-20	8-13-25	10-15-27	12-18-30	13-20-32	15-23-34	17-25-35	20-27-39	
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.075	0.133	0.208	0.299	0.408	0.532	0.674			
	Static Pressure (in. w.g.)	0.069	0.123	0.192	0.277	0.377	0.492	0.623			
	Flow Rate (cfm)	105	140	175	209	244	279	314			
	Sound (NC)	19	29	37	44	50	55	59			
	Throw (ft.)	9-13-26	12-18-30	15-22-33	18-26-37	21-28-39	24-30-42	26-32-45			
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.151	0.269	0.421	0.606						
	Static Pressure (in. w.g.)	0.146	0.259	0.405	0.584						
	Flow Rate (cfm)	164	218	273	327						
	Sound (NC)	33	44	52	59						
	Throw (ft.)	14-21-32	19-26-37	23-29-42	26-32-46						
Length = 48 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.023	0.036	0.052	0.070	0.092	0.116	0.143	0.206	0.281
	Static Pressure (in. w.g.)		0.013	0.020	0.029	0.040	0.052	0.066	0.081	0.117	0.159
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	19	23	27	34	40
	Throw (ft.)		1-3-9	2-5-11	3-7-13	4-8-15	5-9-17	7-10-20	7-11-22	9-13-24	10-15-26
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.027	0.049	0.076	0.110	0.150	0.195	0.247	0.305	0.440	0.598
	Static Pressure (in. w.g.)	0.022	0.039	0.061	0.087	0.119	0.155	0.197	0.243	0.350	0.476
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	17	24	29	34	39	43	49	55
	Throw (ft.)	2-5-12	4-8-16	6-10-19	8-12-23	9-14-25	10-16-26	12-17-28	13-19-30	16-23-32	18-25-35
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.052	0.092	0.144	0.207	0.281	0.367	0.465	0.574		
	Static Pressure (in. w.g.)	0.046	0.082	0.128	0.184	0.251	0.328	0.415	0.512		
	Flow Rate (cfm)	164	218	273	327	382	436	491	545		
	Sound (NC)	-	22	30	37	42	47	52	55		
	Throw (ft.)	6-9-18	8-12-23	10-15-26	12-18-29	14-21-31	16-23-33	18-25-35	20-26-37		
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.090	0.160	0.249	0.359	0.489	0.638				
	Static Pressure (in. w.g.)	0.084	0.150	0.234	0.336	0.458	0.598				
	Flow Rate (cfm)	236	314	393	471	550	628				
	Sound (NC)	22	33	41	48	54	59				
	Throw (ft.)	9-13-24	12-17-28	15-22-31	17-24-34	20-26-37	23-28-40				
Length = 60 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.017	0.027	0.039	0.053	0.069	0.088	0.108	0.156	0.213
	Static Pressure (in. w.g.)		0.007	0.012	0.017	0.023	0.030	0.037	0.046	0.066	0.090
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	-	18	22	28	34
	Throw (ft.)		1-1-5	1-2-6	1-3-7	2-4-9	2-5-10	3-6-11	4-6-12	5-7-15	6-9-17
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.020	0.036	0.057	0.081	0.111	0.145	0.183	0.226	0.326	0.443
	Static Pressure (in. w.g.)	0.015	0.026	0.041	0.059	0.080	0.105	0.133	0.164	0.236	0.321
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	-	18	23	28	33	36	43	49
	Throw (ft.)	1-2-7	2-4-9	3-5-11	4-7-13	5-8-15	6-9-18	7-10-20	7-11-21	9-13-23	10-15-25
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.037	0.067	0.104	0.150	0.204	0.266	0.337	0.416	0.599	
	Static Pressure (in. w.g.)	0.032	0.057	0.088	0.127	0.173	0.226	0.287	0.354	0.509	
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	
	Sound (NC)	-	15	23	30	36	41	45	49	56	
	Throw (ft.)	3-5-10	5-7-14	6-9-17	7-10-20	8-12-22	9-14-23	10-15-25	11-17-26	14-20-28	
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.064	0.113	0.177	0.255	0.347	0.454	0.574			
	Static Pressure (in. w.g.)	0.058	0.103	0.162	0.233	0.317	0.414	0.524			
	Flow Rate (cfm)	236	314	393	471	550	628	707			
	Sound (NC)	15	26	34	41	47	52	56			
	Throw (ft.)	5-7-15	7-10-20	8-12-22	10-15-24	11-17-26	13-20-28	15-21-30			

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks “-” indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
P_{total} = P_{static} + P_{velocity}
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
- Blank area outside recommended operating range.
- Does not include effects of ceiling radiation damper (TBD3-FR).

PERFORMANCE DATA

TBD3 – Ice-Tong Pattern Controller, 2 Slot (continued)

Model TBD3100 1 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.026	0.046	0.071	0.102	0.139	0.182	0.231	0.285	0.410	0.558
	Static Pressure (in. w.g.)	0.020	0.036	0.056	0.080	0.109	0.142	0.180	0.222	0.320	0.436
	Flow Rate (cfm)	59	78	98	118	137	157	176	196	235	274
	Sound (NC)	-	-	-	17	23	28	32	36	43	48
	Throw (ft.)	5-9-18	8-12-22	10-15-25	12-18-27	14-20-30	16-22-32	18-24-34	19-25-35	22-27-39	24-30-42
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.050	0.088	0.138	0.199	0.271	0.353	0.447	0.552		
	Static Pressure (in. w.g.)	0.044	0.078	0.122	0.176	0.240	0.313	0.397	0.490		
	Flow Rate (cfm)	105	140	175	209	244	279	314	349		
	Sound (NC)	-	-	22	29	35	39	44	48		
	Throw (ft.)	10-16-26	14-21-30	17-24-33	21-26-37	23-28-39	24-30-42	26-32-45	27-33-47		
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.088	0.157	0.245	0.353	0.480	0.627				
	Static Pressure (in. w.g.)	0.083	0.147	0.229	0.330	0.449	0.587				
	Flow Rate (cfm)	164	218	273	327	382	436				
	Sound (NC)	-	24	32	39	45	50				
	Throw (ft.)	16-23-32	22-26-37	24-29-42	26-32-46	28-35-49	30-37-53				
Length = 48 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.023	0.036	0.052	0.070	0.092	0.116	0.144	0.207	0.282
	Static Pressure (in. w.g.)		0.013	0.020	0.029	0.040	0.052	0.066	0.081	0.117	0.160
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	15	20	24	30	36
	Throw (ft.)		1-2-8	1-3-10	2-5-12	3-6-13	4-8-15	5-9-17	6-10-19	8-12-23	9-13-26
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.023	0.040	0.063	0.091	0.123	0.161	0.204	0.252	0.362	0.493
	Static Pressure (in. w.g.)	0.017	0.030	0.047	0.068	0.093	0.121	0.153	0.189	0.273	0.371
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	-	-	20	25	30	34	40	46
	Throw (ft.)	2-4-10	3-7-14	5-9-17	7-10-21	8-12-24	9-14-26	10-15-28	11-17-30	14-21-32	16-24-35
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.037	0.066	0.103	0.148	0.201	0.263	0.333	0.411	0.592	
	Static Pressure (in. w.g.)	0.031	0.056	0.087	0.126	0.171	0.223	0.283	0.349	0.502	
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	
	Sound (NC)	-	-	17	24	29	34	39	42	49	
	Throw (ft.)	4-8-16	7-11-21	9-13-26	11-16-29	12-19-31	14-21-33	16-24-35	18-26-37	21-29-40	
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.057	0.102	0.160	0.230	0.313	0.409	0.517	0.639		
	Static Pressure (in. w.g.)	0.052	0.092	0.144	0.208	0.282	0.369	0.467	0.576		
	Flow Rate (cfm)	236	314	393	471	550	628	707	785		
	Sound (NC)	-	17	25	31	37	42	46	50		
	Throw (ft.)	8-12-23	10-15-28	13-19-31	15-23-34	18-26-37	21-28-40	23-30-42	26-31-44		
Length = 60 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.019	0.030	0.043	0.058	0.076	0.096	0.118	0.170	0.232
	Static Pressure (in. w.g.)		0.009	0.014	0.020	0.027	0.036	0.045	0.056	0.081	0.110
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	-	16	20	27	32
	Throw (ft.)		0-1-4	1-1-5	1-2-6	1-3-8	2-4-9	2-5-10	3-5-11	4-6-13	5-8-15
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.018	0.032	0.050	0.072	0.098	0.128	0.163	0.201	0.289	0.393
	Static Pressure (in. w.g.)	0.012	0.022	0.035	0.050	0.068	0.089	0.112	0.138	0.199	0.271
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	-	-	16	21	26	30	36	42
	Throw (ft.)	1-2-6	1-3-8	2-5-10	3-6-12	4-7-13	5-8-15	6-9-17	8-10-19	10-12-23	12-15-25
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.029	0.051	0.080	0.115	0.157	0.205	0.259	0.320	0.460	0.626
	Static Pressure (in. w.g.)	0.023	0.041	0.064	0.093	0.126	0.165	0.208	0.257	0.370	0.504
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	-	-	19	25	30	34	38	45	50
	Throw (ft.)	2-4-9	3-6-12	5-8-15	6-9-18	7-11-21	8-12-23	9-14-25	10-15-26	12-18-28	14-21-31
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.044	0.078	0.121	0.175	0.238	0.311	0.394	0.486		
	Static Pressure (in. w.g.)	0.038	0.068	0.106	0.152	0.208	0.271	0.343	0.424		
	Flow Rate (cfm)	236	314	393	471	550	628	707	785		
	Sound (NC)	-	-	20	27	32	37	42	45		
	Throw (ft.)	4-6-13	6-9-17	7-11-22	9-13-24	10-15-26	12-17-28	13-19-30	14-22-31		

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks "-" indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
P_{total} = P_{static} + P_{velocity}
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
- Blank area outside recommended operating range.
- Does not include effects of ceiling radiation damper (TBD3-FR).

PERFORMANCE DATA

TBD3 – Ice-Tong Pattern Controller, 3 Slot

Model TBD350 1/2 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.029	0.051	0.079	0.114	0.155	0.203	0.257	0.317	0.457	0.622
	Static Pressure (in. w.g.)	0.023	0.041	0.064	0.092	0.125	0.163	0.206	0.255	0.367	0.499
	Flow Rate (cfm)	59	78	98	118	137	157	176	196	235	274
	Sound (NC)	-	-	21	27	32	36	40	44	50	55
	Throw (ft.)	3-7-15	6-10-20	8-13-25	10-15-27	12-18-30	13-20-32	15-23-34	17-25-35	20-27-39	24-30-42
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.056	0.099	0.155	0.224	0.304	0.397	0.503	0.621		
	Static Pressure (in. w.g.)	0.050	0.089	0.140	0.201	0.274	0.358	0.452	0.559		
	Flow Rate (cfm)	105	140	175	209	244	279	314	349		
	Sound (NC)	-	23	31	37	42	46	50	54		
	Throw (ft.)	9-13-26	12-18-30	15-22-33	18-26-37	21-28-39	24-30-42	26-32-45	27-33-47		
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.107	0.190	0.296	0.427	0.581					
	Static Pressure (in. w.g.)	0.101	0.180	0.281	0.404	0.550					
	Flow Rate (cfm)	164	218	273	327	382					
	Sound (NC)	24	33	40	46	51					
	Throw (ft.)	14-21-32	19-26-37	23-29-42	26-32-46	28-35-49					
Length = 48 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.030	0.046	0.067	0.091	0.119	0.150	0.185	0.267	0.363
	Static Pressure (in. w.g.)		0.020	0.031	0.044	0.060	0.079	0.100	0.123	0.177	0.241
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	19	24	28	32	36	42	47
	Throw (ft.)		1-3-9	2-5-11	3-7-13	4-8-15	5-9-17	7-10-20	7-11-22	9-13-24	10-15-26
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)		0.045	0.071	0.102	0.139	0.182	0.230	0.284	0.409	0.557
	Static Pressure (in. w.g.)		0.035	0.055	0.080	0.109	0.142	0.180	0.222	0.319	0.434
	Flow Rate (cfm)		140	175	209	244	279	314	349	419	489
	Sound (NC)		-	19	25	30	35	39	42	48	53
	Throw (ft.)		4-8-16	6-10-19	8-12-23	9-14-25	10-16-26	12-17-28	13-19-30	16-23-32	18-25-35
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.041	0.073	0.114	0.163	0.223	0.291	0.368	0.454	0.654	
	Static Pressure (in. w.g.)	0.035	0.063	0.098	0.141	0.192	0.251	0.317	0.392	0.564	
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	
	Sound (NC)	-	19	26	32	37	42	46	49	55	
	Throw (ft.)	6-9-18	8-12-23	10-15-26	12-18-29	14-21-31	16-23-33	18-25-35	20-26-37	23-29-40	
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.066	0.117	0.182	0.263	0.357	0.467	0.591			
	Static Pressure (in. w.g.)	0.060	0.107	0.167	0.240	0.327	0.427	0.540			
	Flow Rate (cfm)	236	314	393	471	550	628	707			
	Sound (NC)	16	26	33	39	44	49	53			
	Throw (ft.)	9-13-24	12-17-28	15-22-31	17-24-34	20-26-37	23-28-40	24-30-42			
Length = 60 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.026	0.041	0.059	0.081	0.106	0.134	0.165	0.237	0.323
	Static Pressure (in. w.g.)		0.016	0.026	0.037	0.050	0.066	0.083	0.103	0.148	0.201
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	17	22	27	30	34	40	45
	Throw (ft.)		1-1-5	1-2-6	1-3-7	2-4-9	2-5-10	3-6-11	4-6-12	5-7-15	6-9-17
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)		0.038	0.059	0.085	0.115	0.151	0.191	0.235	0.339	0.461
	Static Pressure (in. w.g.)		0.028	0.043	0.062	0.085	0.111	0.140	0.173	0.249	0.339
	Flow Rate (cfm)		140	175	209	244	279	314	349	419	489
	Sound (NC)		-	16	22	27	32	36	39	45	50
	Throw (ft.)		2-4-9	3-5-11	4-7-13	5-8-15	6-9-18	7-10-20	7-11-21	9-13-23	10-15-25
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.032	0.057	0.088	0.127	0.173	0.226	0.286	0.353	0.509	
	Static Pressure (in. w.g.)	0.026	0.047	0.073	0.105	0.143	0.186	0.236	0.291	0.419	
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	
	Sound (NC)	-	15	22	28	34	38	42	45	51	
	Throw (ft.)	3-5-10	5-7-14	6-9-17	7-10-20	8-12-22	9-14-23	10-15-25	11-17-26	14-20-28	
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.049	0.087	0.135	0.195	0.265	0.346	0.438	0.541		
	Static Pressure (in. w.g.)	0.043	0.077	0.120	0.172	0.234	0.306	0.388	0.479		
	Flow Rate (cfm)	236	314	393	471	550	628	707	785		
	Sound (NC)	-	21	29	35	40	44	48	52		
	Throw (ft.)	5-7-15	7-10-20	8-12-22	10-15-24	11-17-26	13-20-28	15-21-30	16-22-31		

Performance Notes:

1. Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
2. Airflow is in cubic feet per minute [cfm].
3. NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
4. Blanks "-" indicate an NC level below 15.
5. All pressures are in inches of water column [in. w.g.].
6. Pressures not listed can be calculated using the following formula:
 $P_{total} = P_{static} + P_{velocity}$
7. Throw data is based on supply air and room air being at isothermal conditions.
8. Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
9. Blank area outside recommended operating range.
10. Does not include effects of ceiling radiation damper (TBD3-FR).

PERFORMANCE DATA

TBD3 – Ice-Tong Pattern Controller, 3 Slot (continued)

Model TBD375 3/4 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.019	0.033	0.052	0.075	0.102	0.133	0.168	0.207	0.299	0.406
	Static Pressure (in. w.g.)	0.013	0.023	0.036	0.052	0.071	0.093	0.117	0.145	0.209	0.284
	Flow Rate (cfm)	59	78	98	118	137	157	176	196	235	274
	Sound (NC)	-	-	-	16	22	26	31	35	41	47
	Throw (ft.)	2-4-13	3-8-17	5-11-22	8-13-26	10-15-30	11-17-32	13-19-34	14-22-35	17-26-39	20-30-42
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.041	0.073	0.114	0.164	0.224	0.292	0.370	0.457	0.657	
	Static Pressure (in. w.g.)	0.035	0.063	0.099	0.142	0.193	0.252	0.319	0.394	0.568	
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	
	Sound (NC)	-	17	25	32	38	43	47	51	58	
	Throw (ft.)	6-12-23	10-15-30	13-19-33	15-23-37	18-27-39	20-30-42	23-32-45	26-33-47	30-37-52	
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.080	0.142	0.221	0.318	0.434	0.566				
	Static Pressure (in. w.g.)	0.074	0.132	0.206	0.296	0.403	0.526				
	Flow Rate (cfm)	164	218	273	327	382	436				
	NC	20	30	39	45	51	56				
	Throw (ft.)	12-18-32	16-24-37	20-29-42	24-32-46	28-35-49	30-37-53				
Length = 48 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.014	0.022	0.031	0.043	0.056	0.070	0.087	0.125	0.170
	Static Pressure (in. w.g.)		0.004	0.006	0.009	0.012	0.016	0.020	0.024	0.035	0.048
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	-	-	17	24	29
	Throw (ft.)		1-2-7	1-3-9	2-4-11	2-5-13	3-7-15	4-8-16	5-9-18	7-11-22	9-13-26
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)		0.029	0.045	0.064	0.087	0.114	0.144	0.178	0.257	0.349
	Static Pressure (in. w.g.)		0.019	0.029	0.042	0.057	0.074	0.094	0.116	0.167	0.227
	Flow Rate (cfm)		140	175	209	244	279	314	349	419	489
	Sound (NC)		-	-	-	18	23	28	32	38	44
	Throw (ft.)		3-6-13	4-8-16	6-10-19	8-11-23	9-13-26	10-15-28	11-16-30	13-19-32	15-23-35
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.029	0.052	0.081	0.116	0.158	0.206	0.261	0.323	0.465	0.632
	Static Pressure (in. w.g.)	0.023	0.042	0.065	0.094	0.128	0.167	0.211	0.260	0.375	0.510
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	-	18	25	31	36	40	44	50	56
	Throw (ft.)	3-8-15	6-10-20	8-13-25	10-15-29	12-18-31	14-20-33	15-23-35	17-25-37	20-29-40	24-31-44
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.049	0.087	0.135	0.195	0.265	0.346	0.438	0.541		
	Static Pressure (in. w.g.)	0.043	0.077	0.120	0.172	0.235	0.306	0.388	0.479		
	Flow Rate (cfm)	236	314	393	471	550	628	707	785		
	Sound (NC)	-	20	29	35	41	46	50	54		
	Throw (ft.)	9-13-24	12-17-28	15-22-31	17-24-34	20-26-37	23-28-40	24-30-42	26-31-44		
Length = 60 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.011	0.017	0.024	0.033	0.043	0.054	0.066	0.096	0.130
	Static Pressure (in. w.g.)		0.001	0.001	0.001	0.002	0.003	0.003	0.004	0.006	0.008
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	-	-	-	18	24
	Throw (ft.)		0-1-3	1-1-5	1-2-6	1-2-7	1-3-8	2-4-9	2-5-10	3-6-12	4-7-14
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)		0.021	0.034	0.048	0.066	0.086	0.109	0.134	0.193	0.263
	Static Pressure (in. w.g.)		0.012	0.018	0.026	0.035	0.046	0.058	0.072	0.104	0.141
	Flow Rate (cfm)		140	175	209	244	279	314	349	419	489
	Sound (NC)		-	-	-	-	18	22	26	33	38
	Throw (ft.)		1-3-7	2-4-9	3-5-11	3-6-13	5-7-15	5-8-16	6-9-18	7-11-22	9-13-25
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.021	0.038	0.060	0.086	0.117	0.153	0.193	0.239	0.344	0.468
	Static Pressure (in. w.g.)	0.016	0.028	0.044	0.063	0.086	0.113	0.143	0.176	0.254	0.345
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	-	-	19	24	29	34	38	44	50
	Throw (ft.)	2-3-9	3-6-11	4-7-14	6-9-17	7-10-20	8-11-23	9-13-25	9-14-26	11-17-28	13-20-31
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.035	0.063	0.098	0.141	0.193	0.251	0.318	0.393	0.566	
	Static Pressure (in. w.g.)	0.030	0.053	0.083	0.119	0.162	0.212	0.268	0.331	0.476	
	Flow Rate (cfm)	236	314	393	471	550	628	707	785	942	
	Sound (NC)	-	-	22	29	35	40	44	48	54	
	Throw (ft.)	3-6-12	5-8-16	7-10-21	8-12-24	10-14-26	11-16-28	12-18-30	14-21-31	16-24-34	

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks "-" indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
P_{total} = P_{static} + P_{velocity}
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
- Blank area outside recommended operating range.
- Does not include effects of ceiling radiation damper (TBD3-FR).

PERFORMANCE DATA

TBD3 – Ice-Tong Pattern Controller, 3 Slot (continued)

Model TBD3100 1 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.017	0.030	0.047	0.068	0.092	0.120	0.152	0.188	0.271	0.369
	Static Pressure (in. w.g.)	0.011	0.020	0.031	0.045	0.062	0.080	0.102	0.126	0.181	0.246
	Flow Rate (cfm)	59	78	98	118	137	157	176	196	235	274
	Sound (NC)	-	-	-	-	15	20	24	28	35	41
	Throw (ft.)	1-3-11	2-5-15	4-9-19	5-11-23	7-13-27	10-15-31	11-17-34	13-19-35	15-23-39	18-27-42
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.031	0.055	0.086	0.124	0.168	0.220	0.278	0.343	0.495	
	Static Pressure (in. w.g.)	0.025	0.045	0.070	0.101	0.138	0.180	0.228	0.281	0.405	
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	
	Sound (NC)	-	-	-	20	26	31	35	39	46	
	Throw (ft.)	4-10-20	8-14-27	11-17-33	14-20-37	16-24-39	18-27-42	20-31-45	23-33-47	27-37-52	
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.052	0.093	0.145	0.209	0.284	0.371	0.470	0.580		
	Static Pressure (in. w.g.)	0.047	0.083	0.129	0.186	0.254	0.331	0.419	0.518		
	Flow Rate (cfm)	164	218	273	327	382	436	491	545		
	Sound (NC)	-	-	23	30	35	40	45	49		
	Throw (ft.)	11-16-32	14-21-37	18-27-42	21-32-46	25-35-49	28-37-53	32-40-56	34-42-59		
Length = 48 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.016	0.026	0.037	0.050	0.065	0.083	0.102	0.147	0.200
	Static Pressure (in. w.g.)		0.006	0.010	0.014	0.019	0.025	0.032	0.040	0.057	0.078
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	-	-	17	24	30
	Throw (ft.)		1-1-5	1-2-8	1-3-10	2-4-11	2-5-13	3-6-14	3-8-16	5-10-19	7-11-22
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)		0.027	0.042	0.061	0.082	0.108	0.136	0.168	0.242	0.330
	Static Pressure (in. w.g.)		0.017	0.026	0.038	0.052	0.068	0.086	0.106	0.153	0.208
	Flow Rate (cfm)		140	175	209	244	279	314	349	419	489
	Sound (NC)		-	-	-	-	18	22	26	33	39
	Throw (ft.)		2-4-11	3-6-14	4-9-17	5-10-20	7-11-23	9-13-26	9-14-28	11-17-32	13-20-35
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.024	0.042	0.066	0.095	0.129	0.168	0.213	0.263	0.378	0.515
	Static Pressure (in. w.g.)	0.018	0.032	0.050	0.072	0.098	0.128	0.162	0.200	0.288	0.392
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	-	-	16	21	26	30	34	41	47
	Throw (ft.)	2-5-13	4-9-18	6-11-22	9-13-27	10-16-31	12-18-33	13-20-35	15-22-37	18-27-40	21-31-44
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.035	0.063	0.098	0.141	0.192	0.251	0.318	0.392	0.565	
	Static Pressure (in. w.g.)	0.030	0.053	0.083	0.119	0.162	0.211	0.267	0.330	0.475	
	Flow Rate (cfm)	236	314	393	471	550	628	707	785	942	
	Sound (NC)	-	-	16	23	28	33	38	42	48	
	Throw (ft.)	5-10-19	9-13-26	11-16-31	13-19-34	15-22-37	17-26-40	19-29-42	21-31-44	26-34-49	
Length = 60 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.014	0.022	0.031	0.042	0.055	0.070	0.086	0.124	0.169
	Static Pressure (in. w.g.)		0.004	0.006	0.009	0.012	0.015	0.019	0.024	0.034	0.047
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	-	-	-	21	27
	Throw (ft.)		0-1-2	0-1-3	1-1-5	1-2-6	1-2-7	1-3-8	1-3-9	2-5-11	3-6-13
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)		0.022	0.034	0.049	0.067	0.088	0.111	0.137	0.198	0.269
	Static Pressure (in. w.g.)		0.012	0.019	0.027	0.037	0.048	0.061	0.075	0.108	0.147
	Flow Rate (cfm)		140	175	209	244	279	314	349	419	489
	Sound (NC)		-	-	-	-	-	19	23	29	35
	Throw (ft.)		1-2-6	1-3-8	2-4-10	2-5-11	3-6-13	4-7-14	5-8-16	6-10-19	7-11-22
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.019	0.033	0.052	0.075	0.102	0.134	0.169	0.209	0.301	0.409
	Static Pressure (in. w.g.)	0.013	0.023	0.037	0.053	0.072	0.094	0.119	0.146	0.211	0.287
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	-	-	-	17	22	26	30	37	43
	Throw (ft.)	1-2-7	2-4-10	3-6-12	4-7-15	6-9-17	7-10-20	7-11-22	8-12-25	10-15-28	12-17-31
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.028	0.049	0.076	0.110	0.150	0.196	0.248	0.306	0.440	0.599
	Static Pressure (in. w.g.)	0.022	0.039	0.061	0.088	0.119	0.156	0.197	0.243	0.350	0.477
	Flow Rate (cfm)	236	314	393	471	550	628	707	785	942	1099
	Sound (NC)	-	-	-	18	24	29	33	37	44	50
	Throw (ft.)	2-5-11	4-7-14	6-9-18	7-11-22	8-13-25	10-14-28	11-16-30	12-18-31	14-22-34	17-25-37

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks “-” indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
 $P_{total} = P_{static} + P_{velocity}$
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
- Blank area outside recommended operating range.
- Does not include effects of ceiling radiation damper (TBD3-FR).

PERFORMANCE DATA

TBD3 – Ice-Tong Pattern Controller, 4 Slot

Model TBD350 1/2 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.) Static Pressure (in. w.g.) Flow Rate (cfm) Sound (NC) Throw (ft.)		0.039 0.029 78 - 4-9-18	0.061 0.046 98 17 6-11-23	0.088 0.066 118 23 9-14-27	0.120 0.090 137 28 11-16-30	0.157 0.117 157 32 12-18-32	0.199 0.148 176 36 14-20-34	0.245 0.183 196 40 15-23-35	0.353 0.263 235 46 18-27-39	0.480 0.358 274 51 21-30-42
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.) Static Pressure (in. w.g.) Flow Rate (cfm) Sound (NC) Throw (ft.)	0.039 0.033 105 - 7-12-24	0.069 0.059 140 18 11-16-30	0.108 0.093 175 25 13-20-33	0.156 0.133 209 31 16-24-37	0.212 0.182 244 37 19-28-39	0.277 0.237 279 41 21-30-42	0.351 0.300 314 45 24-32-45	0.433 0.371 349 48 27-33-47	0.624 0.534 419 54 30-37-52	
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.) Static Pressure (in. w.g.) Flow Rate (cfm) NC Throw (ft.)	0.069 0.064 164 17 13-19-32	0.124 0.114 218 27 17-25-37	0.193 0.177 273 34 21-29-42	0.278 0.256 327 40 25-32-46	0.378 0.348 382 45 28-35-49	0.494 0.454 436 50 30-37-53	0.625 0.575 491 53 32-40-56			
Length = 48 in. Inlet = 6 in.	Total Pressure (in. w.g.) Static Pressure (in. w.g.) Flow Rate (cfm) Sound (NC) Throw (ft.)		0.026 0.016 78 - 1-2-8	0.040 0.024 98 - 1-3-10	0.058 0.035 118 17 2-5-12	0.078 0.048 137 22 3-6-13	0.102 0.063 157 26 4-8-15	0.130 0.079 176 30 5-9-17	0.160 0.098 196 34 6-10-19	0.230 0.141 235 40 8-12-23	0.314 0.192 274 45 9-13-26
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.) Static Pressure (in. w.g.) Flow Rate (cfm) Sound (NC) Throw (ft.)		0.036 0.026 140 - 3-7-14	0.056 0.040 175 16 5-9-17	0.081 0.058 209 22 7-10-21	0.110 0.079 244 27 8-12-24	0.143 0.104 279 31 9-14-26	0.182 0.131 314 35 10-15-28	0.224 0.162 349 39 11-17-30	0.323 0.233 419 45 14-21-32	0.439 0.317 489 50 16-24-35
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.) Static Pressure (in. w.g.) Flow Rate (cfm) Sound (NC) Throw (ft.)	0.030 0.024 164 - 4-8-16	0.053 0.043 218 - 7-11-21	0.083 0.067 273 21 9-13-26	0.119 0.097 327 27 11-16-29	0.162 0.131 382 33 12-19-31	0.212 0.172 436 37 14-21-33	0.268 0.217 491 41 16-24-35	0.331 0.268 545 44 18-26-37	0.476 0.386 654 50 21-29-40	0.648 0.526 763 55 25-31-44
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.) Static Pressure (in. w.g.) Flow Rate (cfm) Sound (NC) Throw (ft.)	0.045 0.039 236 - 8-12-23	0.080 0.070 314 20 10-15-28	0.125 0.109 393 28 13-19-31	0.180 0.157 471 34 15-23-34	0.244 0.214 550 39 18-26-37	0.319 0.279 628 43 21-28-40	0.404 0.353 707 47 23-30-42	0.499 0.436 785 50 26-31-44		
Length = 60 in. Inlet = 6 in.	Total Pressure (in. w.g.) Static Pressure (in. w.g.) Flow Rate (cfm) Sound (NC) Throw (ft.)		0.023 0.013 78 - 0-1-4	0.037 0.021 98 - 1-1-5	0.053 0.030 118 15 1-2-6	0.072 0.041 137 20 1-3-8	0.094 0.054 157 25 2-4-9	0.119 0.068 176 29 2-5-10	0.146 0.084 196 32 3-5-11	0.211 0.121 235 38 4-6-13	0.287 0.165 274 43 5-8-15
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.) Static Pressure (in. w.g.) Flow Rate (cfm) Sound (NC) Throw (ft.)		0.031 0.021 140 - 1-3-8	0.048 0.033 175 - 2-5-10	0.069 0.047 209 19 3-6-12	0.094 0.064 244 25 4-7-13	0.123 0.083 279 29 5-8-15	0.156 0.106 314 33 6-9-17	0.193 0.130 349 36 6-10-19	0.278 0.188 419 42 8-12-23	0.378 0.256 489 47 9-13-25
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.) Static Pressure (in. w.g.) Flow Rate (cfm) Sound (NC) Throw (ft.)		0.043 0.033 218 - 3-6-12	0.067 0.051 273 18 5-8-15	0.096 0.074 327 24 6-9-18	0.131 0.101 382 29 7-11-21	0.172 0.132 436 34 8-12-23	0.217 0.167 491 38 9-14-25	0.268 0.206 545 41 10-15-26	0.386 0.296 654 47 12-18-28	0.525 0.403 763 52 14-21-31
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.) Static Pressure (in. w.g.) Flow Rate (cfm) Sound (NC) Throw (ft.)	0.035 0.029 236 - 4-6-13	0.061 0.051 314 16 6-9-17	0.096 0.080 393 24 7-11-22	0.138 0.116 471 30 9-13-24	0.188 0.158 550 35 10-15-26	0.246 0.206 628 39 12-17-28	0.311 0.261 707 43 13-19-30	0.384 0.322 785 47 14-22-31	0.553 0.463 942 53 17-24-34	

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks "-" indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
 $P_{total} = P_{static} + P_{velocity}$
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
- Blank area outside recommended operating range.
- Does not include effects of ceiling radiation damper (TBD3-FR).

PERFORMANCE DATA

TBD3 – Ice-Tong Pattern Controller, 4 Slot (continued)

Model TBD375 3/4 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.023	0.036	0.052	0.070	0.092	0.116	0.143	0.206	0.281
	Static Pressure (in. w.g.)		0.013	0.020	0.029	0.040	0.052	0.066	0.081	0.117	0.159
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	19	23	27	34	40
	Throw (ft.)		2-5-15	4-9-19	5-11-23	7-13-27	10-15-31	11-17-34	13-19-35	15-23-39	18-27-42
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.027	0.049	0.076	0.110	0.150	0.195	0.247	0.305	0.440	0.598
	Static Pressure (in. w.g.)	0.022	0.039	0.061	0.087	0.119	0.155	0.197	0.243	0.350	0.476
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	17	24	29	34	39	43	49	55
	Throw (ft.)	4-10-20	8-14-27	11-17-33	14-20-37	16-24-39	18-27-42	20-31-45	23-33-47	27-37-52	32-39-56
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.052	0.092	0.144	0.207	0.281	0.367	0.465	0.574		
	Static Pressure (in. w.g.)	0.046	0.082	0.128	0.184	0.251	0.328	0.415	0.512		
	Flow Rate (cfm)	164	218	273	327	382	436	491	545		
	Sound (NC)	-	22	30	37	42	47	52	55		
	Throw (ft.)	11-16-32	14-21-37	18-27-42	21-32-46	25-35-49	28-37-53	32-40-56	34-42-59		
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)		0.020	0.031	0.045	0.061	0.079	0.100	0.124	0.178	0.243
	Static Pressure (in. w.g.)		0.010	0.015	0.022	0.030	0.039	0.050	0.062	0.089	0.121
	Flow Rate (cfm)		140	175	209	244	279	314	349	419	489
	Sound (NC)		-	-	-	-	16	20	24	31	37
	Throw (ft.)		2-4-11	3-6-14	4-9-17	5-10-20	7-11-23	9-13-26	9-14-28	11-17-32	13-20-35
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.020	0.035	0.055	0.079	0.107	0.140	0.177	0.219	0.315	0.429
	Static Pressure (in. w.g.)	0.014	0.025	0.039	0.056	0.077	0.100	0.127	0.157	0.226	0.307
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	-	-	17	23	28	32	36	43	48
	Throw (ft.)	2-5-13	4-9-18	6-11-22	9-13-27	10-16-31	12-18-33	13-20-35	15-22-37	18-27-40	21-31-44
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.032	0.057	0.090	0.129	0.176	0.230	0.291	0.359	0.517	
	Static Pressure (in. w.g.)	0.027	0.047	0.074	0.107	0.145	0.190	0.240	0.297	0.427	
	Flow Rate (cfm)	236	314	393	471	550	628	707	785	942	
	Sound (NC)	-	-	20	27	33	38	42	46	53	
	Throw (ft.)	5-10-19	9-13-26	11-16-31	13-19-34	15-22-37	17-26-40	19-29-42	21-31-44	26-34-49	
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)		0.015	0.024	0.034	0.046	0.060	0.076	0.094	0.136	0.184
	Static Pressure (in. w.g.)		0.005	0.008	0.011	0.016	0.020	0.026	0.032	0.046	0.062
	Flow Rate (cfm)		140	175	209	244	279	314	349	419	489
	Sound (NC)		-	-	-	-	-	-	19	25	31
	Throw (ft.)		1-2-6	1-3-8	2-4-10	2-5-11	3-6-13	4-7-14	5-8-16	6-10-19	7-11-22
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)		0.026	0.041	0.059	0.080	0.105	0.133	0.164	0.236	0.321
	Static Pressure (in. w.g.)		0.016	0.025	0.037	0.050	0.065	0.082	0.102	0.146	0.199
	Flow Rate (cfm)		218	273	327	382	436	491	545	654	763
	Sound (NC)		-	-	-	17	22	26	30	37	42
	Throw (ft.)		2-4-10	3-6-12	4-7-15	6-9-17	7-10-20	7-11-22	8-12-25	10-15-28	12-17-31
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.024	0.042	0.066	0.095	0.130	0.169	0.214	0.265	0.381	0.518
	Static Pressure (in. w.g.)	0.018	0.032	0.051	0.073	0.099	0.129	0.164	0.202	0.291	0.396
	Flow Rate (cfm)	236	314	393	471	550	628	707	785	942	1099
	Sound (NC)	-	-	-	21	27	31	36	40	46	52
	Throw (ft.)	2-5-11	4-7-14	6-9-18	7-11-22	8-13-25	10-14-28	11-16-30	12-18-31	14-22-34	17-25-37

Performance Notes:

1. Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
2. Airflow is in cubic feet per minute [cfm].
3. NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
4. Blanks “-” indicate an NC level below 15.
5. All pressures are in inches of water column [in. w.g.].
6. Pressures not listed can be calculated using the following formula:
P_{total} = P_{static} + P_{velocity}
7. Throw data is based on supply air and room air being at isothermal conditions.
8. Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
9. Blank area outside recommended operating range.
10. Does not include effects of ceiling radiation damper (TBD3-FR).

PERFORMANCE DATA

TBD3 – Ice-Tong Pattern Controller, 4 Slot (continued)

Model TBD3100 1 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.023	0.036	0.052	0.070	0.092	0.116	0.144	0.207	0.282
	Static Pressure (in. w.g.)		0.013	0.020	0.029	0.040	0.052	0.066	0.081	0.117	0.160
Length = 24 in. Inlet = 8 in.	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	15	20	24	30	36
Length = 24 in. Inlet = 10 in.	Throw (ft.)		2-4-13	3-6-17	4-8-20	5-11-24	7-13-27	8-15-30	10-17-34	13-20-39	16-24-42
	Static Pressure (in. w.g.)	0.023	0.040	0.063	0.091	0.123	0.161	0.204	0.252	0.362	0.493
Length = 48 in. Inlet = 8 in.	Flow Rate (cfm)	0.017	0.030	0.047	0.068	0.093	0.121	0.153	0.189	0.273	0.371
	Sound (NC)	105	140	175	209	244	279	314	349	419	489
Length = 48 in. Inlet = 10 in.	Throw (ft.)	-	-	-	-	20	25	30	34	40	46
	Static Pressure (in. w.g.)	0.037	0.066	0.103	0.148	0.201	0.263	0.333	0.411	0.592	
Length = 48 in. Inlet = 12 in.	Flow Rate (cfm)	0.031	0.056	0.087	0.126	0.171	0.223	0.283	0.349	0.502	
	Sound (NC)	164	218	273	327	382	436	491	545	654	
Length = 60 in. Inlet = 8 in.	Throw (ft.)	-	-	17	24	29	34	39	42	49	
	Static Pressure (in. w.g.)	7-14-28	12-19-37	16-23-42	19-28-46	22-33-49	25-37-53	28-40-56	31-42-59	37-46-65	
Length = 60 in. Inlet = 10 in.	Flow Rate (cfm)		0.021	0.032	0.047	0.064	0.083	0.105	0.130	0.187	0.254
	Sound (NC)		0.011	0.017	0.024	0.033	0.043	0.055	0.067	0.097	0.132
Length = 60 in. Inlet = 12 in.	Throw (ft.)		140	175	209	244	279	314	349	419	489
	Static Pressure (in. w.g.)		-	-	-	-	-	18	22	28	34
Length = 84 in. Inlet = 8 in.	Flow Rate (cfm)		1-3-10	2-4-12	3-6-15	3-8-17	5-10-20	6-11-22	7-12-25	10-15-30	12-17-35
	Sound (NC)		0.018	0.031	0.049	0.071	0.096	0.125	0.159	0.196	0.282
Length = 84 in. Inlet = 10 in.	Throw (ft.)		0.012	0.021	0.033	0.048	0.065	0.085	0.108	0.134	0.192
	Static Pressure (in. w.g.)		164	218	273	327	382	436	491	545	654
Length = 84 in. Inlet = 12 in.	Flow Rate (cfm)		-	-	-	16	21	25	29	36	42
	Sound (NC)		2-4-12	3-6-16	4-10-19	6-12-23	8-14-27	10-16-31	12-18-35	13-19-37	16-23-40
Length = 108 in. Inlet = 8 in.	Throw (ft.)		0.026	0.046	0.071	0.103	0.140	0.182	0.231	0.285	0.410
	Static Pressure (in. w.g.)		0.020	0.036	0.056	0.080	0.109	0.143	0.180	0.223	0.321
Length = 108 in. Inlet = 10 in.	Flow Rate (cfm)		236	314	393	471	550	628	707	785	942
	Sound (NC)		-	-	-	17	23	28	32	36	43
Length = 108 in. Inlet = 12 in.	Throw (ft.)		3-7-17	6-11-22	9-14-28	11-17-34	13-20-37	15-22-40	17-25-42	19-28-44	22-34-49
	Static Pressure (in. w.g.)		0.017	0.027	0.039	0.053	0.069	0.087	0.108	0.155	0.211
Length = 132 in. Inlet = 8 in.	Flow Rate (cfm)		0.007	0.011	0.016	0.022	0.029	0.037	0.045	0.065	0.089
	Sound (NC)		140	175	209	244	279	314	349	419	489
Length = 132 in. Inlet = 10 in.	Throw (ft.)		-	-	-	-	-	-	18	25	31
	Static Pressure (in. w.g.)		1-1-5	1-2-7	1-3-8	2-3-10	2-5-11	3-6-13	3-7-14	5-8-17	6-10-20
Length = 132 in. Inlet = 12 in.	Flow Rate (cfm)		0.025	0.040	0.057	0.078	0.101	0.128	0.158	0.228	0.310
	Sound (NC)		0.015	0.024	0.035	0.047	0.061	0.078	0.096	0.138	0.188
Length = 156 in. Inlet = 8 in.	Throw (ft.)		218	273	327	382	436	491	545	654	763
	Static Pressure (in. w.g.)		-	-	-	-	17	21	25	32	38
Length = 156 in. Inlet = 10 in.	Flow Rate (cfm)		1-3-9	2-4-11	3-6-13	4-8-15	5-9-17	6-10-20	7-11-22	9-13-26	10-15-30
	Sound (NC)		0.020	0.036	0.056	0.081	0.111	0.144	0.183	0.226	0.325
Length = 156 in. Inlet = 12 in.	Throw (ft.)		0.015	0.026	0.041	0.059	0.080	0.105	0.132	0.163	0.235
	Static Pressure (in. w.g.)		236	314	393	471	550	628	707	785	942
Length = 180 in. Inlet = 8 in.	Flow Rate (cfm)		-	-	-	18	23	28	32	38	44
	Sound (NC)		1-3-9	3-6-13	4-8-16	6-9-19	7-11-22	8-13-25	9-14-28	10-16-31	13-19-34
Length = 180 in. Inlet = 10 in.	Throw (ft.)										
	Static Pressure (in. w.g.)										
Length = 180 in. Inlet = 12 in.	Flow Rate (cfm)										
	Sound (NC)										
Length = 216 in. Inlet = 8 in.	Throw (ft.)										
	Static Pressure (in. w.g.)										
Length = 216 in. Inlet = 10 in.	Flow Rate (cfm)										
	Sound (NC)										
Length = 216 in. Inlet = 12 in.	Throw (ft.)										
	Static Pressure (in. w.g.)										

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks "-" indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
P_{total} = P_{static} + P_{velocity}
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
- Blank area outside recommended operating range.
- Does not include effects of ceiling radiation damper (TBD3-FR).

PERFORMANCE DATA

TBD8 – Ice-Tong Pattern Controller, Sloped Plenum, 1 Slot

Model TBD850 1/2 in. Slot Width

Flow Rate (cfm)			50	60	70	80	90	100	120	140	160
Throw (ft)		H	2-4-8	3-5-9	3-6-10	4-7-11	5-8-11	6-8-12	7-9-13	8-10-14	9-11-15
		V	1-2-6	2-4-7	2-4-8	3-5-8	3-6-9	4-6-9	5-7-10	6-8-11	7-8-11
Normal Length	Spread (ft)	H	6-12	7-13	5-9-15	6-10-16	7-12-17	9-12-18	10-13-19	12-15-21	13-16-22
		V	8	5-9	5-11	7-11	8-12	5-8-12	7-9-13	8-11-15	9-11-15
48 in. 5 in. Round	Total Pressure (in. w.g.)	H	.045	.060	.080	.110	.135	.170	.245	.330	.435
		V	.035	.047	.062	.086	.105	.133	.191	.258	.340
	Sound (NC)	H	-	-	18	22	25	28	33	37	40
		V	-	-	-	18	21	24	29	33	36
60 in. 6 in. Round	Total Pressure (in. w.g.)	H	.027	.041	.054	.068	.088	.109	.156	.214	.279
		V	.020	.031	.041	.051	.066	.082	.117	.158	.209
	Sound (NC)	H	-	-	-	18	21	24	29	33	36
		V	-	-	-	-	16	19	24	28	31

Model TBD875 3/4 in. Slot Width

Flow Rate (cfm)			60	80	100	120	140	160	180	200	220
Throw (ft)		H	3-4-9	4-6-10	5-7-11	6-9-12	7-10-14	8-10-15	9-11-15	9-11-16	10-12-17
		V	1-3-6	3-4-7	3-5-8	4-6-9	5-7-9	5-7-10	6-7-10	6-8-11	7-8-11
Normal Length	Spread (ft)	H	4-6-13	6-9-15	7-10-16	9-13-18	10-15-21	12-15-22	13-16-23	14-17-24	15-18-25
		V	8	5-9	7-11	5-8-12	7-9-12	7-9-13	8-9-13	8-11-15	9-11-15
48 in. 6 in. Round	Total Pressure (in. w.g.)	H	.042	.070	.112	.161	.217	.287	.364	.441	.553
		V	.031	.051	.082	.117	.158	.209	.265	.321	.403
	Sound (NC)	H	-	19	25	30	34	37	40	43	46
		V	-	13	19	24	28	31	34	37	40
60 in. 7 in. Round	Total Pressure (in. w.g.)	H	.025	.049	.074	.107	.148	.197	.246	.303	.369
		V	.018	.036	.054	.078	.108	.144	.180	.222	.280
	Sound (NC)	H	-	-	19	24	28	31	34	37	40
		V	-	-	-	19	23	26	29	32	35

Model TBD8100 1 in. Slot Width

Flow Rate (cfm)			60	80	100	120	140	160	180	200	220
Throw (ft)		H	2-4-8	3-5-10	4-7-11	5-8-12	6-9-13	7-10-14	8-10-15	9-11-16	10-12-17
		V	1-2-4	2-3-5	2-3-6	3-4-6	3-5-7	3-5-7	4-5-8	4-6-8	5-6-9
Normal Length	Spread (ft)	H	6-12	7-15	6-10-16	7-12-18	9-13-19	10-15-21	12-15-22	13-16-24	15-18-25
		V	5	7	8	5-8	7-9	7-9	5-7-11	5-8-11	7-8-12
48 in. 7 in. Round	Total Pressure (in. w.g.)	H	.028	.055	.083	.120	.166	.221	.276	.340	.413
		V	.019	.038	.057	.082	.113	.151	.189	.233	.284
	Sound (NC)	H	-	15	21	26	30	33	36	39	42
		V	-	-	15	20	24	27	30	33	36
60 in. 8 in. Round	Total Pressure (in. w.g.)	H	.020	.031	.051	.072	.102	.133	.163	.204	.255
		V	.014	.021	.035	.048	.069	.090	.110	.138	.173
	Sound (NC)	H	-	-	16	21	25	28	31	34	37
		V	-	-	-	-	18	21	24	27	30

Table of Velocity Pressures, in. w.g.

cfm	50	60	70	80	90	100	120	140	160	180	200	220
5 in.	0.008	0.012	0.016	0.021	0.027	0.034	0.048	0.066	0.086	0.109	0.134	0.162
6 in.	0.004	0.006	0.008	0.010	0.013	0.016	0.023	0.032	0.041	0.052	0.065	0.078
7 in.	0.002	0.003	0.004	0.006	0.007	0.009	0.013	0.017	0.022	0.028	0.035	0.042
8 in.	0.001	0.002	0.003	0.003	0.004	0.005	0.007	0.010	0.013	0.017	0.020	0.025

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks "-" indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula: Ptotal = Pstatic + Pvelocity
- Throw data is based on supply air and room air being at isothermal conditions.
- The throw, horizontal (H) and vertical (V), is the distance to terminal velocities (VT) of 150, 100 and 50 fpm. Spread is the maximum width of the jet as defined by the above terminal velocities.

PERFORMANCE DATA

TBD8 – Ice-Tong Pattern Controller, Sloped Plenum, 2 Slot

Model TBD850 1/2 in. Slot Width

Flow Rate (cfm)			100	130	160	190	220	250	280	310	340
Throw (ft)		H	4-6-11	5-7-12	6-9-14	7-10-15	8-11-16	9-12-17	10-13-18	11-13-19	11-14-20
		V	2-3-5	2-4-6	3-4-7	3-5-7	4-6-8	4-6-8	5-6-9	5-7-9	6-7-10
Normal Length	Spread (ft)	H	6-9-16	7-10-18	9-13-21	10-15-22	12-16-24	13-18-25	15-19-27	16-19-28	16-21-30
		V	3-4-6	3-5-8	4-5-9	4-6-9	5-8-10	5-8-10	6-8-12	6-9-12	8-9-13
48 in.	Total Pressure (in. w.g.)		.050	.084	.131	.184	.247	.315	.396	.487	.587
	Sound (NC)		-	17	25	30	35	39	43	46	49
60 in.	Total Pressure (in. w.g.)		.032	.053	.077	.112	.147	.193	.242	.294	.354
	Sound (NC)		-	-	21	24	28	32	36	39	41

Model TBD875 3/4 in. Slot Width

Flow Rate (cfm)			130	160	190	220	250	280	310	340	370
Throw (ft)		H	5-7-12	6-9-13	7-10-14	8-11-15	9-11-16	10-12-17	10-13-18	11-13-19	11-14-20
		V	2-4-6	3-4-6	4-5-7	4-5-7	5-6-8	5-6-8	5-6-9	5-6-9	6-7-10
Normal Length	Spread (ft)	H	7-10-18	9-13-19	10-15-21	12-16-22	13-16-24	15-18-25	15-19-27	16-19-28	16-21-30
		V	3-5-8	4-5-8	5-6-9	5-6-9	6-8-10	6-8-10	6-8-12	6-8-12	8-9-13
48 in.	Total Pressure (in. w.g.)		.059	.086	.126	.165	.216	.271	.330	.397	.472
	Sound (NC)		-	22	28	30	34	38	41	43	46
60 in.	Total Pressure (in. w.g.)		.045	.066	.091	.146	.161	.202	.247	.297	.353
	Sound (NC)		-	-	24	28	32	36	39	42	44

Model TBD8100 1 in. Slot Width

Flow Rate (cfm)			160	190	220	250	280	310	340	370	400
Throw (ft)		H	5-8-12	6-9-14	7-10-15	8-11-16	9-12-18	10-12-17	11-13-18	11-13-19	11-14-20
		V	2-3-6	3-4-7	3-5-7	3-5-7	4-6-8	4-6-8	5-6-8	5-6-9	5-6-9
Normal Length	Spread (ft)	H	7-12-18	9-13-21	10-15-22	12-16-24	13-18-25	15-18-27	16-19-27	16-19-28	16-21-30
		V	3-4-8	4-5-9	4-6-9	4-6-9	5-8-10	5-8-10	6-8-10	6-8-12	6-8-12
48 in.	Total Pressure (in. w.g.)		.060	.087	.114	.150	.188	.228	.275	.326	.381
	Sound (NC)		-	23	25	29	33	35	37	39	42
60 in.	Total Pressure (in. w.g.)		.040	.055	.076	.098	.122	.149	.180	.214	.250
	Sound (NC)		-	19	22	25	28	30	32	34	37

Performance Notes:

1. Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
2. Airflow is in cubic feet per minute [cfm].
3. NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
4. Blanks "-" indicate an NC level below 15.
5. All pressures are in inches of water column [in. w.g.].
6. Pressures not listed can be calculated using the following formula: Ptotal = Pstatic + Pvelocity
7. Throw data is based on supply air and room air being at isothermal conditions.
8. The throw, horizontal (H) and vertical (V), is the distance to terminal velocities (VT) of 150, 100 and 50 fpm. Spread is the maximum width of the jet as defined by the above terminal velocities.

PERFORMANCE DATA

TBD4 – Blade Pattern Controller, 1 Slot

Model TBD475 3/4 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.030	0.068	0.121	0.190	0.273	0.372	0.486	0.615	0.759	
	Static Pressure (in. w.g.)	0.028	0.063	0.111	0.174	0.251	0.341	0.446	0.564	0.697	
	Flow Rate (cfm)	39	59	78	98	118	137	157	176	196	
	Sound (NC)	-	18	28	35	41	46	50	54	57	
	Throw (ft.)	2-4-10	4-7-14	6-10-18	8-12-21	10-14-23	11-17-24	13-18-26	14-20-28	16-21-29	
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.071	0.160	0.284	0.443	0.638					
	Static Pressure (in. w.g.)	0.068	0.154	0.274	0.428	0.616					
	Flow Rate (cfm)	70	105	140	175	209					
	Sound (NC)	19	32	41	48	54					
	Throw (ft.)	6-8-17	8-13-21	11-17-25	14-19-28	17-21-30					
Length = 48 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.012	0.027	0.049	0.076	0.109	0.149	0.194	0.246	0.304	0.437
	Static Pressure (in. w.g.)	0.010	0.022	0.039	0.060	0.087	0.118	0.154	0.195	0.241	0.347
	Flow Rate (cfm)	39	59	78	98	118	137	157	176	196	235
	Sound (NC)	-	-	-	20	26	31	35	39	42	48
	Throw (ft.)	1-2-6	2-4-10	3-6-12	5-8-14	6-10-15	7-11-16	8-12-18	10-13-19	11-14-20	12-15-22
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.026	0.058	0.103	0.162	0.233	0.317	0.413	0.523		
	Static Pressure (in. w.g.)	0.023	0.053	0.093	0.146	0.210	0.286	0.374	0.473		
	Flow Rate (cfm)	70	105	140	175	209	244	279	314		
	Sound (NC)	-	16	25	32	38	43	47	51		
	Throw (ft.)	3-6-11	6-8-14	8-11-17	9-13-19	11-14-20	13-16-22	14-17-23	14-18-25		
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.049	0.110	0.195	0.305	0.439	0.598				
	Static Pressure (in. w.g.)	0.046	0.104	0.185	0.289	0.417	0.567				
	Flow Rate (cfm)	109	164	218	273	327	382				
	Sound (NC)	-	26	35	42	48	53				
	Throw (ft.)	6-9-15	9-13-18	12-15-21	13-16-23	15-18-25	16-19-27				
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.085	0.192	0.341	0.532						
	Static Pressure (in. w.g.)	0.083	0.186	0.331	0.517						
	Flow Rate (cfm)	157	236	314	393						
	Sound (NC)	22	35	44	51						
	Throw (ft.)	8-12-18	12-15-22	14-18-25	16-20-28						
Length = 60 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.009	0.021	0.037	0.058	0.083	0.113	0.148	0.187	0.231	0.332
	Static Pressure (in. w.g.)	0.007	0.015	0.027	0.042	0.061	0.083	0.108	0.136	0.168	0.243
	Flow Rate (cfm)	39	59	78	98	118	137	157	176	196	235
	Sound (NC)	-	-	-	16	22	27	31	35	38	44
	Throw (ft.)	1-1-5	1-3-8	2-5-9	3-6-11	5-8-12	6-9-12	7-9-13	8-10-14	9-11-15	9-12-16
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.019	0.043	0.077	0.120	0.172	0.234	0.306	0.387	0.478	
	Static Pressure (in. w.g.)	0.017	0.037	0.067	0.104	0.150	0.204	0.266	0.337	0.416	
	Flow Rate (cfm)	70	105	140	175	209	244	279	314	349	
	Sound (NC)	-	-	20	27	33	38	42	46	50	
	Throw (ft.)	2-4-9	4-7-11	6-9-13	8-10-14	9-11-15	10-12-17	10-13-18	11-13-19	11-14-20	
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.035	0.079	0.141	0.220	0.317	0.432	0.564			
	Static Pressure (in. w.g.)	0.033	0.074	0.131	0.205	0.295	0.402	0.525			
	Flow Rate (cfm)	109	164	218	273	327	382	436			
	Sound (NC)	-	21	30	37	43	48	52			
	Throw (ft.)	4-7-11	7-10-14	9-11-16	10-12-18	11-14-19	12-15-21	13-16-22			
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.060	0.136	0.241	0.377	0.543					
	Static Pressure (in. w.g.)	0.058	0.130	0.231	0.361	0.520					
	Flow Rate (cfm)	157	236	314	393	471					
	Sound (NC)	16	29	38	46	51					
	Throw (ft.)	7-9-13	9-12-16	11-13-19	12-15-21	13-16-23					

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks "-" indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
P_{total} = P_{static} + P_{velocity}
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
- Blank area outside recommended operating range.
- Does not include effects of ceiling radiation damper (TBD4-FR).

PERFORMANCE DATA

TBD4 – Blade Pattern Controller, 1 Slot (continued)

Model TBD4100 1 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.032	0.072	0.128	0.200	0.288	0.392	0.512			
	Static Pressure (in. w.g.)	0.029	0.066	0.118	0.184	0.265	0.361	0.472			
	Flow Rate (cfm)	39	59	78	98	118	137	157			
	Sound (NC)	-	17	26	34	39	44	49			
	Throw (ft.)	1-3-9	3-7-13	6-9-18	7-11-21	9-13-23	10-15-24	12-18-26			
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.068	0.152	0.270	0.422	0.608					
	Static Pressure (in. w.g.)	0.065	0.146	0.260	0.407	0.586					
	Flow Rate (cfm)	70	105	140	175	209					
	Sound (NC)	19	32	41	48	54					
	Throw (ft.)	4-8-16	8-12-21	10-16-25	13-19-28	16-21-30					
Length = 48 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.014	0.032	0.056	0.088	0.127	0.172	0.225	0.285	0.352	0.507
	Static Pressure (in. w.g.)	0.012	0.026	0.046	0.072	0.104	0.142	0.185	0.235	0.290	0.417
	Flow Rate (cfm)	39	59	78	98	118	137	157	176	196	235
	NC	-	-	-	17	23	28	33	36	40	46
	Throw (ft.)	1-1-5	1-3-9	2-5-12	4-7-14	5-9-15	7-10-16	8-12-18	9-13-19	10-14-20	12-15-22
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.028	0.062	0.111	0.173	0.249	0.340	0.444	0.561	0.693	
	Static Pressure (in. w.g.)	0.025	0.057	0.101	0.158	0.227	0.309	0.404	0.511	0.631	
	Flow Rate (cfm)	70	105	140	175	209	244	279	314	349	
	Sound (NC)	-	-	24	31	37	42	46	50	53	
	Throw (ft.)	2-4-10	4-8-14	7-10-17	9-13-19	10-14-20	12-16-22	14-17-23	14-18-25	15-19-26	
Length = 48 in. Inlet = 10 in. [254]	Total Pressure (in. w.g.)	0.049	0.109	0.194	0.304	0.437	0.595				
	Static Pressure (in. w.g.)	0.046	0.104	0.184	0.288	0.415	0.565				
	Flow Rate (cfm)	109	164	218	273	327	382				
	Sound (NC)	-	25	35	42	48	53				
	Throw (ft.)	5-8-15	8-12-18	11-15-21	13-16-23	15-18-25	16-19-27				
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.079	0.179	0.317	0.496						
	Static Pressure (in. w.g.)	0.077	0.173	0.308	0.480						
	Flow Rate (cfm)	157	236	314	393						
	Sound (NC)	22	35	44	52						
	Throw (ft.)	8-12-18	12-15-22	14-18-25	16-20-28						
Length = 60 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.011	0.025	0.044	0.068	0.099	0.134	0.175	0.222	0.274	0.394
	Static Pressure (in. w.g.)	0.008	0.019	0.034	0.053	0.076	0.104	0.135	0.171	0.212	0.305
	Flow Rate (cfm)	39	59	78	98	118	137	157	176	196	235
	Sound (NC)	-	-	-	-	18	23	28	31	35	41
	Throw (ft.)	0-1-4	1-2-7	2-4-9	3-6-11	4-7-12	5-8-12	6-9-13	7-10-14	8-11-15	9-12-16
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.021	0.048	0.085	0.133	0.191	0.260	0.339	0.429	0.530	
	Static Pressure (in. w.g.)	0.019	0.042	0.075	0.117	0.168	0.229	0.299	0.379	0.468	
	Flow Rate (cfm)	70	105	140	175	209	244	279	314	349	
	Sound (NC)	-	-	18	25	31	36	41	44	48	
	Throw (ft.)	1-3-8	3-6-11	5-8-13	7-10-14	8-11-15	10-12-17	10-13-18	11-13-19	11-14-20	
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.037	0.082	0.146	0.228	0.329	0.447	0.584			
	Static Pressure (in. w.g.)	0.034	0.077	0.136	0.213	0.306	0.417	0.544			
	Flow Rate (cfm)	109	164	218	273	327	382	436			
	Sound (NC)	-	20	29	36	42	47	51			
	Throw (ft.)	3-7-11	7-10-14	9-11-16	10-12-18	11-14-19	12-15-21	13-16-22			
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.059	0.132	0.234	0.366	0.527					
	Static Pressure (in. w.g.)	0.056	0.126	0.224	0.351	0.505					
	Flow Rate (cfm)	157	236	314	393	471					
	Sound (NC)	16	29	38	46	51					
	Throw (ft.)	6-9-13	9-12-16	11-13-19	12-15-21	13-16-23					

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks "-" indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
P_{total} = P_{static} + P_{velocity}
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
- Blank area outside recommended operating range.
- Does not include effects of ceiling radiation damper (TBD4-FR).

PERFORMANCE DATA

TBD4 – Blade Pattern Controller, 1 Slot (continued)

Model TBD4150 1-1/2 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.020	0.044	0.078	0.123	0.177	0.240	0.314	0.397	0.490	0.706
	Static Pressure (in. w.g.)	0.017	0.039	0.068	0.107	0.154	0.210	0.274	0.347	0.428	0.616
	Flow Rate (cfm)	39	59	78	98	118	137	157	176	196	235
	Sound (NC)	-	-	17	24	30	35	39	43	46	52
	Throw (ft.)	1-2-8	2-5-12	4-8-16	6-10-20	8-12-23	9-14-24	10-16-26	12-18-28	13-20-29	16-23-32
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.040	0.089	0.159	0.248	0.357	0.486	0.634			
	Static Pressure (in. w.g.)	0.037	0.084	0.149	0.232	0.334	0.455	0.595			
	Flow Rate (cfm)	70	105	140	175	209	244	279			
	Sound (NC)	-	21	31	38	44	49	53			
	Throw (ft.)	3-7-14	7-11-21	9-14-25	12-18-28	14-21-30	16-23-33	19-25-35			
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.071	0.161	0.285	0.446	0.642					
	Static Pressure (in. w.g.)	0.069	0.155	0.275	0.430	0.620					
	Flow Rate (cfm)	109	164	218	273	327					
	NC	20	33	42	49	55					
	Throw (ft.)	7-11-22	11-16-27	15-22-31	18-24-34	22-27-38					
Length = 48 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.009	0.020	0.036	0.056	0.081	0.110	0.143	0.181	0.224	0.323
	Static Pressure (in. w.g.)	0.006	0.015	0.026	0.040	0.058	0.079	0.103	0.131	0.162	0.233
	Flow Rate (cfm)	39	59	78	98	118	137	157	176	196	235
	Sound (NC)	-	-	-	-	-	19	24	27	31	37
	Throw (ft.)	0-1-3	1-2-7	2-3-10	2-5-12	3-7-15	5-9-16	6-10-18	7-11-19	8-12-20	10-15-22
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.017	0.039	0.069	0.107	0.154	0.210	0.274	0.347	0.428	0.617
	Static Pressure (in. w.g.)	0.015	0.033	0.059	0.091	0.132	0.179	0.234	0.296	0.366	0.527
	Flow Rate (cfm)	70	105	140	175	209	244	279	314	349	419
	Sound (NC)	-	-	-	21	27	32	36	40	44	49
	Throw (ft.)	1-3-9	3-6-13	5-9-17	7-11-19	9-13-20	10-16-22	12-17-23	13-18-25	15-19-26	17-20-29
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.029	0.066	0.116	0.182	0.262	0.357	0.466	0.590		
	Static Pressure (in. w.g.)	0.027	0.060	0.106	0.166	0.240	0.326	0.426	0.539		
	Flow Rate (cfm)	109	164	218	273	327	382	436	491		
	Sound (NC)	-	15	25	32	38	43	47	51		
	Throw (ft.)	3-7-14	7-10-18	9-14-21	12-16-23	14-18-25	16-19-27	17-21-29	18-22-31		
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.046	0.104	0.184	0.288	0.415	0.565				
	Static Pressure (in. w.g.)	0.044	0.098	0.174	0.273	0.392	0.534				
	Flow Rate (cfm)	157	236	314	393	471	550				
	Sound (NC)	-	24	34	41	47	52				
	Throw (ft.)	6-10-18	10-15-22	13-18-25	16-20-28	18-22-30	19-23-33				
Length = 60 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.007	0.016	0.028	0.044	0.063	0.086	0.113	0.142	0.176	0.253
	Static Pressure (in. w.g.)	0.005	0.010	0.018	0.028	0.041	0.056	0.073	0.092	0.113	0.163
	Flow Rate (cfm)	39	59	78	98	118	137	157	176	196	235
	Sound (NC)	-	-	-	-	-	-	19	23	26	32
	Throw (ft.)	0-1-2	1-1-5	1-2-8	2-4-10	2-5-12	3-7-12	4-8-13	5-9-14	6-10-15	8-12-16
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.013	0.030	0.053	0.083	0.119	0.163	0.212	0.269	0.332	0.478
	Static Pressure (in. w.g.)	0.011	0.024	0.043	0.067	0.097	0.132	0.173	0.218	0.270	0.388
	Flow Rate (cfm)	70	105	140	175	209	244	279	314	349	419
	Sound (NC)	-	-	-	16	22	27	31	35	39	44
	Throw (ft.)	1-2-7	2-4-11	3-7-13	5-9-14	7-11-15	8-12-17	10-13-18	11-13-19	11-14-20	13-15-22
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.022	0.050	0.089	0.139	0.200	0.272	0.356	0.450	0.556	
	Static Pressure (in. w.g.)	0.020	0.044	0.079	0.123	0.178	0.242	0.316	0.400	0.494	
	Flow Rate (cfm)	109	164	218	273	327	382	436	491	545	
	Sound (NC)	-	-	19	26	32	37	42	45	49	
	Throw (ft.)	2-4-11	4-8-14	7-11-16	9-12-18	11-14-19	12-15-21	13-16-22	14-17-23	14-18-25	
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.035	0.078	0.139	0.217	0.312	0.425	0.555	0.703		
	Static Pressure (in. w.g.)	0.032	0.072	0.129	0.201	0.290	0.395	0.515	0.652		
	Flow Rate (cfm)	157	236	314	393	471	550	628	707		
	Sound (NC)	-	19	28	35	41	46	50	54		
	Throw (ft.)	4-8-13	8-12-16	11-13-19	12-15-21	13-16-23	14-18-25	15-19-27	16-20-28		

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks "-" indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
P_{total} = P_{static} + P_{velocity}
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
- Blank area outside recommended operating range.
- Does not include effects of ceiling radiation damper (TBD4-FR).

PERFORMANCE DATA

TBD4 – Blade Pattern Controller, 2 Slot

Model TBD475 3/4 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.027	0.049	0.076	0.109	0.149	0.194	0.246	0.304	0.437	0.595
	Static Pressure (in. w.g.)	0.022	0.039	0.060	0.087	0.118	0.154	0.195	0.241	0.347	0.473
	Flow Rate (cfm)	59	78	98	118	137	157	176	196	235	274
	Sound (NC)	-	18	25	31	36	40	44	48	53	58
	Throw (ft.)	2-5-12	4-8-16	6-10-20	8-12-23	9-14-24	10-16-26	12-18-28	13-20-29	16-23-32	18-24-35
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.058	0.103	0.162	0.233	0.317	0.413	0.523			
	Static Pressure (in. w.g.)	0.053	0.093	0.146	0.210	0.286	0.374	0.473			
	Flow Rate (cfm)	105	140	175	209	244	279	314			
	Sound (NC)	24	34	41	47	52	56	60			
	Throw (ft.)	7-11-21	9-14-25	12-18-28	14-21-30	16-23-33	19-25-35	21-26-37			
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.110	0.195	0.305	0.439	0.598					
	Static Pressure (in. w.g.)	0.104	0.185	0.289	0.417	0.567					
	Flow Rate (cfm)	164	218	273	327	382					
	Sound (NC)	37	47	54	60	65					
	Throw (ft.)	11-16-27	15-22-31	18-24-34	22-27-38	24-29-41					
Length = 48 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.021	0.033	0.048	0.065	0.085	0.108	0.133	0.191	0.260
	Static Pressure (in. w.g.)		0.011	0.018	0.025	0.035	0.045	0.057	0.071	0.102	0.138
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	19	24	27	31	37	42
	Throw (ft.)		2-3-10	2-5-12	3-7-15	5-9-16	6-10-18	7-11-19	8-12-20	10-15-22	12-16-23
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.024	0.042	0.066	0.095	0.129	0.168	0.213	0.263	0.379	0.515
	Static Pressure (in. w.g.)	0.018	0.032	0.050	0.072	0.098	0.128	0.162	0.201	0.289	0.393
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	15	22	28	33	38	41	45	51	55
	Throw (ft.)	3-6-13	5-9-17	7-11-19	9-13-20	10-16-22	12-17-23	13-18-25	15-19-26	17-20-29	18-22-31
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.042	0.074	0.116	0.167	0.227	0.297	0.375	0.463		
	Static Pressure (in. w.g.)	0.036	0.064	0.100	0.144	0.196	0.257	0.325	0.401		
	Flow Rate (cfm)	164	218	273	327	382	436	491	545		
	Sound (NC)	18	27	34	40	45	49	53	56		
	Throw (ft.)	7-10-18	9-14-21	12-16-23	14-18-25	16-19-27	17-21-29	18-22-31	19-23-33		
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.068	0.122	0.190	0.274	0.373	0.487	0.616			
	Static Pressure (in. w.g.)	0.063	0.112	0.174	0.251	0.342	0.447	0.565			
	Flow Rate (cfm)	236	314	393	471	550	628	707			
	Sound (NC)	28	37	44	50	55	59	63			
	Throw (ft.)	10-15-22	13-18-25	16-20-28	18-22-30	19-23-33	20-25-35	22-26-37			
Length = 60 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.017	0.026	0.037	0.051	0.066	0.084	0.103	0.149	0.202
	Static Pressure (in. w.g.)		0.007	0.010	0.015	0.020	0.026	0.033	0.041	0.059	0.080
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	18	22	26	31	36
	Throw (ft.)		1-2-8	2-4-10	2-5-12	3-7-12	4-8-13	5-9-14	6-10-15	8-12-16	9-12-18
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.018	0.032	0.050	0.072	0.098	0.128	0.163	0.201	0.289	0.393
	Static Pressure (in. w.g.)	0.012	0.022	0.035	0.050	0.068	0.089	0.112	0.138	0.199	0.271
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	17	23	28	32	36	39	45	50
	Throw (ft.)	2-4-11	3-7-13	5-9-14	7-11-15	8-12-17	10-13-18	11-13-19	11-14-20	13-15-22	14-17-23
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.031	0.056	0.087	0.125	0.170	0.222	0.281	0.347	0.500	0.680
	Static Pressure (in. w.g.)	0.026	0.046	0.071	0.103	0.140	0.182	0.231	0.285	0.410	0.558
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	21	28	34	39	43	47	50	56	61
	Throw (ft.)	4-8-14	7-11-16	9-12-18	11-14-19	12-15-21	13-16-22	14-17-23	14-18-25	16-19-27	17-21-29
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.050	0.090	0.140	0.201	0.274	0.358	0.453	0.560		
	Static Pressure (in. w.g.)	0.045	0.080	0.124	0.179	0.244	0.318	0.403	0.497		
	Flow Rate (cfm)	236	314	393	471	550	628	707	785		
	Sound (NC)	21	31	38	44	49	53	57	60		
	Throw (ft.)	8-12-16	11-13-19	12-15-21	13-16-23	14-18-25	15-19-27	16-20-28	17-21-30		

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks "-" indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
Ptotal = Pstatic + Pvelocity
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
- Blank area outside recommended operating range.
- Does not include effects of ceiling radiation damper (TBD4-FR).

PERFORMANCE DATA

TBD4 – Blade Pattern Controller, 2 Slot (continued)

Model TBD4100 1 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.032	0.056	0.088	0.127	0.172	0.225	0.285	0.352	0.507	0.690
	Static Pressure (in. w.g.)	0.026	0.046	0.072	0.104	0.142	0.185	0.235	0.290	0.417	0.568
	Flow Rate (cfm)	59	78	98	118	137	157	176	196	235	274
	Sound (NC)	-	-	17	23	28	33	36	40	46	50
	Throw (ft.)	2-4-11	3-7-14	5-9-18	7-11-22	8-13-24	10-14-26	11-16-28	12-18-29	14-22-32	17-24-35
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.062	0.111	0.173	0.249	0.340	0.444	0.561	0.693		
	Static Pressure (in. w.g.)	0.057	0.101	0.158	0.227	0.309	0.404	0.511	0.631		
	Flow Rate (cfm)	105	140	175	209	244	279	314	349		
	Sound (NC)	-	24	31	37	42	46	50	53		
	Throw (ft.)	5-10-19	9-13-25	11-16-28	13-19-30	15-22-33	17-25-35	19-26-37	21-28-39		
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.109	0.194	0.304	0.437	0.595					
	Static Pressure (in. w.g.)	0.104	0.184	0.288	0.415	0.565					
	Flow Rate (cfm)	164	218	273	327	382					
	Sound (NC)	25	35	42	48	53					
	Throw (ft.)	10-15-27	13-20-31	17-24-34	20-27-38	23-29-41					
Length = 48 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.026	0.041	0.059	0.080	0.105	0.133	0.164	0.236	0.321
	Static Pressure (in. w.g.)		0.016	0.025	0.037	0.050	0.065	0.082	0.102	0.146	0.199
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	17	21	25	30	35
	Throw (ft.)		1-2-9	2-4-11	2-6-13	3-8-16	4-9-18	6-10-19	7-11-20	9-13-22	10-16-23
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.028	0.049	0.077	0.111	0.151	0.198	0.250	0.309	0.444	0.605
	Static Pressure (in. w.g.)	0.022	0.039	0.062	0.089	0.121	0.158	0.199	0.246	0.355	0.483
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	-	21	26	30	34	37	43	48
	Throw (ft.)	2-4-12	3-8-16	5-10-19	8-12-20	9-14-22	11-16-23	12-18-25	13-19-26	16-20-29	18-22-31
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.046	0.082	0.129	0.185	0.252	0.330	0.417	0.515		
	Static Pressure (in. w.g.)	0.041	0.072	0.113	0.163	0.222	0.290	0.367	0.453		
	Flow Rate (cfm)	164	218	273	327	382	436	491	545		
	Sound (NC)	-	18	25	31	36	40	44	47		
	Throw (ft.)	5-9-18	8-12-21	10-15-23	12-18-25	14-19-27	16-21-29	18-22-31	19-23-33		
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.072	0.128	0.200	0.288	0.392	0.512	0.648			
	Static Pressure (in. w.g.)	0.066	0.118	0.185	0.266	0.362	0.472	0.598			
	Flow Rate (cfm)	236	314	393	471	550	628	707			
	Sound (NC)	17	26	34	39	44	49	53			
	Throw (ft.)	9-13-22	12-18-25	15-20-28	18-22-30	19-23-33	20-25-35	22-26-37			
Length = 60 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.021	0.032	0.047	0.063	0.083	0.105	0.129	0.186	0.253
	Static Pressure (in. w.g.)		0.011	0.017	0.024	0.033	0.043	0.054	0.067	0.096	0.131
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	-	17	20	26	31
	Throw (ft.)		1-2-6	1-3-9	2-4-11	2-5-12	3-6-13	4-8-14	5-9-15	6-11-16	8-12-18
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.022	0.039	0.060	0.087	0.118	0.154	0.195	0.241	0.347	0.472
	Static Pressure (in. w.g.)	0.016	0.029	0.045	0.064	0.087	0.114	0.145	0.178	0.257	0.350
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	-	16	21	25	29	32	38	43
	Throw (ft.)	1-3-10	2-5-13	4-8-14	5-10-15	7-11-17	8-13-18	10-13-19	11-14-20	13-15-22	14-17-23
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.036	0.064	0.099	0.143	0.195	0.254	0.322	0.397	0.572	
	Static Pressure (in. w.g.)	0.030	0.054	0.084	0.121	0.164	0.214	0.271	0.335	0.482	
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	
	Sound (NC)	-	-	20	26	31	35	39	42	48	
	Throw (ft.)	3-7-14	6-10-16	8-12-18	10-14-19	12-15-21	13-16-22	14-17-23	14-18-25	16-19-27	
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.055	0.098	0.152	0.220	0.299	0.390	0.494	0.610		
	Static Pressure (in. w.g.)	0.049	0.088	0.137	0.197	0.268	0.350	0.443	0.547		
	Flow Rate (cfm)	236	314	393	471	550	628	707	785		
	Sound (NC)	-	21	28	34	39	43	47	51		
	Throw (ft.)	7-11-16	10-13-19	12-15-21	13-16-23	14-18-25	15-19-27	16-20-28	17-21-30		

Performance Notes:

1. Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
2. Airflow is in cubic feet per minute [cfm].
3. NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
4. Blanks "-" indicate an NC level below 15.
5. All pressures are in inches of water column [in. w.g.].
6. Pressures not listed can be calculated using the following formula:
 $P_{total} = P_{static} + P_{velocity}$
7. Throw data is based on supply air and room air being at isothermal conditions.
8. Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
9. Blank area outside recommended operating range.
10. Does not include effects of ceiling radiation damper (TBD4-FR).

PERFORMANCE DATA

TBD4 – Blade Pattern Controller, 2 Slot (continued)

Model TBD4150 1-1/2 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.020	0.036	0.056	0.081	0.110	0.143	0.181	0.224	0.323	0.439
	Static Pressure (in. w.g.)	0.015	0.026	0.040	0.058	0.079	0.103	0.131	0.162	0.233	0.317
	Flow Rate (cfm)	59	78	98	118	137	157	176	196	235	274
	Sound (NC)	-	-	-	-	19	24	27	31	37	42
	Throw (ft.)	2-5-12	4-8-16	6-10-20	8-12-23	9-14-24	10-16-26	12-18-28	13-20-29	16-23-32	18-24-35
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.039	0.069	0.107	0.154	0.210	0.274	0.347	0.428	0.617	
	Static Pressure (in. w.g.)	0.033	0.059	0.091	0.132	0.179	0.234	0.296	0.366	0.527	
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	
	Sound (NC)	-	-	21	27	32	36	40	44	49	
	Throw (ft.)	7-11-21	9-14-25	12-18-28	14-21-30	16-23-33	19-25-35	21-26-37	23-28-39	25-30-43	
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.066	0.116	0.182	0.262	0.357	0.466	0.590			
	Static Pressure (in. w.g.)	0.060	0.106	0.166	0.240	0.326	0.426	0.539			
	Flow Rate (cfm)	164	218	273	327	382	436	491			
	Sound (NC)	15	25	32	38	43	47	51			
	Throw (ft.)	11-16-27	15-22-31	18-24-34	22-27-38	24-29-41	25-31-44	27-33-46			
Length = 48 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.017	0.027	0.038	0.052	0.068	0.086	0.107	0.154	0.209
	Static Pressure (in. w.g.)		0.007	0.011	0.016	0.022	0.028	0.036	0.044	0.064	0.087
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	-	-	16	22	27
	Throw (ft.)		1-1-6	1-2-9	1-3-11	2-5-13	3-6-15	3-7-17	4-9-19	6-11-22	8-13-23
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.018	0.032	0.049	0.071	0.097	0.126	0.160	0.197	0.284	0.387
	Static Pressure (in. w.g.)	0.012	0.022	0.034	0.049	0.066	0.086	0.109	0.135	0.194	0.265
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	-	-	17	21	25	28	34	39
	Throw (ft.)	1-3-10	2-5-13	3-7-17	5-10-20	6-12-22	8-13-23	10-15-25	11-17-26	13-20-29	16-22-31
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.029	0.052	0.081	0.116	0.158	0.207	0.262	0.323	0.465	0.633
	Static Pressure (in. w.g.)	0.023	0.042	0.065	0.094	0.128	0.167	0.211	0.261	0.375	0.511
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	-	16	22	27	31	35	38	44	49
	Throw (ft.)	3-6-16	5-10-21	8-13-23	10-16-25	12-18-27	14-21-29	16-22-31	17-23-33	21-25-36	22-27-39
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.044	0.079	0.123	0.177	0.241	0.314	0.398	0.491		
	Static Pressure (in. w.g.)	0.039	0.069	0.107	0.154	0.210	0.274	0.347	0.429		
	Flow Rate (cfm)	236	314	393	471	550	628	707	785		
	Sound (NC)	-	17	24	30	35	39	43	46		
	Throw (ft.)	6-11-22	10-15-25	13-19-28	15-22-30	18-23-33	20-25-35	22-26-37	23-28-39		
Length = 60 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.014	0.021	0.030	0.041	0.054	0.068	0.084	0.122	0.166
	Static Pressure (in. w.g.)		0.004	0.006	0.008	0.011	0.014	0.018	0.022	0.032	0.043
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	-	-	-	17	22
	Throw (ft.)		0-1-4	1-1-6	1-2-9	1-3-10	2-4-12	2-5-13	3-6-15	4-9-16	5-10-18
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.014	0.025	0.039	0.056	0.076	0.099	0.126	0.155	0.223	0.304
	Static Pressure (in. w.g.)	0.008	0.015	0.023	0.033	0.045	0.059	0.075	0.093	0.134	0.182
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	-	-	-	16	20	24	29	34
	Throw (ft.)	1-2-7	1-3-11	2-5-13	3-7-15	4-9-17	5-11-18	7-12-19	8-13-20	11-15-22	12-17-23
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.023	0.040	0.063	0.091	0.123	0.161	0.204	0.252	0.363	0.493
	Static Pressure (in. w.g.)	0.017	0.030	0.047	0.068	0.093	0.121	0.153	0.189	0.273	0.371
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	-	-	17	22	26	30	33	39	44
	Throw (ft.)	2-4-12	3-7-16	5-10-18	7-12-19	10-15-21	11-16-22	12-17-23	14-18-25	16-19-27	17-21-29
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.034	0.061	0.095	0.137	0.186	0.243	0.307	0.379	0.546	
	Static Pressure (in. w.g.)	0.029	0.051	0.079	0.114	0.155	0.203	0.257	0.317	0.456	
	Flow Rate (cfm)	236	314	393	471	550	628	707	785	942	
	Sound (NC)	-	-	19	25	30	34	38	41	47	
	Throw (ft.)	4-9-16	7-12-19	10-15-21	12-16-23	14-18-25	15-19-27	16-20-28	17-21-30	19-23-33	

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks "-" indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
P_{total} = P_{static} + P_{velocity}
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
- Blank area outside recommended operating range.
- Does not include effects of ceiling radiation damper (TBD4-FR).

PERFORMANCE DATA

TBD4 – Blade Pattern Controller, 3 Slot

Model TBD475 3/4 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.017	0.030	0.046	0.067	0.091	0.119	0.150	0.186	0.267	0.364
	Static Pressure (in. w.g.)	0.011	0.020	0.031	0.044	0.060	0.079	0.100	0.123	0.177	0.242
	Flow Rate (cfm)	59	78	98	118	137	157	176	196	235	274
	Sound (NC)	-	-	15	21	26	30	34	38	43	48
	Throw (ft.)	2-3-10	3-6-14	4-9-17	6-10-21	8-12-24	9-14-26	10-15-28	11-17-29	14-21-32	16-24-35
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.034	0.060	0.094	0.136	0.185	0.241	0.306	0.377	0.543	
	Static Pressure (in. w.g.)	0.028	0.050	0.079	0.113	0.154	0.202	0.255	0.315	0.454	
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	
	Sound (NC)	-	23	30	36	41	45	49	52	58	
	Throw (ft.)	5-9-18	8-12-25	10-15-28	12-18-30	14-21-33	16-25-35	18-26-37	20-28-39	25-30-43	
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.061	0.109	0.171	0.246	0.335	0.437	0.553	0.683		
	Static Pressure (in. w.g.)	0.056	0.099	0.155	0.223	0.304	0.397	0.503	0.620		
	Flow Rate (cfm)	164	218	273	327	382	436	491	545		
	Sound (NC)	25	35	42	48	53	57	61	64		
	Throw (ft.)	10-14-27	13-19-31	16-24-34	19-27-38	22-29-41	25-31-44	27-33-46	28-34-49		
Length = 48 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.013	0.021	0.030	0.041	0.054	0.068	0.084	0.121	0.165
	Static Pressure (in. w.g.)		0.004	0.006	0.008	0.011	0.014	0.018	0.022	0.032	0.043
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	-	18	21	27	32
	Throw (ft.)		1-2-8	1-3-11	2-5-13	3-7-15	4-8-17	5-10-19	6-11-20	8-13-22	10-15-23
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)		0.026	0.040	0.058	0.079	0.104	0.131	0.162	0.233	0.317
	Static Pressure (in. w.g.)		0.016	0.025	0.036	0.049	0.064	0.081	0.100	0.143	0.195
	Flow Rate (cfm)		140	175	209	244	279	314	349	419	489
	Sound (NC)		-	-	18	23	28	31	35	41	46
	Throw (ft.)		3-7-15	5-9-19	7-11-20	9-13-22	10-15-23	11-17-25	13-19-26	15-20-29	18-22-31
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.025	0.044	0.069	0.099	0.135	0.177	0.224	0.276	0.398	0.542
	Static Pressure (in. w.g.)	0.019	0.034	0.053	0.077	0.105	0.137	0.173	0.214	0.308	0.419
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	16	23	29	34	39	42	46	52	56
	Throw (ft.)	4-9-18	7-12-21	10-15-23	12-18-25	14-19-27	16-21-29	18-22-31	19-23-33	21-25-36	22-27-39
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.040	0.070	0.110	0.158	0.215	0.281	0.356	0.439	0.633	
	Static Pressure (in. w.g.)	0.034	0.060	0.094	0.136	0.185	0.241	0.305	0.377	0.543	
	Flow Rate (cfm)	236	314	393	471	550	628	707	785	942	
	Sound (NC)	16	26	33	39	44	48	52	55	61	
	Throw (ft.)	8-13-22	11-17-25	14-20-28	17-22-30	19-23-33	20-25-35	22-26-37	23-28-39	25-30-43	
Length = 60 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.011	0.017	0.024	0.032	0.042	0.054	0.066	0.095	0.130
	Static Pressure (in. w.g.)		0.001	0.001	0.001	0.002	0.002	0.003	0.004	0.005	0.007
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	-	-	17	22	27
	Throw (ft.)		1-1-6	1-2-8	1-3-10	2-4-12	2-6-13	3-7-14	4-8-15	6-10-16	8-12-18
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)		0.020	0.031	0.045	0.061	0.080	0.101	0.125	0.180	0.246
	Static Pressure (in. w.g.)		0.010	0.016	0.023	0.031	0.040	0.051	0.063	0.091	0.123
	Flow Rate (cfm)		140	175	209	244	279	314	349	419	489
	Sound (NC)		-	-	-	18	22	26	30	35	40
	Throw (ft.)		2-4-12	3-7-14	4-9-15	6-11-17	8-12-18	9-13-19	10-14-20	12-15-22	14-17-23
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.019	0.034	0.053	0.076	0.103	0.135	0.171	0.211	0.303	0.413
	Static Pressure (in. w.g.)	0.013	0.024	0.037	0.053	0.073	0.095	0.120	0.148	0.214	0.291
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	-	18	24	29	33	37	40	46	51
	Throw (ft.)	3-6-14	5-9-16	7-12-18	9-14-19	11-15-21	13-16-22	14-17-23	14-18-25	16-19-27	17-21-29
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.030	0.053	0.082	0.119	0.162	0.211	0.267	0.330	0.475	0.646
	Static Pressure (in. w.g.)	0.024	0.043	0.067	0.096	0.131	0.171	0.217	0.267	0.385	0.524
	Flow Rate (cfm)	236	314	393	471	550	628	707	785	942	1099
	Sound (NC)	-	20	27	33	38	42	46	49	55	60
	Throw (ft.)	6-10-16	9-13-19	11-15-21	13-16-23	14-18-25	15-19-27	16-20-28	17-21-30	19-23-33	20-25-35

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks "-" indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
P_{total} = P_{static} + P_{velocity}
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
- Blank area outside recommended operating range.
- Does not include effects of ceiling radiation damper (TBD4-FR).

PERFORMANCE DATA

TBD4 – Blade Pattern Controller, 3 Slot (continued)

Model TBD4100 1 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.017	0.029	0.046	0.066	0.090	0.117	0.149	0.183	0.264	0.360
	Static Pressure (in. w.g.)	0.011	0.019	0.030	0.044	0.059	0.077	0.098	0.121	0.174	0.237
	Flow Rate (cfm)	59	78	98	118	137	157	176	196	235	274
	Sound (NC)	-	-	-	-	19	23	27	30	36	41
	Throw (ft.)	1-2-9	2-4-12	3-7-15	4-9-19	6-11-22	8-12-25	9-14-28	10-15-29	12-19-32	14-22-35
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.028	0.049	0.077	0.111	0.151	0.197	0.250	0.308	0.444	0.604
	Static Pressure (in. w.g.)	0.022	0.039	0.062	0.089	0.121	0.157	0.199	0.246	0.354	0.482
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	16	22	27	31	35	38	44	49
	Throw (ft.)	3-8-17	6-11-22	9-14-28	11-17-30	13-19-33	15-22-35	17-25-37	18-28-39	22-30-43	26-33-46
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.042	0.075	0.117	0.169	0.230	0.300	0.379	0.468	0.675	
	Static Pressure (in. w.g.)	0.037	0.065	0.102	0.146	0.199	0.260	0.329	0.406	0.585	
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	
	Sound (NC)	-	-	22	28	33	37	41	44	50	
	Throw (ft.)	8-13-26	11-17-31	14-21-34	17-26-38	20-29-41	23-31-44	26-33-46	28-34-49	31-38-53	
Length = 48 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.017	0.026	0.037	0.051	0.066	0.084	0.103	0.149	0.203
	Static Pressure (in. w.g.)		0.007	0.010	0.015	0.020	0.026	0.033	0.041	0.059	0.080
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	-	18	21	27	32
	Throw (ft.)		1-1-6	1-2-9	1-3-11	2-5-13	3-6-15	3-7-17	4-9-19	6-11-22	8-13-23
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)		0.027	0.041	0.060	0.081	0.106	0.134	0.166	0.239	0.325
	Static Pressure (in. w.g.)		0.017	0.026	0.037	0.051	0.066	0.084	0.104	0.149	0.203
	Flow Rate (cfm)		140	175	209	244	279	314	349	419	489
	Sound (NC)		-	-	-	17	21	25	29	34	39
	Throw (ft.)		2-5-13	3-7-17	5-10-20	6-12-22	8-13-23	10-15-25	11-17-26	13-20-29	16-22-31
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.022	0.039	0.061	0.089	0.120	0.157	0.199	0.246	0.354	0.482
	Static Pressure (in. w.g.)	0.017	0.029	0.046	0.066	0.090	0.117	0.149	0.184	0.264	0.360
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	-	-	18	23	27	31	35	40	45
	Throw (ft.)	3-6-16	5-10-21	8-13-23	10-16-25	12-18-27	14-21-29	16-22-31	17-23-33	21-25-36	22-27-39
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.031	0.055	0.086	0.124	0.169	0.220	0.279	0.344	0.495	0.674
	Static Pressure (in. w.g.)	0.025	0.045	0.070	0.101	0.138	0.180	0.228	0.282	0.405	0.552
	Flow Rate (cfm)	236	314	393	471	550	628	707	785	942	1099
	Sound (NC)	-	-	17	23	28	32	36	40	45	50
	Throw (ft.)	9-13-22	12-18-25	15-20-28	18-22-30	19-23-33	20-25-35	22-26-37	23-28-39	25-30-43	27-33-47
Length = 60 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.014	0.022	0.031	0.043	0.056	0.071	0.087	0.126	0.171
	Static Pressure (in. w.g.)		0.004	0.006	0.009	0.012	0.016	0.020	0.025	0.036	0.049
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	-	15	19	25	30
	Throw (ft.)		0-1-4	1-1-6	1-2-9	1-3-10	2-4-12	2-5-13	3-6-15	4-9-16	5-10-18
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)		0.022	0.034	0.049	0.067	0.088	0.111	0.137	0.198	0.269
	Static Pressure (in. w.g.)		0.012	0.019	0.027	0.037	0.048	0.061	0.075	0.108	0.147
	Flow Rate (cfm)		140	175	209	244	279	314	349	419	489
	Sound (NC)		-	-	-	-	18	22	26	32	36
	Throw (ft.)		1-3-11	2-5-13	3-7-15	4-9-17	5-11-18	7-12-19	8-13-20	11-15-22	12-17-23
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.018	0.032	0.050	0.073	0.099	0.129	0.163	0.201	0.290	0.395
	Static Pressure (in. w.g.)	0.013	0.022	0.035	0.050	0.068	0.089	0.113	0.139	0.200	0.273
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	-	-	15	20	24	28	31	37	42
	Throw (ft.)	2-4-12	3-7-16	5-10-18	7-12-19	10-15-21	11-16-22	12-17-23	14-18-25	16-19-27	17-21-29
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.025	0.045	0.070	0.101	0.137	0.179	0.227	0.280	0.403	0.548
	Static Pressure (in. w.g.)	0.020	0.035	0.054	0.078	0.107	0.139	0.176	0.217	0.313	0.426
	Flow Rate (cfm)	236	314	393	471	550	628	707	785	942	1099
	Sound (NC)	-	-	-	20	25	29	33	36	42	47
	Throw (ft.)	4-9-16	7-12-19	10-15-21	12-16-23	14-18-25	15-19-27	16-20-28	17-21-30	19-23-33	20-25-35

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks "-" indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
 $P_{total} = P_{static} + P_{velocity}$
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
- Blank area outside recommended operating range.
- Does not include effects of ceiling radiation damper (TBD4-FR).

PERFORMANCE DATA

TBD4 – Blade Pattern Controller, 3 Slot (continued)

Model TBD4150 1-1/2 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.012	0.021	0.033	0.047	0.064	0.083	0.105	0.130	0.187	0.255
	Static Pressure (in. w.g.)	0.006	0.011	0.017	0.024	0.033	0.043	0.055	0.068	0.098	0.133
	Flow Rate (cfm)	59	78	98	118	137	157	176	196	235	274
	Sound (NC)	-	-	-	-	-	18	21	25	31	36
	Throw (ft.)	1-2-6	1-3-11	2-4-13	3-6-16	4-8-18	5-11-21	6-12-24	7-13-26	11-16-32	12-18-35
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.019	0.034	0.053	0.077	0.105	0.137	0.173	0.213	0.307	0.418
	Static Pressure (in. w.g.)	0.014	0.024	0.038	0.054	0.074	0.097	0.122	0.151	0.217	0.296
	Flow Rate (cfm)	105	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	-	16	21	25	29	32	38	43
	Throw (ft.)	2-5-14	4-9-19	6-12-23	9-14-28	11-16-33	12-19-35	14-21-37	16-23-39	19-28-43	22-33-46
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.029	0.051	0.080	0.115	0.157	0.205	0.259	0.320	0.461	0.627
	Static Pressure (in. w.g.)	0.023	0.041	0.064	0.093	0.126	0.165	0.209	0.258	0.371	0.505
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	-	16	22	27	31	35	39	44	49
	Throw (ft.)	5-11-22	9-15-29	12-18-34	15-22-38	17-26-41	19-29-44	22-33-46	24-34-49	29-38-53	33-41-58
Length = 48 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.012	0.019	0.028	0.038	0.049	0.062	0.077	0.110	0.150
	Static Pressure (in. w.g.)		0.002	0.004	0.005	0.007	0.009	0.012	0.014	0.021	0.028
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	-	-	17	23	28
	Throw (ft.)		0-1-3	1-1-5	1-2-8	1-3-11	2-3-13	2-4-14	2-5-16	3-8-19	5-11-22
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)		0.019	0.030	0.043	0.058	0.076	0.096	0.118	0.170	0.232
	Static Pressure (in. w.g.)		0.009	0.014	0.020	0.027	0.036	0.045	0.056	0.081	0.110
	Flow Rate (cfm)		140	175	209	244	279	314	349	419	489
	Sound (NC)		-	-	-	-	16	20	23	29	34
	Throw (ft.)		1-3-11	2-4-14	3-6-17	4-8-20	5-11-22	6-13-25	8-14-26	11-17-29	13-20-31
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.015	0.027	0.043	0.062	0.084	0.110	0.139	0.172	0.247	0.337
	Static Pressure (in. w.g.)	0.010	0.018	0.027	0.039	0.054	0.070	0.089	0.109	0.158	0.214
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	-	-	-	18	22	26	29	35	40
	Throw (ft.)	2-4-13	3-7-17	5-10-22	7-13-25	9-15-27	12-17-29	13-20-31	15-22-33	17-25-36	20-27-39
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.021	0.038	0.059	0.085	0.116	0.152	0.192	0.237	0.341	0.465
	Static Pressure (in. w.g.)	0.016	0.028	0.044	0.063	0.086	0.112	0.142	0.175	0.252	0.342
	Flow Rate (cfm)	236	314	393	471	550	628	707	785	942	1099
	Sound (NC)	-	-	-	18	23	27	31	34	40	45
	Throw (ft.)	3-8-19	6-13-25	10-16-28	13-19-30	15-22-33	17-25-35	19-26-37	21-28-39	25-30-43	27-33-47
Length = 60 in. Inlet = 6 in.	Total Pressure (in. w.g.)		0.011	0.017	0.024	0.032	0.042	0.053	0.066	0.095	0.129
	Static Pressure (in. w.g.)		0.001	0.001	0.001	0.002	0.002	0.003	0.004	0.005	0.007
	Flow Rate (cfm)		78	98	118	137	157	176	196	235	274
	Sound (NC)		-	-	-	-	-	-	-	20	25
	Throw (ft.)		0-1-2	0-1-3	1-1-5	1-2-7	1-2-9	1-3-11	2-3-12	2-5-15	3-7-17
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)		0.016	0.025	0.036	0.049	0.064	0.080	0.099	0.143	0.195
	Static Pressure (in. w.g.)		0.006	0.009	0.013	0.018	0.024	0.030	0.037	0.053	0.073
	Flow Rate (cfm)		140	175	209	244	279	314	349	419	489
	Sound (NC)		-	-	-	-	-	17	21	27	32
	Throw (ft.)		1-2-7	1-3-11	2-4-13	2-5-15	3-7-18	4-9-19	5-11-20	7-13-22	9-15-23
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.013	0.023	0.036	0.051	0.070	0.091	0.115	0.142	0.205	0.278
	Static Pressure (in. w.g.)	0.007	0.013	0.020	0.029	0.039	0.051	0.065	0.080	0.115	0.156
	Flow Rate (cfm)	164	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	-	-	-	-	19	23	26	32	37
	Throw (ft.)	1-2-10	2-4-14	3-7-17	4-10-19	6-12-21	8-14-22	10-16-23	12-17-25	14-19-27	16-21-29
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.017	0.031	0.049	0.070	0.095	0.124	0.157	0.194	0.280	0.381
	Static Pressure (in. w.g.)	0.012	0.021	0.033	0.048	0.065	0.084	0.107	0.132	0.190	0.259
	Flow Rate (cfm)	236	314	393	471	550	628	707	785	942	1099
	Sound (NC)	-	-	-	-	19	24	28	31	37	42
	Throw (ft.)	2-5-15	4-9-19	6-12-21	9-15-23	12-17-25	13-19-27	15-20-28	17-21-30	19-23-33	20-25-35

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks “-” indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
P_{total} = P_{static} + P_{velocity}
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
- Blank area outside recommended operating range.
- Does not include effects of ceiling radiation damper (TBD4-FR).

PERFORMANCE DATA

TBD4 – Blade Pattern Controller, 4 Slot

Model TBDA75 3/4 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.021	0.033	0.048	0.065	0.085	0.108	0.133	0.191	0.260
	Static Pressure (in. w.g.)	0.011	0.018	0.025	0.035	0.045	0.057	0.071	0.102	0.138
	Flow Rate (cfm)	78	98	118	137	157	176	196	235	274
	Sound (NC)	-	-	-	19	24	27	31	37	42
	Throw (ft.)	2-4-12	3-7-15	4-9-19	6-11-22	8-12-25	9-14-28	10-15-29	12-19-32	14-22-35
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.042	0.066	0.095	0.129	0.168	0.213	0.263	0.379	0.515
	Static Pressure (in. w.g.)	0.032	0.050	0.072	0.098	0.128	0.162	0.201	0.289	0.393
	Flow Rate (cfm)	140	175	209	244	279	314	349	419	489
	Sound (NC)	15	22	28	33	38	41	45	51	55
	Throw (ft.)	6-11-22	9-14-28	11-17-30	13-19-33	15-22-35	17-25-37	18-28-39	22-30-43	26-33-46
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.074	0.116	0.167	0.227	0.297	0.375	0.463	0.667	
	Static Pressure (in. w.g.)	0.064	0.100	0.144	0.196	0.257	0.325	0.401	0.577	
	Flow Rate (cfm)	218	273	327	382	436	491	545	654	
	Sound (NC)	27	34	40	45	49	53	56	62	
	Throw (ft.)	11-17-31	14-21-34	17-26-38	20-29-41	23-31-44	26-33-46	28-34-49	31-38-53	
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.019	0.029	0.042	0.057	0.075	0.094	0.116	0.168	0.228
	Static Pressure (in. w.g.)	0.009	0.014	0.019	0.027	0.035	0.044	0.054	0.078	0.106
	Flow Rate (cfm)	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	-	17	21	25	28	34	39
	Throw (ft.)	2-5-13	3-7-17	5-10-20	6-12-22	8-13-23	10-15-25	11-17-26	13-20-29	16-22-31
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.031	0.049	0.070	0.096	0.125	0.158	0.195	0.281	0.382
	Static Pressure (in. w.g.)	0.021	0.033	0.048	0.065	0.085	0.107	0.133	0.191	0.260
	Flow Rate (cfm)	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	16	22	27	31	35	39	44	49
	Throw (ft.)	5-10-21	8-13-23	10-16-25	12-18-27	14-21-29	16-22-31	17-23-33	21-25-36	22-27-39
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.049	0.076	0.109	0.149	0.195	0.246	0.304	0.438	0.596
	Static Pressure (in. w.g.)	0.039	0.060	0.087	0.118	0.155	0.196	0.242	0.348	0.474
	Flow Rate (cfm)	314	393	471	550	628	707	785	942	1099
	Sound (NC)	18	25	31	36	40	44	48	54	58
	Throw (ft.)	10-15-25	13-19-28	15-22-30	18-23-33	20-25-35	22-26-37	23-28-39	25-30-43	27-33-47
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.015	0.023	0.033	0.044	0.058	0.074	0.091	0.131	0.178
	Static Pressure (in. w.g.)	0.005	0.007	0.010	0.014	0.018	0.023	0.028	0.041	0.056
	Flow Rate (cfm)	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	-	-	16	20	23	29	34
	Throw (ft.)	1-3-11	2-5-13	3-7-15	4-9-17	5-11-18	7-12-19	8-13-20	11-15-22	12-17-23
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.024	0.038	0.054	0.074	0.096	0.122	0.150	0.216	0.294
	Static Pressure (in. w.g.)	0.014	0.022	0.032	0.043	0.056	0.071	0.088	0.126	0.172
	Flow Rate (cfm)	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	-	17	22	26	30	33	39	44
	Throw (ft.)	3-7-16	5-10-18	7-12-19	10-15-21	11-16-22	12-17-23	14-18-25	16-19-27	17-21-29
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.037	0.058	0.083	0.113	0.148	0.187	0.231	0.333	0.453
	Static Pressure (in. w.g.)	0.027	0.042	0.061	0.083	0.108	0.137	0.169	0.243	0.331
	Flow Rate (cfm)	314	393	471	550	628	707	785	942	1099
	Sound (NC)	-	20	26	31	35	39	42	48	53
	Throw (ft.)	7-12-19	10-15-21	12-16-23	14-18-25	15-19-27	16-20-28	17-21-30	19-23-33	20-25-35

Performance Notes:

1. Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
2. Airflow is in cubic feet per minute [cfm].
3. NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
4. Blanks "-" indicate an NC level below 15.
5. All pressures are in inches of water column [in. w.g.].
6. Pressures not listed can be calculated using the following formula:
P_{total} = P_{static} + P_{velocity}
7. Throw data is based on supply air and room air being at isothermal conditions.
8. Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
9. Blank area outside recommended operating range.
10. Does not include effects of ceiling radiation damper (TBD4-FR).

PERFORMANCE DATA

TBD4 – Blade Pattern Controller, 4 Slot (continued)

Model TBD4100 1 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.023	0.036	0.052	0.070	0.092	0.116	0.143	0.207	0.281
	Static Pressure (in. w.g.)	0.013	0.020	0.029	0.040	0.052	0.066	0.081	0.117	0.159
	Flow Rate (cfm)	78	98	118	137	157	176	196	235	274
	Sound (NC)	-	-	-	-	19	23	26	32	37
	Throw (ft.)	1-3-11	2-5-14	3-7-17	4-10-19	6-11-22	7-12-25	9-14-28	11-17-32	13-19-35
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.038	0.059	0.085	0.116	0.152	0.192	0.237	0.341	0.465
	Static Pressure (in. w.g.)	0.028	0.044	0.063	0.086	0.112	0.142	0.175	0.252	0.343
	Flow Rate (cfm)	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	18	23	27	31	34	40	45
	Throw (ft.)	4-10-20	7-12-25	10-15-29	11-17-33	13-20-35	15-22-37	16-25-39	20-29-43	23-33-46
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.057	0.089	0.129	0.175	0.229	0.289	0.357	0.514	
	Static Pressure (in. w.g.)	0.047	0.074	0.106	0.144	0.189	0.239	0.295	0.425	
	Flow Rate (cfm)	218	273	327	382	436	491	545	654	
	Sound (NC)	-	18	24	29	33	37	40	46	
	Throw (ft.)	10-15-31	13-19-34	15-23-38	18-27-41	20-31-44	23-33-46	26-34-49	31-38-53	
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.021	0.033	0.047	0.064	0.083	0.105	0.130	0.188	0.255
	Static Pressure (in. w.g.)	0.011	0.017	0.024	0.033	0.043	0.055	0.068	0.098	0.133
	Flow Rate (cfm)	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	-	-	18	21	25	31	36
	Throw (ft.)	1-3-12	2-5-15	3-7-18	4-10-21	6-12-23	7-13-25	9-15-26	12-18-29	14-21-31
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.030	0.048	0.068	0.093	0.122	0.154	0.190	0.274	0.373
	Static Pressure (in. w.g.)	0.020	0.032	0.046	0.063	0.082	0.104	0.128	0.184	0.251
	Flow Rate (cfm)	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	-	-	19	23	27	31	36	41
	Throw (ft.)	3-8-18	5-11-23	8-14-25	11-16-27	12-18-29	14-21-31	15-23-33	18-25-36	21-27-39
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.042	0.066	0.095	0.129	0.169	0.214	0.264	0.380	0.517
	Static Pressure (in. w.g.)	0.032	0.050	0.073	0.099	0.129	0.163	0.201	0.290	0.395
	Flow Rate (cfm)	314	393	471	550	628	707	785	942	1099
	Sound (NC)	-	-	19	24	28	32	36	41	46
	Throw (ft.)	7-13-25	11-17-28	13-20-30	15-23-33	18-25-35	20-26-37	22-28-39	25-30-43	27-33-47
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.017	0.027	0.039	0.053	0.070	0.088	0.109	0.157	0.213
	Static Pressure (in. w.g.)	0.007	0.012	0.017	0.023	0.030	0.038	0.047	0.067	0.091
	Flow Rate (cfm)	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	-	-	-	19	22	28	33
	Throw (ft.)	1-2-8	1-3-12	2-5-14	3-6-16	4-8-18	5-10-19	6-12-20	8-14-22	11-16-23
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.025	0.039	0.056	0.077	0.100	0.127	0.157	0.226	0.307
	Static Pressure (in. w.g.)	0.015	0.024	0.034	0.046	0.061	0.077	0.095	0.136	0.185
	Flow Rate (cfm)	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	-	-	16	21	24	28	34	38
	Throw (ft.)	2-5-15	3-8-18	5-11-19	7-13-21	9-15-22	11-16-23	12-18-25	15-19-27	17-21-29
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.035	0.054	0.078	0.106	0.138	0.175	0.216	0.311	0.423
	Static Pressure (in. w.g.)	0.025	0.038	0.055	0.075	0.098	0.124	0.153	0.221	0.301
	Flow Rate (cfm)	314	393	471	550	628	707	785	942	1099
	Sound (NC)	-	-	16	21	25	29	33	38	43
	Throw (ft.)	5-10-19	7-13-21	10-16-23	12-18-25	14-19-27	16-20-28	17-21-30	19-23-33	20-25-35

Performance Notes:

1. Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
2. Airflow is in cubic feet per minute [cfm].
3. NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
4. Blanks “-” indicate an NC level below 15.
5. All pressures are in inches of water column [in. w.g.].
6. Pressures not listed can be calculated using the following formula:
Ptotal = Pstatic + Pvelocity
7. Throw data is based on supply air and room air being at isothermal conditions.
8. Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
9. Blank area outside recommended operating range.
10. Does not include effects of ceiling radiation damper (TBD4-FR).

PERFORMANCE DATA

TBD4 – Blade Pattern Controller, 4 Slot (continued)

Model TBD4150 1-1/2 in. Slot Width

Length = 24 in. Inlet = 6 in.	Total Pressure (in. w.g.)	0.017	0.026	0.037	0.051	0.066	0.084	0.103	0.149	0.203
	Static Pressure (in. w.g.)	0.007	0.010	0.015	0.020	0.026	0.033	0.041	0.059	0.080
	Flow Rate (cfm)	78	98	118	137	157	176	196	235	274
	Sound (NC)	-	-	-	-	-	18	21	27	32
	Throw (ft.)	1-2-7	1-3-12	2-4-14	3-6-16	3-7-19	4-9-21	5-12-23	7-14-28	10-16-33
Length = 24 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.027	0.041	0.060	0.081	0.106	0.134	0.166	0.239	0.325
	Static Pressure (in. w.g.)	0.017	0.026	0.037	0.051	0.066	0.084	0.104	0.149	0.203
	Flow Rate (cfm)	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	-	17	21	25	29	34	39
	Throw (ft.)	3-6-17	4-9-21	6-12-25	8-14-29	11-17-33	12-19-37	14-21-39	17-25-43	19-29-46
Length = 24 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.039	0.061	0.089	0.120	0.157	0.199	0.246	0.354	0.482
	Static Pressure (in. w.g.)	0.029	0.046	0.066	0.090	0.117	0.149	0.184	0.264	0.360
	Flow Rate (cfm)	218	273	327	382	436	491	545	654	763
	NC	-	-	18	23	27	31	35	40	45
	Throw (ft.)	6-13-26	10-16-32	13-19-38	15-23-41	17-26-44	19-29-46	22-32-49	26-38-53	30-41-58
Length = 48 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.015	0.024	0.034	0.046	0.061	0.077	0.095	0.136	0.185
	Static Pressure (in. w.g.)	0.005	0.008	0.012	0.016	0.021	0.026	0.032	0.046	0.063
	Flow Rate (cfm)	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	-	-	-	17	20	26	31
	Throw (ft.)	1-2-7	1-3-11	2-4-15	2-6-17	3-7-20	4-9-22	5-11-24	7-15-29	10-17-31
Length = 48 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.022	0.034	0.048	0.066	0.086	0.109	0.135	0.194	0.264
	Static Pressure (in. w.g.)	0.012	0.018	0.026	0.035	0.046	0.059	0.072	0.104	0.142
	Flow Rate (cfm)	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	-	-	-	18	22	25	31	36
	Throw (ft.)	2-4-15	3-7-19	4-10-23	6-13-27	8-15-29	10-17-31	12-19-33	15-23-36	18-27-39
Length = 48 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.029	0.046	0.066	0.090	0.118	0.149	0.184	0.264	0.360
	Static Pressure (in. w.g.)	0.019	0.030	0.044	0.059	0.078	0.098	0.121	0.175	0.238
	Flow Rate (cfm)	314	393	471	550	628	707	785	942	1099
	Sound (NC)	-	-	-	19	23	27	30	36	41
	Throw (ft.)	4-9-22	6-14-27	9-16-30	13-19-33	15-22-35	16-25-37	18-27-39	22-30-43	26-33-47
Length = 60 in. Inlet = 8 in.	Total Pressure (in. w.g.)	0.013	0.020	0.029	0.039	0.051	0.065	0.080	0.116	0.157
	Static Pressure (in. w.g.)	0.003	0.005	0.006	0.009	0.012	0.015	0.018	0.026	0.035
	Flow Rate (cfm)	140	175	209	244	279	314	349	419	489
	Sound (NC)	-	-	-	-	-	-	17	23	28
	Throw (ft.)	1-1-5	1-2-7	1-3-10	2-4-14	2-5-15	3-6-17	3-7-19	5-10-22	6-14-23
Length = 60 in. Inlet = 10 in.	Total Pressure (in. w.g.)	0.018	0.028	0.040	0.055	0.072	0.091	0.112	0.162	0.220
	Static Pressure (in. w.g.)	0.008	0.013	0.018	0.025	0.032	0.041	0.050	0.072	0.098
	Flow Rate (cfm)	218	273	327	382	436	491	545	654	763
	Sound (NC)	-	-	-	-	15	19	23	28	33
	Throw (ft.)	1-3-11	2-4-15	3-6-18	4-9-21	5-11-22	6-14-23	8-15-25	11-18-27	14-21-29
Length = 60 in. Inlet = 12 in.	Total Pressure (in. w.g.)	0.024	0.038	0.055	0.074	0.097	0.123	0.152	0.218	0.297
	Static Pressure (in. w.g.)	0.014	0.022	0.032	0.044	0.057	0.072	0.089	0.128	0.175
	Flow Rate (cfm)	314	393	471	550	628	707	785	942	1099
	Sound (NC)	-	-	-	16	20	24	27	33	38
	Throw (ft.)	3-6-17	4-9-21	6-13-23	8-15-25	10-17-27	13-20-28	14-21-30	17-23-33	20-25-35

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks "-" indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:
Ptotal = Pstatic + Pvelocity
- Throw data is based on supply air and room air being at isothermal conditions.
- Throw data is given in feet [ft] to terminal velocities of:
150 fpm (minimum)
100 fpm (middle)
50 fpm (maximum)
- Blank area outside recommended operating range.
- Does not include effects of ceiling radiation damper (TBD4-FR).