

PERFORMANCE DATA

80 / 81 / 82 / 80FF / 80FH - 0° Core

Core Area (sq. ft.)	Nominal Size	Core Velocity (fpm) Velocity Pressure (in. w.g.) Neg. Static Pressure (in. w.g.)	NC20							NC30			
			300	400	500	600	700	800	1000	1200	1400	1500	
			0.006	0.010	0.016	0.022	0.031	0.040	0.062	0.090	0.122	0.14	
			0.013	0.021	0.034	0.047	0.066	0.085	0.132	0.192	0.260	0.298	
0.15	7 x 4 6 x 5	Flow Rate (cfm)	45	60	75	90	105	120	150	180	210	225	
		Sound (NC)	-	-	-	-	-	-	22	28	34	37	
0.18	8 x 4 7 x 5	Flow Rate (cfm)	54	72	90	108	126	144	180	216	252	270	
		Sound (NC)	-	-	-	-	-	-	22	29	35	38	
0.22	10 x 4 8 x 5	Flow Rate (cfm)	66	88	110	132	154	176	220	264	308	330	
		Sound (NC)	-	-	-	-	-	-	23	30	36	38	
0.26	12 x 4 10 x 5	Flow Rate (cfm)	78	104	130	156	182	208	260	312	364	390	
		Sound (NC)	-	-	-	-	-	15	24	31	36	39	
0.30	14 x 4	Flow Rate (cfm)	90	120	150	180	210	240	300	360	420	450	
		Sound (NC)	-	-	-	-	-	16	24	31	37	40	
0.34	16 x 4 12 x 5	Flow Rate (cfm)	102	136	170	204	238	272	340	408	476	510	NC40
		Sound (NC)	-	-	-	-	-	16	25	32	37	40	
0.39	18 x 4 14 x 5	Flow Rate (cfm)	117	156	195	234	273	312	390	468	546	585	
		Sound (NC)	-	-	-	-	-	17	25	32	38	41	
0.46	20 x 4 16 x 5	Flow Rate (cfm)	138	184	230	276	322	368	460	552	644	690	
		Sound (NC)	-	-	-	-	-	18	26	33	39	41	
0.52	24 x 4 18 x 5	Flow Rate (cfm)	156	208	260	312	364	416	520	624	728	780	
		Sound (NC)	-	-	-	-	-	18	26	33	39	42	
0.60	28 x 4 20 x 5	Flow Rate (cfm)	180	240	300	360	420	480	600	720	840	900	
		Sound (NC)	-	-	-	-	-	19	27	34	40	42	
0.69	30 x 4 24 x 5	Flow Rate (cfm)	207	276	345	414	483	552	690	828	966	1035	
		Sound (NC)	-	-	-	-	-	19	28	34	40	43	
0.81	36 x 4 28 x 5	Flow Rate (cfm)	243	324	405	486	567	648	810	972	1134	1215	
		Sound (NC)	-	-	-	-	-	20	28	35	41	43	
0.90	40 x 4 30 x 5	Flow Rate (cfm)	270	360	450	540	630	720	900	1080	1260	1350	
		Sound (NC)	-	-	-	-	15	20	29	35	41	44	
1.07	48 x 4 36 x 5	Flow Rate (cfm)	321	428	535	642	749	856	1070	1284	1498	1605	
		Sound (NC)	-	-	-	-	16	21	29	36	42	45	
1.18	34 x 6 24 x 8	Flow Rate (cfm)	354	472	590	708	826	944	1180	1416	1652	1770	
		Sound (NC)	-	-	-	-	16	21	30	37	42	45	
1.34	60 x 4 48 x 5	Flow Rate (cfm)	402	536	670	804	938	1072	1340	1608	1876	2010	
		Sound (NC)	-	-	-	-	17	22	30	37	43	45	
1.60	72 x 4 30 x 8	Flow Rate (cfm)	480	640	800	960	1120	1280	1600	1920	2240	2400	
		Sound (NC)	-	-	-	-	17	22	31	38	44	46	
1.80	60 x 5 48 x 6	Flow Rate (cfm)	540	720	900	1080	1260	1440	1800	2160	2520	2700	
		Sound (NC)	-	-	-	-	18	23	31	38	44	47	
2.08	72 x 5 60 x 6	Flow Rate (cfm)	624	832	1040	1248	1456	1664	2080	2496	2912	3120	
		Sound (NC)	-	-	-	-	18	23	32	39	45	47	
2.45	72 x 6 48 x 8	Flow Rate (cfm)	735	980	1225	1470	1715	1960	2450	2940	3430	3675	
		Sound (NC)	-	-	-	-	19	24	33	39	45	48	
2.78	36 x 12 30 x 14	Flow Rate (cfm)	834	1112	1390	1668	1946	2224	2780	3336	3892	4170	
		Sound (NC)	-	-	-	-	20	25	33	40	46	48	
3.11	60 x 8 48 x 10	Flow Rate (cfm)	933	1244	1555	1866	2177	2488	3110	3732	4354	4665	
		Sound (NC)	-	-	-	-	20	25	33	40	46	49	
3.61	72 x 8 60 x 10	Flow Rate (cfm)	1083	1444	1805	2166	2527	2888	3610	4332	5054	5415	
		Sound (NC)	-	-	-	-	21	26	34	41	47	49	
4.29	48 x 14 36 x 18	Flow Rate (cfm)	1287	1716	2145	2574	3003	3432	4290	5148	6006	6435	NC50
		Sound (NC)	-	-	-	15	21	26	35	42	47	50	
4.65	72 x 10 48 x 16	Flow Rate (cfm)	1395	1860	2325	2790	3255	3720	4650	5580	6510	6975	
		Sound (NC)	-	-	-	16	22	27	35	42	48	50	
5.58	72 x 12 60 x 14	Flow Rate (cfm)	1674	2232	2790	3348	3906	4464	5580	6696	7812	8370	
		Sound (NC)	-	-	-	16	22	27	36	43	48	51	
6.25	72 x 14 60 x 16	Flow Rate (cfm)	1875	2500	3125	3750	4375	5000	6250	7500	8750	9375	
		Sound (NC)	-	-	-	17	23	28	36	43	49	51	

Performance Notes:

- Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
- Airflow is in cubic feet per minute [cfm].
- NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
- Blanks "-" indicate an NC level below 15.
- All pressures are in inches of water column [in. w.g.].
- Pressures not listed can be calculated using the following formula:

$$P_{\text{total}} = P_{\text{static}} + P_{\text{velocity}}$$

- Grille tested without damper. Corrections for grille with damper:
 - Multiply negative static pressure by 1.3
 - Add 6 to listed NC.
- The performance tables are based on grilles with F border. For ED border the following correction factors must be applied due to the reduced core area of this border:

Listed Core Area	Multiply Total Pressure	Add NC
.15 - .30	2.4	+15
.34 - .90	1.9	+10
1.07 - 1.80	1.4	+5
2.08 - 6.25	1.2	+2

- Does not include pressure drop through filter on FF, FH models
- Does not include effects of ceiling radiation damper (80-FR, 80FF-FR, 81-FR, 82-FR).

PERFORMANCE DATA

85 - 45° Core

Core Area (sq. ft.)	Nominal Size	Core Velocity (fpm) Velocity Pressure (in. w.g.) Neg. Static Pressure (in. w.g.)	NC20				NC30		
			100 0.001	200 0.002	300 0.006	400 0.010	500 0.016	600 0.022	700 0.031
			0.01	0.034	0.068	0.112	0.166	0.228	0.298
0.15	7x4	Flow Rate (cfm)	15	30	45	60	75	90	105
	6x5	Sound (NC)	-	-	-	15	21	26	30
0.18	8x4	Flow Rate (cfm)	18	36	54	72	90	108	126
	7x5	Sound (NC)	-	-	-	16	22	27	31
0.22	10x4	Flow Rate (cfm)	22	44	66	88	110	132	154
	8x5	Sound (NC)	-	-	-	16	22	27	32
0.26	12x4	Flow Rate (cfm)	26	52	78	104	130	156	182
	10x5	Sound (NC)	-	-	-	17	23	28	32
0.30	14x4	Flow Rate (cfm)	30	60	90	120	150	180	210
		Sound (NC)	-	-	-	18	24	28	33
0.34	16x4	Flow Rate (cfm)	34	68	102	136	170	204	238
	12x5	Sound (NC)	-	-	-	18	24	29	33
0.39	18x4	Flow Rate (cfm)	39	78	117	156	195	234	273
	14x5	Sound (NC)	-	-	-	18	24	29	34
0.46	20x4	Flow Rate (cfm)	46	92	138	184	230	276	322
	16x5	Sound (NC)	-	-	-	19	25	30	34
0.52	24x4	Flow Rate (cfm)	52	104	156	208	260	312	364
	18x5	Sound (NC)	-	-	-	19	26	30	35
0.60	28x4	Flow Rate (cfm)	60	120	180	240	300	360	420
	20x5	Sound (NC)	-	-	-	20	26	31	35
0.69	30x4	Flow Rate (cfm)	69	138	207	276	345	414	483
	24x5	Sound (NC)	-	-	-	20	27	31	36
0.81	36x4	Flow Rate (cfm)	81	162	243	324	405	486	567
	28x5	Sound (NC)	-	-	-	21	27	32	36
0.90	40x4	Flow Rate (cfm)	90	180	270	360	450	540	630
	30x5	Sound (NC)	-	-	-	21	27	32	37
1.07	48x4	Flow Rate (cfm)	107	214	321	428	535	642	749
	36x5	Sound (NC)	-	-	-	22	28	33	37
1.18	34x6	Flow Rate (cfm)	118	236	354	472	590	708	826
	24x8	Sound (NC)	-	-	-	22	28	33	38
1.34	60x4	Flow Rate (cfm)	134	268	402	536	670	804	938
	48x5	Sound (NC)	-	-	15	23	29	34	38
1.60	72x4	Flow Rate (cfm)	160	320	480	640	800	960	1120
	30x8	Sound (NC)	-	-	16	23	30	34	39
1.80	60x5	Flow Rate (cfm)	180	360	540	720	900	1080	1260
	48x6	Sound (NC)	-	-	16	24	30	35	39
2.08	72x5	Flow Rate (cfm)	208	416	624	832	1040	1248	1456
	60x6	Sound (NC)	-	-	17	24	30	35	40
2.45	72x6	Flow Rate (cfm)	245	490	735	980	1225	1470	1715
	48x8	Sound (NC)	-	-	17	25	31	36	40
2.78	36x12	Flow Rate (cfm)	278	556	834	1112	1390	1668	1946
	30x14	Sound (NC)	-	-	18	25	32	36	41
3.11	60x8	Flow Rate (cfm)	311	622	933	1244	1555	1866	2177
	48x10	Sound (NC)	-	-	18	26	32	37	41
3.61	72x8	Flow Rate (cfm)	361	722	1083	1444	1805	2166	2527
	60x10	Sound (NC)	-	-	19	26	32	37	42
4.29	48x14	Flow Rate (cfm)	429	858	1287	1716	2145	2574	3003
	36x18	Sound (NC)	-	-	19	27	33	38	42
4.65	72x10	Flow Rate (cfm)	465	930	1395	1860	2325	2790	3255
	48x16	Sound (NC)	-	-	20	27	33	38	42
5.58	72x12	Flow Rate (cfm)	558	1116	1674	2232	2790	3348	3906
	60x14	Sound (NC)	-	-	20	28	34	39	43
6.25	72x14	Flow Rate (cfm)	625	1250	1875	2500	3125	3750	4375
	60x16	Sound (NC)	-	-	21	28	34	39	44

Performance Notes

1. Tested in accordance with ASHRAE Standard 70 – 2023 Method of Testing for Rating the Performance of Air Outlets and Inlets.
2. Airflow is in cubic feet per minute [cfm].
3. NC, sound pressure levels, are based on a room absorption of 10 dB re 10⁻¹² Watts, and a single diffuser/grille.
4. Blanks "-" indicate an NC level below 15.
5. All pressures are in inches of water column [in. w.g.].
6. Pressures not listed can be calculated using the following formula:

$$P_{\text{total}} = P_{\text{static}} + P_{\text{velocity}}$$